

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR
OFFICE OF THE EXECUTIVE ENGINEER, ZONE (PHE-I)

NO. JDA/Ex.En./PHE-I/2016/D- 57-

DATE: 04.02.2016

Addenda NO. 1 to NIT No. 11/2015-16

The treated sewage quality at page no. 46 s.no. 9 shall be read as follows:-

S.No.	Parameter	Value
1	PH	6.5-9.0
2	BOD (mg/L)	Not more than 10
3	COD (mg/L)	Not more than 50
4	TSS (mg/L)	Not more than 20
5	NH4-N (mg/L)	Not more than 5
6	N-total (mg/L)	Not more than 10
7	Faecal Coliform (MPN/100 ml)	Less than 100
8	Oil & Grease	NIL


Executive Engineer (PHE-I)
JDA, Jaipur