


JAIPUR DEVELOPMENT AUTHORITY



Bid Document

For

**P/L/J of DI/HDPE pipeline and construction of 2 nos. 200 mm dia tubewell with 3 years O&M for
water supply scheme Shiv Enclave, JDA, Jaipur.**

Cost : Rs. 37.27 Lacs

NIB No. 08/2021-22

**Executive Engineer (PHE-I)
Jaipur Development Authority
Jaipur**

जयपुर विकास प्राधिकरण, जयपुर

राम किशोर व्यास भवन, कमरा नं. 135, प्रथम-तल, मुख्य भवन,
इन्दिरा सर्किल जवाहर लाल नेहरू मार्ग, जयपुर-302004

क्रमांक जविप्रा/अधि.अभि. (पीएचई- I)/2021-22/D-493

दिनांक : 10.12.2021

निविदा सूचना

निविदा सूचना सं0 अधि. अभि. (पीएचई- I)/08/2021-22

जयपुर विकास प्राधिकरण द्वारा **“P/L/J of DI/HDPE pipeline and construction of 2 nos. 200 mm dia tubewell with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur.”** जिसकी अनुमानित लागत रु 37.27 लाख के लिए ऑनलाईन बिड्स दिनांक 23.12.2021 को सायं 6:00 बजे तक आमन्त्रित की जाती है। निविदा बोली का ऑनलाईन आवेदन व भुगतान जविप्रा पोर्टल पर करने की अन्तिम तिथी 23.12.2021 को सायं 6:00 बजे तक है। निविदा बोली के दस्तावेजों का विस्तृत विवरण www.sppp.rajasthan.gov.in, www.eproc.rajasthan.gov.in and www.jda.urban.rajasthan.gov.in पर देखा जा सकता है।

निविदा में भाग लेने वालों को निम्न शर्तों की पूर्ति करनी होगी।

1. निविदा दाता जयपुर विकास प्राधिकरण की वेबसाइट www.jda.urban.rajasthan.gov.in पर पंजीकृत हो एवं निविदा में भाग लेने के लिए बोलीदाता को आवेदन करने के लिए दस्तावेज शुल्क, अमानत राशि, आर.आई.एस. एल. प्रोसेसिंग शुल्क ऑनलाईन जमा करनी होगी।
2. ऑनलाईन निविदा प्रस्तुत करने के लिए निविदा दाताओं का राजस्थान सरकार के ई-प्राक्यूमेंट पोर्टल www.eproc.rajasthan.gov.in पर पंजीकृत हो।

(एम.एल. जॉगिड)
अधिशायी अभियंता (पीएचई- I)
जविप्रा, जयपुर।

JAIPUR DEVELOPMENT AUTHORITY

Room No. 135, Main Building, First Floor, Ram Kishore Vyas Bhavan, Indira Circle, JawaharLal Nehru Marg, Jaipur – 302 004
Telephone: +91-141-2569696 E.mail: zephe1jda@yahoo.in

No: - JDA/EE/PHE-I/2021-22/D-493

Dated: 10.12.2021

NOTICE INVITING BID

NIB No. : JDA/EE (PHE-I)/08/2021-22

Online Bids are invited up-to 6.00 PM of 23.12.2021 for **"P/L/J of DI/HDPE pipe line and construction of 2 nos. 200 mm dia tube well with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur"** Estimated cost of 37.27 Lacs. The last date for Applying Bid and making online payment on JDA portal is up-to 6.00 PM of 23.12.2021 Details may be seen in the Bidding Document at our office or the State Public Procurement Portal website www.sppp.rajasthan.gov.in, www.eproc.rajasthan.gov.in and www.jda.urban.rajasthan.gov.in.

To participate in the bid, bidder has to be:

1. Registered on JDA website www.jda.urban.rajasthan.gov.in, For participating in the Bid, the Bidder has to apply for the Bid and pay the Bidding Document Fee, RISL Processing Fee and Bid Security Deposit, online only.
2. Registered on e-Procurement Portal of Government of Rajasthan www.eproc.rajasthan.gov.in for online e-Bid submission.

(M.L. Jangid)
Executive Engineer (PHE-I)
JDA, Jaipur

JAIPUR DEVELOPMENT AUTHORITY

Room No. 135, Main Building, First Floor, Ram Kishore Vyas Bhavan, Indira Circle, JawaharLal Nehru Marg, Jaipur – 302 004

Telephone: +91-141-2569696 E.mail: zepheljda@yahoo.in**Bid No: - JDA/EE/PHE-I/2021-22/D-493****Dated: 10.12.2021****NOTICE INVITING BID**

NIB No. : JDA/EE(PHE-I)/08/2021-22

Name & Address of the Procuring Entity	➤ Name: Executive Engineer (PHE-I), Jaipur Development Authority Address: Room No. 135, Main Building, First Floor, Ram Kishore Vyas Bhavan, Indira Circle, JawaharLal Nehru Marg, Jaipur – 302 004 Telephone: +91-141-2569696 E.mail: zepheljda@yahoo.in
Subject Matter of Procurement	➤ P/L/J of DI/HDPE pipeline and construction of 2 nos. 200 mm dia tubewell with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur. ➤ Job No. : 172/2021-22
Bid Procedure	➤ Single-Stage tender (eg. Single-envelope) open competitive eBid procedure at http://eproc.rajasthan.gov.in
Bid Evaluation Criteria (Selection Method)	➤ L1 (eg. Least Cost Based Selection (LCBS)-L1)
Websites for downloading Bidding Document, Corrigendum's, Addendums, etc.	➤ Websites: www.sppp.rajasthan.gov.in , www.eproc.rajasthan.gov.in , www.jda.urban.rajasthan.gov.in
Website for online Bid application participation and payment *	➤ Website: www.jda.urban.rajasthan.gov.in ➤ For participating in the Bid, the Bidder has to apply for this Bid and pay the Bidding Document Fee, RISL Processing Fee and Bid Security Deposit, online only. ○ Bidding document fee: Rs. 500/- (Rupees Five Hundred only) ○ RISL Processing Fee: Rs. 1000/- (Rupees One Thousand only) Requisite Bid Security Deposit
Estimated Procurement Cost	➤ INR 3727266.00/- (Rupees Thirty Seven Lacs Twenty Seven Thousand Two Hundred and Sixty Six Only)
Bid Security Deposit	➤ All the eligible contractors should be submit bid security declaration on non-judicial stamp of Rs. 50/- as per order issued for finance department (GF&AR) GoR dated 23.12.2020 (Declaration attached with tender document) in lies of Bid Security. It is mandatory to submit bid security bid security declaration in prescribed format along with the bid. ➤ Eligibility: Bidder who is A and AA class contractor registered in other Government Department and Bidder registered as contractor AA, A, B, C & D in JDA.
Date/Time/Place of Pre-Bid	➤ NA
Applying Bid and making Online Payment on JDA portal (www.jda.urban.rajasthan.gov.in)	➤ Start Date: 13.12.2021 at 9.30 AM ➤ End Date: 23.12.2021 at 06.00 PM
Bid Submission on e-Procurement Portal of GOR	➤ Start Date: 13.12.2021 at 9.30 AM ➤ End Date: 23.12.2021 at 06.00 PM
Date/Time/Place of Technical Bid Opening	➤ 24.12.2021 at 11.00 PM
Date/ Time/ Place of Financial Bid Opening	➤ Will be intimated later to the Technically qualified bidders in case of Two Bid
Bid Validity	➤ 120 days from the date of opening of bid

Completion period of work	➤ 06 Months
* Jaipur Development Authority has decided to receive Earnest Money Deposit (EMD) (Bid Security), Tender Fee and RISL processing fee online through JDA Portal. The bid security options available in tender for participants are as mentioned below:	
A. Payment Options: Option-1: Bank Guarantee (BG) against EMD / Bid Security Bidder may opt Bank Guarantee (BG) against EMD (Bid Security), for which bidder requires to prepare BG before applying in the tender. The details of BG requires to be fed on JDA portal before paying balance amount (Tender Fee + RISL Processing Fee). This amount will be paid through Payment Gateway only, option to make balance payment through EFT (RTGS/NEFT) will not be available. If bidder does not opt for BG against EMD, options of making complete payment through Payment Gateway or through EFT (NEFT / RTGS) will be available. Option-2: Electronic Fund Transfer (EFT: NEFT/RTGS) If the bidder selects payment mode as EFT (NEFT/RTGS), "Paying Slip for EFT (NEFT/RTGS)" will be generated by the system for the complete amount. The payment can be made from any Bank any Branch using this Paying Slip through NEFT/RTGS (Claim against payment made through EFT in any other JDA bank account will not be acceptable and bidder stands disqualified from participation in the bid applied for). After successful transaction through NEFT/RTGS, as per the standard procedures it may take 4 to 24 hours in process of confirmation of EFT through Auto-Process depending on the time of EFT done. Therefore, option to make payment through EFT (NEFT/RTGS) will be available till 48 hours prior to closing date of bid participation. Option-3: Payment Gateway (Aggregator) The facility to make payment through Debit Card, Credit Card, Net banking etc., will be available. User can use this facility from anywhere any time till the closing date & time of bid participation. B. Bid Participation Receipt After confirming payment, the bidder will get Bid Participation Receipt on the basis of which user will get the payment details along with other details for bidding on e-Procurement portal of GOR. - In case of BG as the remaining payment will be done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis. - In case complete payment is done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis. - In case complete payment is done through EFT (NEFT/RTGS), on confirmation of payment from ICICI Bank (Auto Process) "Bid Participation Receipt" will be available on Login of Bidder on JDA portal.	
Note: Bidder (authorised signatory) shall submit their offer on-line in Electronic formats both for technical and financial proposal. In case, any of the bidders fails to pay the Tender Fee, BSD, and RISL Processing Fee, online (subject to confirmation), its Bid shall not be accepted. To participate in online bidding process, Bidders must procure a Digital Signature Certificate (Type III) as per Information Technology Act-2000 using which they can digitally sign their electronic bids. Bidders can procure the same from any CCA approved certifying agency, i.e. TCS, Safecrypt, Ncode etc. Bidders who already have a valid Digital Signature Certificate (DSC) need not procure a new DSC. Also, bidders must register on http://eproc.rajasthan.gov.in (bidders already registered on http://eproc.rajasthan.gov.in before 30-09-2011 must register again). JDA will not be responsible for delay in online submission due to any reason. For this, bidders are requested to upload the complete bid well advance in time so as to avoid 11th hour issues like slow speed; choking of web site due to heavy load or any other unforeseen problems. Bidders are also advised to refer "Bidders Manual Kit" available at eProc website for further details about the e-Tendering process. Training for the bidders on the usage of e-Tendering System (eProcurement) is also being arranged by DoIT&C, GoR on a regular basis. Bidders interested for training may contact e-Procurement Cell, DoIT&C for booking the training slot. Contact No: 0141-4022688 (Help desk 10 am to 6 pm on all working days) e-mail: eproc@rajasthan.gov.in Address : e-Procurement Cell, JDA, Yojana Bhawan, Tilak Marg, C-Scheme, Jaipur The procuring entity reserves the complete right to cancel the bid process and reject any or all of the Bids. No contractual obligation whatsoever shall arise from the bidding document/ bidding process unless and until a formal contract is signed and executed between the procuring entity and the successful bidder. Procurement entity disclaims any factual/ or other errors in the bidding document (the onus is purely on the individual bidders to verify such information) and the information provided therein are intended only to help the bidders to prepare a logical bid-proposal. The provisions of RTPPA Act 2012 and Rules 2013 thereto shall be applicable for this procurement. Furthermore, in case of any inconsistency in any of the provisions of this bidding document with the RTPP Act 2012 and Rules thereto, the later shall prevail.	

(M.L. Jangid)
Executive Engineer (PHE-I)
JDA, Jaipur

Annexure: 3
As part of NIB Document

Process for Participation & Depositing Payment Online

JAIPUR DEVELOPMENT AUTHORITY, has decided to receive Bidding document fee, RISL Processing Fee and Bid Security Deposit (BSD) through online mode only for which the bidder has to get registered himself on JDA portal www.jaipurjda.org.

To participate in the bid, bidder has to be:

1. Registered on JDA website www.jaipurjda.org (by depositing Rs. 500.00 online, the validity of which remains 3 (three) years).
For participating in the Bid, the Bidder has to apply for this Bid and pay the Bid Document Fee, RISL Processing Fee and Bid Security Deposit, online only.
2. Registered on e-Procurement Portal of Government of Rajasthan www.eproc.rajasthan.gov.in for online e-Bid submission.

Methods for depositing on line amount

- Online through Internet Banking, Debit Card or Credit Card.
- In case the amount exceeds the online payment limit, the payment may be made through RTGS / NEFT / Transfer in Bank Account Number **675401700586** IFSC Code **ICIC0006754** of ICICI BANK Limited, JDA Campus Jaipur.

In case of RTGS / NEFT / Transfer the bidder is required to deposit the requisite amount in the dedicated bank account number as mentioned above and has to get the UTR / Reference number from the bank. This number requires to be updated while applying the bid on JDA portal.

While participation in the bid, a receipt will be generated through the system showing the submission details as per **Annexure-4**. The bidder is required to fill the instrument numbers for various heads on e-Procurement portal www.eproc.rajasthan.gov.in as mentioned in the receipt.

More details about Registration Process, Terms and Conditions and FAQ along with contact detail is available on JDA website www.jaipurjda.org under [eServices](#)>>JDA Tender

Section A-1

Instructions to Bidders

JAIPUR DEVELOPMENT AUTHORITY JAIPUR

SCHEDULE AND SPECIFICATIONS

Name of work:- "P/L/J of DI/HDPE pipeline and construction of 2 nos. 200 mm dia tubewell with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur."

- | | |
|-------------------------------------|--|
| 1. NIB No. | :- E.E.(PHE-I)/08/2021-22 |
| 2. Bid cost | :- Rs. 37.27 Lacs |
| 3. Cost of the tender documents | :- Rs 500/- |
| 4. Earnest Money | :- All the eligible contractors should be submit bid security declaration on non-judicial stamp of Rs. 50/- as per order issued for finance department (GF&AR) GoR dated 23.12.2020 (Declaration attached with tender document) in lies of Bid Security. It is mandatory to submit bid security bid security declaration in prescribed format along with the bid.
Eligibility: Bidder who is A and AA class contractor registered in other Government Department and Bidder registered as contractor AA, A, B, C & D in JDA |
| 5. Bid Submission Start date & Time | :- 13.12.2021 (9:30 AM) |
| 6. Bid Submission End date & Time | :- 23.12.2021 (upto 6:00 P.M.) |
| 7. Bid Opening date & Time | :- 24.12.2021 at 11:00 A.M. |
| 8. Completion period of work | :- 06 Months |

SCHEDULE 'A' : INFORMATION USEFUL FOR THE CONTRACTORS :

The tenderer should see the site and fully understand the condition of the site before tendering and include all lead, lifts etc. **Percentage above/Below on the rates as given in the 'G'-Schedule.** The work shall be carried out in accordance with the Rajasthan PWD, PHED and JDA detailed specification and to the entire satisfaction of the Engineer-In charge of the work.

The bid will be opened only of those bidders deposit proper bid security, processing fee, tender fee, GST registration, clearance certificate and copy of registration of contractor in required category are found to be in order. The Bid security, tender fee will be accepted through online payment only.

SCHEDULE 'B' : LIST OF THE DRAWING TO BE SUPPLIED BY THE DEPARTMENT:

The drawings may also be seen in the office of undersigned.

SCHEDULE 'C' : LIST OF THE DRAWING TO BE SUPPLIED BY THE CONTRACTOR:

List of the drawing to be supplied by the contractor NIL. But the contractor shall have to arrange at his own cost drawings required for the work after depositing necessary cost within JDA.

SCHEDULE 'D' : TEST OF THE MATERIALS :

The test of the material and workmanship shall be conducted by the JDA staff as necessary, The result of such tests should confirm to the standard laid down in the Indian standards and or the standards laid down in the detailed specification of the Public Works Deptt,. Proper quality control is required to be maintained by the contractor. Qualified personnel as required under the contractor enlistments rules duly approved by the Deptt. shall have to be engaged at site by the contractor. The deptt. reserves the right to engage such staff and recover the expenses from the contractor on such account in case of his failure to do so.

SCHEDULE 'E' : SAMPLES OF THE MATERIALS :

The samples of the material to be used by the contractor shall be deposited 15 days in advance with the Engineer In charge and be got approved by him before use.

SCHEDULE 'F' : TIME OF COMPLETION :

The work should start within Ten days of issue of work order and complete within **06 months**.

SCHEDULE 'H' : Special condition Attached separately.

“If any bidder quotes a rate below than the schedule “G” rates, i.e. rates below than “at par”, then the bidder has to deposit the difference amount i.e. difference amount of the rates as per “at par” and quoted “below”, as “Work Performance Guarantee”. This amount has to be deposited before the commencement of work and will be refunded after expiry of DLP only in case of satisfactory performance of work during DLP. Lowest bidder will be issued LOA (Letter of Acceptance) and within 14 days period he has to deposit difference amount in the form of B.G/FDR/NSC. The validity of B.G/FDR/NSC shall be for a period three months beyond of DLP period of work. In case of non deposition of the same in specified period, the bid security will be forfeited. In case work is not completed satisfactorily, the “Work Performance Guarantee” will be forfeited and other action will be taken as per Contract Agreement.”

Annexure A : Compliance with the code of Integrity and No Conflict of Interest

Annexure B : Declaration by the Bidder regarding Qualifications

Annexure C : Grievance Redressal during Procurement Process

Annexure D : Additional Conditions of Contract

Annexure E : DLP period for various type of works. Office order D-29 dated 11.03.2016

Annexure F : Payment mechanism for participating in tender: Office order D-399 dated 04.10.2016.

Annexure G : GST Circular for participating in tender: Office order D-172 dated 12.07.2017.

SIGNATURE OF CONTRACTOR

**Executive Engineer (PHE-I)
Jaipur Development Authority,
Jaipur**

with full address & Mobile No. :



राजस्थान सरकार नगरीय विकास एवं आवासन विभाग

क्रमांक:- प.01(24)नविवि / 1/2020 लूज

जयपुर, दिनांक:- 20 SEP 2021

आदेश

नगरीय विकास एवं आवासन विभाग के अर्न्तगत विभिन्न विकास कार्यों की निविदाओं में संवेदकों द्वारा बी.एस.आर. दर से कम दर डालने पर अन्तर राशि (AT PAR की दर से जितनी कम है) वर्क परफोरमेंस गारन्टी के रूप में कार्य प्रारम्भ करने से पूर्व ली जाएगी तथा इसे कार्य के सन्तोषजनक रूप से पूर्ण होने के पश्चात दोष निवारण अवधि में कार्य की स्थिति सन्तोषजनक पाए जाने पर, दोषनिवारण अवधि उपरान्त वापस लौटा दिया जावेगा। न्यूनतम दरदाता की बोली नियमानुसार स्वीकृत कर Letter of acceptance (LOA) जारी किया जावेगा एवं बी.एस.आर. दर से कम दर की अन्तर राशि की BG/FDR/NSC प्रस्तुत करने हेतु 14 दिवस का समय दिया जायेगा। अन्तर राशि जमा नहीं कराने पर BID SECURITY की राशि नियमानुसार जब्त कर ली जावे। यदि संवेदक वर्क परफोरमेंस गारन्टी राशि जमा कराने के पश्चात कार्य सन्तोषजनक रूप से पूर्ण नहीं करता है अथवा दोष निवारण अवधि में कार्य में खराबी होती है तो उसकी वर्क परफोरमेंस गारन्टी की राशि जब्त कर ली जावे एवं अनुबन्धानुसार अन्य कार्यवाही भी संपादित की जावे। यह आदेश तुरन्त प्रभाव से लागू किये जाते हैं। यह आदेश उन सभी निविदाओं पर लागू होगा जो कि भविष्य में जारी होगी तथा वे निविदाएं जो इस आदेश के जारी होने की दिनांक तक अप्राप्त हैं, इस सम्बन्ध में निविदा दस्तावेजों में आवश्यक संशोधन तुरन्त संबन्धित उपापन अधिकारी द्वारा किया जावे एवं नवीन सभी निविदाओं में उक्त शर्तों का समावेश किया जाना सुनिश्चित किया जावे।

यह आदेश सक्षम स्तर से अनुमोदित है।


 (कुन्जीलाल मीना)
 प्रमुख शासन सचिव
 नगरीय विकास विभाग

कार्यालय का पता- खाद्य भवन, द्वितीय तल, कमरा नं0 7203, शासन सचिवालय, जयपुर-302005
ई-मेल आई.डी. CEUDHRAJASTHAN@GMAIL.COM



राजस्थान सरकार नगरीय विकास एवं आवासन विभाग

प्रतिलिपि निम्नांकित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित है :-

1. विशिष्ट सहायक, माननीय मंत्री महोदय नगरीय विकास एवं आवासन विभाग, राजस्थान जयपुर।
2. निजी सचिव, आयुक्त, राजस्थान आवासन मण्डल, जयपुर।
3. निजी सचिव, शासन सचिव स्वायत्त शासन विभाग, राजस्थान जयपुर
4. निजी सचिव, निदेशक, स्थानीय निकाय विभाग, जयपुर।
5. वरिष्ठ उपशासन सचिव, नगरीय विकास विभाग को प्रेषित कर लेख है कि इस आदेश को नगरीय विकास विभाग की वेबसाइट पर अपलोड करावें।
6. सचिव, विकास प्राधिकरण, जयपुर/जोधपुर/अजमेर।
7. सचिव, नगर विकास न्यास, अलवर, आबू, बाडमेर, भरतपुर, बीकानेर, भीलवाड़ा, चित्तौड़गढ़, जैसलमेर, पाली, कोटा, उदयपुर, सीकर, श्रीगंगानगर एवं सवाईमाधोपुर।
8. रक्षित पत्रावली।


 मुख्य अभियन्ता (मुख्यालय)
 नगरीय विकास विभाग

कार्यालय का पता— खाद्य भवन, द्वितीय तल, कमरा नं० 7203, शासन सचिवालय, जयपुर-302005
ई-मेल आईडी CEJUDHRAIASTHAN@GMAIL.COM

TENDER FOR WORKS

I/We hereby tender for the execution for the Jaipur Development Authority, Jaipur of the work specified in the underwritten memorandum within the time specified in such memorandum at the rates, (in figure)% (as well as in words) Percent below/above the amount, entered in the schedule G in all respects in accordance with the specifications, designs, drawings and instructions in writing referred to in Rule I in all respects in accordance conditions with such conditions so far as applicable. I/We have visited the site of work and am/are fully aware of all the difficulties and conditions likely to affect carrying out the work, I/We have fully acquainted myself/ourselves about the conditions in regard to accessibility of site and quarries/kilns nature and the extent of ground, working conditions including stacking, of materials, installation of tools & plant, conditions effecting accommodation and movement of labour etc. required for the satisfactory execution of contract.

Memorandum

- (a) **General description of work..-** :
- (b) **Estimated cost** : **Rs. 37.27 Lacs**
- (c) **Earnest money** : All the eligible contractors should be submit bid security declaration on non-judicial stamp of Rs. 50/- as per order issued for finance department (GF&AR) GoR dated 23.12.2020 (Declaration attached with tender document) in lies of Bid Security. It is mandatory to submit bid security bid security declaration in prescribed format along with the bid.
Eligibility: Bidder who is A and AA class contractor registered in other Government Department and Bidder registered as contractor AA, A, B, C & D in JDA
- (d) **Security Deposit :**
- (i) "The security deposit @ 10% of the gross amount of the running bill shall be deducted from each running bill and shall be refunded as per rules on completion of the contract as per terms and conditions. However, the amount of security deposit deducted from running bills shall not be converted into any mode of securities like bank guarantee, FDR etc. The earned money deposited shall however be adjusted while deducting security deposit from first running bill of the contractor. There will be no maximum limit of security deposit.
However, a contractor may elect to deposit of full amount of 10% security deposit in the shape of bank guarantee or any acceptable form of security before or at the time of executing agreement. In that case earnest money may be refunded only after deposition of full 10% as above. However, in case during execution cost of works exceeds as shown at the time of depositing 10% as above, balance security deposit shall be deducted from the Running Account Bills."
- (ii) Bank Guarantee shall in all cases be payable at the headquarter of the Division or the nearest District Headquarters.
- (e) Time allowed for the completion of work (to be reckoned from the 10th day after the date of written order to commence the work) in **06 months**. Should this tender be accepted in whole or in Part, I/We hereby agree to abide by and fulfill all the terms and provisions of the conditions of contract annexed here to and of the Notice Inviting Tender, or in default thereof, to forfeit and pay to the Governor of Rajasthan or his successors in office, the sum of money mentioned in the said conditions.

Validity of rates 120 days.

A sum of Rs. is forwarded herewith in the form of Cash, Bank Draft, Bankers Cheque as Earnest Money. This amount of earnest money shall absolutely be forfeited to the Governor of Rajasthan or his successor in office without prejudice to any other right or remedies of Governor of Rajasthan or his successor in his office, should I/We fail to commence the work specified in the above memorandum.

Signature of Witness
Witness's address & Occupation

Signature of Contractor
Address of Contractor

Date:

The above tender is hereby accepted by me on behalf of the Governor of Rajasthan

Date:

Executive Engineer (PHE-I)

Section A-2

General Conditions of Contract

(Appendix XI of PWF & AR. Govt. of Rajasthan
effective up to date shall be applicable)

Section A-3

Scope of work & Special Conditions of Contract

SCHEDULE 'I'

Name of work:- "P/L/J of DI/HDPE pipe line and construction of 2 nos. 200 mm dia tube well with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur."

Scope of work:-

1. P/L/J of DI/HDPE pipe line and construction of 2 nos. 200 mm dia tube well with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur as per site requirement.

SPECIAL CONDITIONS OF THE CONTRACT (Part-A)**CONTRACT****1.1 Type of Contract**

The work described in this tender documents consist of Three parts;

Part "A"	P/L/J of DI/HDPE pipe line
Part "B"	Construction of 200 mm dia tube well
Part "C"	3 years O&M for water supply scheme Shiv Enclave

2.1 Third Party Inspection :

The contractor is to contact for third party inspection amongst the **CEIL, SGS, RITES** on his own. He shall deposit & bear the cost of inspection. The contractor should inform the JDA of the name of agency finalized by him for the contract. The agency finalized by him for the contract. The agency will be same for all items of supply in this contract requiring 3rd party inspection.

The manufacturer should be required to call for inspection to the agency under instructions of the Contractor and Engineer In Charge. The Engineer in Charge may depute a representative to witness the inspection. The inspection agency should furnish copies of Inspection Certificate to the manufacturer, Contractor and to the Engineer In Charge directly. All material tested and found satisfactory as per specifications shall be marked distinctly.

2.2 Cost for Inspection

The cost of inspection shall be borne by the contractor.

2.3 Approval of Material and Equipment

The fact that the Contractor has agreed to provide the material prescribed in the Tender Documents does not release him to ask for the final approval of the equipment and material to be used for the Work. The specifications and drawings of each item to be supplied shall be individually scrutinized and its conformity with the technical specifications and the standards shall be verified by the Engineer In Charge.

Prior to ordering any material and equipment such as pipes, specials, measuring equipment's, mechanical and Electro-mechanical equipment, electrical equipment, material for civil works and interior decoration, paints, etc. the Contractor has to supply the detailed specification, drawings, performance curves and data, operation instructions etc., to the Engineer In Charge. If the Contractor has any doubts about the required specifications as prescribed in the Contract, he has to clarify them with the Engineer In Charge.

The procedure for the submission of documents, verification, re-submission if necessary and approval of these items is the same as that for the drawings, described in clause 2.3. If equipment or material which the Contractor submitted first is refused in the approval process he has to submit documents of such equipment which corresponds to the specifications of the Tender Documents and which is likely to be approved.

Only after approval of the material and equipment, the Contractor can place the order or start the manufacturing or purchasing procedures.

Four weeks prior to packing and shipping the Contractor must inform the Engineer In Charge when the material/equipment is ready for inspection and testing. At this date, the Contractor shall supply the results of all manufacturer's own tests made during or after manufacturing and his own quality control certificates. The Engineer In Charge will decide whether he or his representative will inspect and test the material/ equipment or whether he will approve it on the basis of the supplied documentation.

Inspection of bought out items i.e. Sluice valve, Air Valve, or any other Electro-Magnetic, Electrical and Mechanical equipment(s) and other items defined under Category 'A' shall done by third party selected by the JDA.

The Engineer In Charge will provide an authorization for packing and shipment after inspection and/or approval of the material/equipment.

If the Contractor packs and ships material/ equipment without approval or authorization of the Engineer In Charge-in-Charge, it can be refused if it is not matching with the specifications of the Contract. All costs resulting from this are to be borne by the Contractor. The Contractor has then to provide the material/ equipment, which is matching with the Contract.

3. COMPLETION OF THE WORK

3.1 Time for completion

The whole of the work, including mobilization, reconnaissance, construction, installation, testing, commissioning and trial runs, and demobilization has to be completed within a period of 6 months calculated from the commencement date, which is 10 days after the written order to commence the Work.

3.2 Completion of work and fully commissioning

Once the entire system has been successfully tested and commissioned, and removal of all visible defects to the satisfaction of Engineer In Charge-in-Charge, the work shall be treated as "Completed".

Unless otherwise provided in the contract, after the successful completion Engineer In Charge shall issue a certificate of "Completion of Work". The date of Certificate notifying "Completion of Work" will be used for the final payment as per clause 6 and 7 of General Conditions of Contract. From this date of issue of certificate for "Completion of Work", the Operation and Maintenance period shall commence.

3.3 Defects liability period

The defect liability period shall be of 3 years, from the date of the completion. The contractor shall be responsible for satisfactory performance of the work under all design and operation for the duration of the defects liability period. Except for damage due to unprecedented natural calamities. The release of SD amount shall be as per JDA office order no. JDA/Ex.En. (TA to Dir. Eng.-1)/2016/D-29 dated 11.03.16 (Annexure 'E').

3.4.1 Cost of water and electricity for testing

Water and electricity for construction and testing of scheme purpose shall be arranged by the contractor at his own cost. Electricity for trial and run period shall be provided by JDA. **Electric connection and regular electric bill of TW shall be paid by JDA but liaison work shall be carried by contractor with JVVNL, Jaipur.**

4 As-Built Drawings

The submission of the as-built drawings for the equipment is the precondition for the final payment. The final drawings shall be submitted in one reproducible set and 3 copies on linen bound in an album of an approved size. The contractor shall submit all the completion drawings and approved design calculations on CD ROM / DVD in two copies with proper directory structure. The scale of drawing and the size of drawing shall be as per the direction of the Engineer In Charge.

The contractor shall prepare, and keep up to date, a complete set of "as built" records of the execution of the works, showing the exact as built locations, sizes and details of the works as executive. The records shall be kept on the site and shall be used exclusively for the purpose of this sub clause. Two copies shall be supplied to JDA before the commencement of the tests on completion. The Contractor shall obtained the consent of JDA as to their size, the references system, and other relevant details.

5 Progress Of Work

All components of works shall ensure a logical sequence of supply, installation, testing, and commissioning. If any supply of a material is made, not in conformity to the logical sequencing of the work component, no payments will be entitled against such supplies and installations.

6 Documents Required For Payment:

The contractor shall submit the following documents in duplicate along with the invoice/bill.

- (i) Invoice indicating details of equipment's, material manufactured, supplied and installed or work carried out, supply value of such material or equipment or value of such work carried out and amount claimed.
- (ii) Inspection reports/ test reports/ reports certifying completion of activity with acceptable results.
- (iii) Report/certificate of inspections /tests carried out by the supplier of the contractor or by the contractor himself.
- (iv) Any other such details/documents as may be reasonably specified by the Engineer In Charge-in-Charge from time to time during execution of the contract.
- (v) Certificates, as prescribed, regarding payment of Sales Tax, duties etc. legible on supplies made.
- (vi) Other documents required by the Engineer In Charge-in-charge.

7 Payment Terms

- 7.1 Breakup of payment for Supply laying jointing, installation and testing of DI/HDPE pipe line and specials, installation of sluice valve, Air Valves and dismantling joints.

1	After Supply laying jointing, installation and testing of DI/HDPE pipe line and specials, installation of sluice valve, Air Valves and dismantling joints.	100% on commissioning and testing
---	--	-----------------------------------

8. Defects liability period

The defect liability period shall be of 3 years, from the date of the completion. The Contractor shall be responsible for satisfactory performance of the work under all design and operation conditions for the duration of the defects liability period, except for damages due to unprecedented natural calamities.

1. Refund of Performance Guarantee & Security Deposit

The Security Deposit (SD) and Performance Guaranty (PG) shall be refunded after successfully completion of defect liability period of 3 years. The 20 % amount of SD shall be released after completion of 1st year of DLP, other 20 % amount of SD shall be released after completion of 2nd year of DLP and remaining 60 % amount of SD shall be released after completion of 3rd year of DLP. (As per JDA Office order no. JDA/EE(TA to Dir.-Engg-I)/2016/D-29 dated 11.03.2016).

2. As per office order no. JDA/DD (E&B)/2018/D-352 dated 29.08.2018, Clause of agreement no. 45 for Price Escalation variation is not applicable.**COMMISSIONS AND CORRECTIONS**

If there is any typographical error or otherwise in the 'G' Schedule. The nomenclature and the rates as given in the relevant JDA BSR-2016 and JDA approved items/rates on which schedule 'G' is based, shall prevail.

The above conditions may be read very carefully and adhered strictly.

Signature of Contractor

**Executive Engineer (PHE-I)
JDA, Jaipur**

SCHEDULE 'I'

Name of work :- "P/L/J of DI/HDPE pipe line and construction of 2 nos. 200 mm dia tube well with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur."

SPECIAL CONDITIONS OF THE CONTRACT FOR PIPE LINE WORKS

1. Contractor shall get the material inspected from the third party (CEIL, SGS, RITES) before bringing the material at site. The inspection charges shall be born by the contractor. No payment of these items shall be made before the third party inspection.
The HDPE Pipes shall also be got tested from CIPET and amount for testing shall be borne by contractor. Department shall demand for manufacturers' test report for pipes along with pre dispatch inspection by EIC or his authorized representative.
2. In case of pipe line testing shall be done as per the relevant Code and the leakage level shall not be more than as per IS 8329 then 100% payment shall be released after commissioning & testing.
3. The JDA shall be free to carry out the work from any participating agency on the rate of lowest bidder during the concurrency of contract.
4. The contractor shall submit the proof of ownership of suitable machinery for laying of pipeline in all type of strata.
5. The quantity of work can be increased or decreased. However, no guarantee is given about the actual quantity of work.
6. No extra payment shall be made to the contractor on account of excavation in collapsible strata or in hard or rocky strata. The tenderers shall have to make their own arrangement for completing the work and no claim in this respect will entertained.
7. On collection of complete material for each section the same shall be got checked by Engineer-in-Charge or his authorized representative. Such approval shall in no way release the contractor of his responsibility regarding completion of work, as per required specification until the contract is complete.
8. The electric connection, if required, for construction and testing purpose shall be arranged by the contractor at his own cost.
9. The contractor shall make his own arrangement regarding water required for the execution and testing of the work and shall also arrange for the supply of drinking water to his own employees. He shall defray all charges in this connection and should include in his rates a sufficient amount to cover such charges. All such facilities as are required now to be provided for the labour, made under labour welfare rules inforce, shall also be provided by the contractor at his own cost.
10. The contractor will be required to see that the usual hours of work are adhered too. No work shall be done after the sun set without the permission of the engineer-in-charge
11. The Security Deposit (SD) and Performance Guaranty (PG) shall be refunded after successfully completion of defect liability period of 3 years. The 20 % amount of SD shall be released after completion of 1st year of DLP, other 20 % amount of SD shall be released after completion of 2nd year of DLP and remaining 60 % amount of SD shall be released after completion of 3rd year of DLP. (As per JDA Office order no. JDA/EE(TA to Dir.-Engg-I)/2016/D-29 dated 11.03.2016)..
12. The contractor/firm or company while executing the work will adopt all safety measures at his cost to safeguard from any loss of life and damage of public and private property. If any loss and damage is occurred, they will pay the full compensation from their own pocket to the concern. All the consequence (legal and or financial) will be born by the contractor only and JDA will not be responsible in any way.
13. Water for construction / testing purpose shall have to arranged by contractor at his own cost. If water is supplied by the department, the same shall be recovered from the contractor from each running bill at the rate of 1% of total value of pipe line laying work, In case of metered connection the charges shall be recovered on the actual consumption basis on the commercial rates.
14. The contractor shall be fully responsible for structural safety and water tightness of pipeline when tested.
15. No secured advance against material procured at site will be allowed.
16. Pipeline laying should be done in the presence an Engineer not below the rank of Junior Engineer of the JDA, and trench shall be refilled after checking of Assistant engineer. After taking layout, the contractor shall submit day to day schedule of work to the Engineer-in-charge in advance.
18. The contractor/firm or company will take utmost care to safeguard the water mains, Electric and Telephone cable existing surface drains water connections etc., while executing the work. Any damages/rectification shall be born by the contractor only
19. The contractor shall, at his own cost, arrange to provide, erect and maintain necessary display boards/ flags/banners etc. at selection points of project site giving such information as considered necessary for public awareness/ information/ safety as directed by the Engineer-in-charge.
20. Contractor shall provide sufficient number of boards at site of work indicating "JDA AT WORK" at his own cost as required by Engineer-in-charge.
21. The surplus earth and damaged materials will be immediately removed from the site of work and dumped as per instruction of Engineer-in-charge

22. The material collected at site and paid provisionally shall remain under the watch and ward of the contractor till it is consumed fully on the work.
23. Any material not conforming to the specifications collected at site shall have to be removed by the contractor within a period of 3 days of the instructions, issued by the Engineer-in-charge, failing which, such material shall be removed by the Engineer-in-charge at risk and penalty shall be imposed for the same to the contractor after expiry of 3 days period.
24. The contractor/firm/company is bound to get the workmen insured against accident from the Insurance Company at his own cost.
25. Contractor shall be the sole custodian of the men and material at work and will be fully responsible for any loss of life or other wise occurred during the execution of the works.
26. The submission of the as-built drawings of the water line work is the precondition for the final payment. The final drawings shall be submitted in one reproducible set and 3 copies on linen bound in an album of an approved size. The contractor shall submit all the completion drawings and approved design calculations on CD ROM / DVD in two copies with proper directory structure. The scale of drawing and the size of drawing shall be as per the direction of the Engineer in Charge.
27. **The contractor shall be solely responsible for all kind of liaison before starting the work with PHED/Other JDA zone/JVVNL & BSNL etc. which is required to avoid any damage of already laid pipe lines, Electric, BSNL cables. The contractor shall also liaison for the inter connection work with existing PHED system.**
28. Before start of work contractor has to inform concerned JDA zone officers to avoid/minimize road damage
29. The follow up / liaison for release of Electric Power connection of TWs from JVVNL Jaipur shall be in the scope of contractor and shall be deposited the required fees for issue the demand note, which shall be reimbursed by JDA on submission of original receipt.
30. As Built Drawings.
The submission of the as-built drawings of the proposed work with old pipe line work is the precondition for the final payment. The final drawings shall be submitted in one reproducible set and 3 copies on linen bound in an album of an approved size. The contractor shall submit all the completion drawings on CD ROM / DVD in two copies with proper directory structure. The scale of drawing and the size of drawing shall be as per the direction of the Engineer in Charge
31. If there is any typographical error or otherwise in the 'G' Schedule. The nomenclature and the rates as given in the relevant BSR-2016 and JDA approved items/rates on which schedule 'G' is based, shall prevail.

Special conditions for Tube well work

1. The contractor is required to obtain hydrogeological survey report from GWD regarding water availability and submit the same to the EIC prior to commence the tubewell drilling work.
2. The JDA shall be free to carry out the work from any participating agency on the rate of lowest bidder during the current contract.
3. Quantity of work can be increased or decreased. However, no guarantee is given about the actual quantity of work.
4. The envelope shall contain the following information/ documents :-
 - a. I. Certified copy of Registration Certificate of Contractor
 - II. Each page of Tender Document be filled up wherever required and be signed and submitted.
5. No extra charges for higher size drilling in collapsible strata will be paid by the JDA. The tenderers shall have to make their own arrangement for completing the work and no claim in this respect will entertained.
6. Payment will be made on completion of individual tubewell in all respect including development.
7. The boring shall be accepted only when it's Yield is 2000 LPH or more for 200 mm diameter TUBE WELL at a draw down not exceeding 7 meters. Only payment of Drilling shall be made for the tube wells having discharge less than above. It is responsibility of contractor to fill up bore holes of such unsuccessful tube wells upto the ground level immediately.
8. Inspection and Checking of work

As material are collected and the construction of each section of work is completed it will be checked by Engineer-in-Charge or his authorized representative and the representative of the contractor will assertion from the engineer form time to time that what part and portion he wishes to check over and pass out. Such approval shall in no way release the contractor of his responsibility regarding completion of work, as per required specification until the contract being completed.

9. **Water Supply for Work and Drilling Purposes**
The contractor shall make his own arrangement regarding water required for the execution and testing of the work and shall also arrange for the supply of drinking water to his own employees. He shall defray all charges in this connection and should include in his rates a sufficient amount to cover such charges. All such facilities as are required now to be provided for the labour, made under labour welfare rules enforce, shall also be provided by the contractor at his own cost.
10. **Time of Working**
The contractor will be required to see that the usual hours of work are adhered too. No work shall be done in the night without prior permission of Engineer – in – Charge except when it is absolutely necessary in the public interest. In this case contractor shall immediately inform the Engineer-in-Charge and get it approved.
11. **The defect liability period for the tube well and pump set and panel etc. shall be one year after commissioning of the tube well. 10% of amount shall be withheld for each tube well and shall be released after one year of defect liability period. The contractor shall be liable for successful running of tube well during defect liability period.**
12. **The Security Deposit (SD) and Performance Guaranty (PG) shall be refunded after successfully completion of defect liability period of 3 years. The 20 % amount of SD shall be released after completion of 1st year of DLP, other 20 % amount of SD shall be released after completion of 2nd year of DLP and remaining 60 % amount of SD shall be released after completion of 3rd year of DLP. (As per JDA Office order no. JDA/EE(TA to Dir.-Engg-I)/2016/D-29 dated 11.03.2016)..**
13. **Completion Period**
Date of completion of work shall be minimum 7 days for each tube well from date of issue of work order. If nos. of tube wells are increased additional three days will be given for construction of each extra tube wells.
14. **Release of Electric connection from JVVNL**
The contractor shall be responsible for getting electric connection released from JVVNL in feasible areas on behalf of JDA. For this JDA shall provide duly signed application form which shall be produced by contractor in JVVNL office. In normal case the final payment shall not be passed till electric connection is released and testing as per norms is done, however in case of non-feasibility of electric connection area the decision of EIC shall be final. The amount required for release of electric connection shall be deposited by contractor to JVVNL office at first stage which shall be reimbursed to him on producing of original receipt of JVVNL.
15. **Electric and water connections for construction and testing purpose if needed, shall be arranged by the contractor himself at his own cost.**
16. **Contractor shall provide sufficient number of boards at site of work indicating "JDA AT WORK, TOWARDS MAKING JAIPUR A WORLD CLASS CITY" at his own cost as required by Engineer – in – Charge**
17. **The following information's shall be furnished on completion by the contractor in accordance with clause No. of 12.2 of IS 2800 (Part I) : 1991, while handing over the tube well**
 - a) Total depth of tube well drilled.
 - b) Strata chart of tube well indicating different type of soil formation met with at different depths and indicating the depths of each type of soil formation from hydrologist.
 - c) Samples of strata collected, neatly packed and correctly marked in sample bags.
 - d) Position of every joint in well assembly.
 - e) Method used for development.
 - f) Total hours of development done.
 - g) Developed discharge in L.P.S.
 - h) Discharge is totally sand free or presence of sand particles is there.
 - i) PPM and turbidity after development.
 - j) Pumping water level at developed discharge, and
 - k) Static water level
18. **Payment shall be made to contractor ensuring that the lowest tenderer shall remain lowest on the completion of work.**
19. **If contractor failed to do work with in specified time period, the work shall be awarded to second lowest after deposition of earnest money as per rule.**
20. **The format as per IS: 2800 (Part I): 1991 for furnishing the details is given as below:**
 - a) Agency drilling the tubewell.....
 - b) Location of tube well.....
 - c) Method of drilling adopted.....

- d) Date of starting
 e) Date of completion
 f) Pilot hole and test hole Bit Size.....
 Bit typeHours.....fromto
 g) Coring doneBit size..... Bit type
 Hoursrecovery.....from.....to.....
 h) ReamingBit Size.....Bit Type
 Hours.....from.....to.....
 i) Lithological data

From	To	Formation
.....		
.....		

 j) Total length of tube well drilled.....
 k) Assembly of production well Size.....
 Lengthtype
 Perforation per meter

Housing pipe

- Blind pipe
 Strainer pipe.....
 Bail plug.....
 l) Top of tube well above/below ground level.....
 m) Size of gravel.....
 n) Quantity used before
 o) Development.....Quantity used during development.....
 p) Method used for development.....

Total hours of testing.....

- q) Development discharge.....
 r) Turbidity.....
 s) Further details appended
 i) Sample of strata, neatly packed in sample bags
 ii) Chart of pipe assembly lowered
 iii) Results of mechanical analysis of samples of unconsolidated strata.

21. No running payment shall be made for incomplete tube well. Payment shall be made after completion of development, testing of tubewell.

The above conditions may be read very carefully and adhered strictly.

I/we confirm above

Signature of contractor

**Executive Engineer (PHE-I)
JDA, Jaipur**

Conditions Of Contract For Operation & Maintenance Of Newly developed Water Supply assets under this contract By Bidder For 36 Months.

Definitions-

- **Equipment-** is the contractor's machinery and vehicles brought temporarily to the site to construct the works.
- **Facilities-** Shall mean all works and its equipment(s), components which have been supplied and/ or installed or designed, and/or constructed in the contract for works.
- **Plant-** is any integral part of the works, which is to have a mechanical, electrical, electronic, chemical functions.

1 - Administrative Provision

The following additional clauses shall apply only during the Operation and Maintenance period.

- 1.1 "Maintenance Standard" shall mean the requirements for maintaining, repairing, and renewing the Facility :
- a) As set forth in the O & M Manual: bidder shall enclose this with the bid document
 - b) Required pursuant to applicable law:
 - c) As may be necessary for keeping the facility in a satisfactory condition such that the Facility will continuously, comply with the Operation Standard; and
 - d) As may be necessary to ensure that the Facility shall continuously be in an optimum condition and state in relation with the lifetime of the Facility.
- 1.2 "O & M Manual" shall mean the final Manual for the Operation and Maintenance of the Facility to be prepared in accordance with the Bid Documents.

1.3 Brief scope under this contract will be as described below:

- 1.3.1 To schedule daily operations for uninterrupted water supply to consumers.
- 1.3.2 To keep records for daily operation of tube well and leakages.
- 1.3.3 To keep records of staff in position.

2.0 OBJECT OF CONTRACT:

2.1 RISKS AND OBLIGATION OF THE CONTRACTOR :

FOR THE DURATION OF O & M PERIOD, CONTRACTOR SHALL RENDER AND MAKE AVAILABLE TO JDA THE FOLLOWING SERVICES :

- 2.1.1 Pump water from Tube wells to pipe line.
- 2.1.2 Supply all spares & consumables for routine, preventive & break down maintenance. No extra payment shall be made for these supplies of spares & consumables.
- 2.1.3 If any loss or damage happens to the Facility, or any part thereof, or materials, during the period for which the Contractor is responsible for the care thereof, from any cause whatsoever, other than the risks, the Contractor shall, at his own cost, rectify without loss or damage so that the Facility conforms in every respect with the provisions of the Contract to the satisfaction of JDA. The contractor shall also be liable for any loss or damage to the Works occasioned by him in the course of any operations carried out by him for the purpose of complying with his obligation.

- 2.1.4 All material for the repair and maintenance of pumping machinery, pipeline, electrical equipment shall be arranged by the contractor at his own cost.
- 2.1.5 Power charges shall be borne by JDA. However it shall be responsibility of the contractor to collect the bills from JVVNL seven days before due date of payment by cheque and handing over to Engineer in charge, also collecting the cheque from JDA and deposit it in JVVNL within due date. Any late payment, Power factor penalty will be on the part of contractor.
- 2.1.6 In case of any break down of pump machinery or starters, the contractor shall have to inform the JEN/AEN (PHE-I) concerned. In no case the information shall take more than six hours to reach the engineer in charge staff of JDA. However, simultaneously he shall make the arrangements to install the stand by units to restore the supply. The contractor shall always keep the stand by readily available units in respect of all important item/installation Viz. Pump set, starter ICTP switches etc, originally provided by JDA or supplier under the contract. The contractor shall keep stores of all essential items as site.
- 2.1.7 In case of power break down, the contractor shall lodge complaint to the concerned JVVNL office/ station and get the problem solved. In case of major power problem, the contractor shall immediately inform the JEN/AEN (PHE-I) concerned for seeking their help. However, it would be responsibility of the contractor to get the electric problem rectified through proper pursuance. In case, it is unavoidable to restore the water supply, the contracting agency would arrange to get it properly announce to the public taking advance action for water storage/alternative arrangement.
- 2.1.8 Necessary tools required in repairing of Tube Wells and conveyance vehicles such as jeep, tractor, mini truck etc. shall be arranged by the contractor at his own cost. No payment in lieu of conveyance or tools shall be admissible.

3.0 Risk & Obligations of the JDA

- For the duration of O & M Period, the employer will be responsible to bear of the costs for electricity.

4. Commencement And Duration Of O & M Contract :

- 4.1 The O & M period shall commence upon issuing of completion Certificate of construction phase of the project and shall Continue for a period of thirty six (36) months. If JDA wish to propose an extension to the O & M Period, after completion of initial 36 moths O & M contract a prior notice of its intention to exercise such option shall be given to the contractor.

5. Liability:

The contractor will not in any circumstances, be liable for costs or loss of profit that JDA may incur as a result of the unavailability of the plant on account of force major.

6. Personnel :

JDA is not liable for any personnel provided by the contractor in any way and cannot be held responsible in the event of litigation of any sort between the Contractor and members of plant personnel or their representatives. Round the clock (24 hours) watch and ward shall be the responsibility of contractor throughout the contract period. In case of theft of any asset from site, contractor shall replace it at his own cost.

All decisions related to staff numbers and qualifications should be approved by JDA. The number of shifts for pump operation will be decided by the contractor in accordance with the operations requirements.

The Contractor shall undertake to comply with applicable legislation and the code of labour law on the matters of health, hygiene and safety, and shall assume responsibility for works required in the event of any change in applicable regulations.

7. Assignment :

The Contractor will not be entitled to sub-contract any part of his obligation to any third party without prior approval of JDA.

8. Completion Of The Contract :

On the date of Contract Completion or if the Contract is terminated, all the installations, works and equipment placed under the Contractor's responsibility shall be handed over to JDA or any agency, organization specified by it, at no cost, in good working order, except for normal wear and tear. JDA may perform any inspections tests or expert appraisals as may be considered necessary with a view to checking that the property is in good working order. If the works, equipment, plant and/or property is not found in working condition or acceptable condition, the contractor will replace / repair / rectify the same at his own cost to the satisfaction of JDA or third party inspector to be appointed by JDA at its cost.

At the end of O&M period, the Contractor shall be entitled to receive an Operation and Maintenance Completion Certificate within twenty-one (21) days, of the completion of the Contract.

The delivery of such Completion Certificate will relieve the Contractor from his responsibility as regard to the Operation and Maintenance and confirm that the Contractor has fulfilled all of his obligations under the contract.

9. Technical Provisions

The Contractor shall be responsible for corrective maintenance of mechanical, electrical and measuring equipment as well as miscellaneous equipment. The contractor shall properly repair during any leakage, bursts in rising and distribution pipelines, valves, specials etc. The contractor shall ensure that the water losses are not more than 5%, in pipe line network of rising main/ distribution system laid by it.

The Contractor shall be responsible for carrying out regular servicing and lubrication of all machinery and equipment, complying with maintenance instructions as defined in the Operation and Maintenance manual and ensuring that electromechanical equipment and motors operate correctly at all times.

The brief scope will be:

- Operation of submersible pumps at TW's to provide adequate water to meet the daily demand and maintenance of HDPE/ DI pipeline distribution network and to maintain all the assets created under this contract.

10.0 Consumables And Spare Parts:

Unless stipulated otherwise elsewhere in the document, for the duration of O & M period, the Contractor will be responsible for the supply and control of lubricants, spare parts and consumable materials & chemicals excluding electrical power charges, necessary for the continuous operation of the works.

The store's inventory, the issuing and recording of spare parts will be the responsibility of the Contractor.

The contractor is also responsible for providing spare parts and material required for the operation and maintenance during the operation period and shall bear the cost for the same, including the cost of storing and safeguarding.

The contractor will make all necessary arrangements to ensure the continuous supply of spare parts and material for the works, and the rate of supply of these materials shall be in such quantities and amounts as would ensure uninterrupted operation.

Spare parts shall be supplied by the Contractor without any additional charge and the same will be used during O & M period.

11. Documents to Be Provided By the Contractor:

11.1 Operation Log Book:

The Contractor shall keep a permanent record of tube well operation (log book). This log book shall be kept at the site and shall be presented on request to agents approved by JDA.

The log book shall be provided by the contractor. The contractor shall also indicate any significant modification to the set-up characteristics of the installation, shut-downs anomalies or incidents that have occurred with respect to operation.

The log book shall also contain the following:

- Daily report
- Weekly report
- Readings of meters Gauges (voltmeter, ammeter, Flow meter, pressure gauges at TW's.
- Record of break down
- Staff attendance `
- Trouble identification for the installation

Signature of Contractor

**Executive Engineer (PHE-I)
JDA, Jaipur**

Section A-4

Specifications of Work

SUPPLY OF DI /HDPE PIPES, SPECIALS, VALVES AND LAYING OF PIPES FOR WATER SUPPLY**General****Standards**

Except as otherwise specified in this technical specification, the Indian/International Standards and Codes of Practice in their latest version shall be adhered to for the design, manufacturing, inspection, factory testing, packing, handling and transportation of product. Should any product be offered conforming to other standards, the equipment or products shall be equal to or superior to those specified and the documentary confirmation shall be submitted for the prior approval of the Engineer in Charge.

This specification requires a reference to the following standard specifications

IS: 4985	Unplasticized PVC pipes for potable water supplies
IS: 10151	PVC and its copolymers for its safe use in contact with foodstuffs, pharmaceuticals, and drinking water
IS: 10500	Drinking water specification
IS: 12235	Methods of test for unplasticized PVC pipes for potable water supplies
IS: 4669	Methods of test for PVC resin
IS: 12818	Unplasticized PVC screen and casing pipes for bore/tube well
IS: 3400	Methods of test for vulcanized rubber (part-1 to 22)
IS: 1387	General requirements for the supply of metallurgical material
IS: 210	Grey iron casting
IS: 1536	Centrifugally cast (spun) iron pressure pipe for water, gas and sewage
IS: 1537	Vertically cast iron pressure pipe for water, gas and sewage
IS: 1538	Cast iron fittings for pressure pipes for water, gas and sewage
IS: 5531	CI specials for Asbestos cement pressure pipes for water gas & sewage
IS: 1363	Hexagon head bolts, screws and nuts of product grade A and B (part:1-5)
IS: 1367	Technical supply conditions for threaded steel fasteners
IS: 780	Sluice valve for water works purposes
IS: 2906	Specifications for sluice valves for water works purposes
IS: 318	Leaded tin bronze ingots and casting
IS: 8543	Methods of testing plastics: Determination of density of solid plastics
IS: 7181	Horizontally cast iron double flanged pipes for water, gas and sewage.
IS: 8794	CI detachable joints for use with Asbestos cement pressure pipes
IS: 5382	Rubber sealing rings for gas mains, water mains and sewers
IS: 5531	Cast iron specials for asbestos cement pressure pipes for water, gas and sewage
IS: 779	Water meters
IS: 3624	Pressure and vacuum gauges
IS: 341	Black japan, types A, B and C
IS: 9862	Ready mixed paint, brushing, bituminous, black, lead free, acid, alkali, water and chlorine resisting
IS: 1239	Mild steel tubes, tubular and other wrought steel fittings
IS: 7328	High density polyethylene materials for moulding and extrusion
IS: 4984	Specification for high density polyethylene pipes for potable water supplies; sewage and industrial effluents
IS: 554	Dimensions for pipe threads where pressure tight joints are required on the threads
IS: 1592	Asbestos cement pressure pipes - Specifications
IS: 778	Specifications for copper alloy gate, globe and check valves for water works purposes
IS: 12820	Dimensional requirements for rubber gaskets for mechanical joints and push on joint for use with cast iron pipes and fittings for carrying water, gas and sewage.
IS: 9523	Specification for DI fittings for pressure pipes for water, gas, and sewage.
ISO: 2045	Single socket for uPVC and uPVC pressure pipes with elastic sealing ring type joints - Minimum depth of engagement
ISO: 2507	PVC pipes and fittings- Vicat softening temperature - Test method and specification
ISO: 3603	Fittings for PVC pipe with elastic sealing ring joints pressure test for leak profanes
ISO: 1167	Thermoplastics pipes for the transport of fluids - Resistance to internal pressure - Test method and basic specification
ISO 3451-5	Determination of Ash: Part-5 - Poly vinyl chloride
ASTM: D 2152	Standard test method for degree of fusion of extruded PVC pipe and moulded fittings by Acetone immersion
MTNL	Mahanagar Telephone Nigam Limited; Technical specifications for cable ducts.
BS: 4772	Specification for DI fittings
IS: 7634- Parts 1-3	Code of practice for plastic pipe works for potable water supplies
IS: 8329	Centrifugally cast (spun) ductile iron pressure pipes for water, gas and sewage.
IS: 12288	Code of practice for use and laying of ductile iron pipes
CPHEEO Manual on	Water Supply and Treatment, III edition, Ministry of Urban Development, New Delhi- May 1999.

Ductile Iron Pipe:-

The pipes will be centrifugally cast (spun) Ductile Iron pipes for Water and Sewage confirming to the IS 8329: 2000. The pipes used will be either with push on joints (Rubber Gasket Joints) or Flanged joints. The class of pipe to be used shall be of the class K-7.

The pipes shall be coated with bitumen as per appendix C and have factory provided cement mortar lining in the inside as per the provisions of Appendix B of the IS 8329: 2000.

The pipes will be supplied in standard length of 5.50 and 6.00 meters length with suitably rounded or chamfered ends. Each pipe of the push on joint variety will also be supplied with a rubber EPDM gasket. Any change in the stipulated lengths will be approved by the Engineer – in charge. The gaskets will confirm to the IS 5382:1985.

The gaskets should also be supplied by the manufacturer of the pipes. They should preferably be manufactured by the manufacturer of the pipes. In case they are not, it will be the responsibility of the manufacturer of the pipes to have them manufactured from a suitable manufacturer under its own supervision and have it tested at his/sub contractors premises as per the contract. The pipe manufacturer will however be responsible for the compatibility and quality of the products.

The flanged joints will confirm to the Clause 6.2 of IS 8329. The pipe supply will also include one rubber gaskets for each flange.

Inspection and Testing:

The pipes will be subjected to following tests for acceptance:

Visual and dimensional check as per Clause 13 and 15 of IS 8329

Mechanical Test as per Clause 10 of IS 8329

Hydrostatic Test as per Clause 11 of IS 8329

The test reports for the rubber gaskets shall be as per acceptance tests of the IS 5832 and will be in accordance to Clause 3.8

The sampling shall be as per the provisions of the IS 8329

Marking

All pipes will be marked as per Clause 18 of IS 8329 and show as below:

Manufacturer name/ stamp

Nominal diameter

Class reference

A white ring line showing length of insertion at spigot end

Packing and Transport:

The pipes should be preferably transported by road from the factory and stored as per the manufacturer specifications to protect damage.

Specials for Ductile Iron Pipes

General

This section covers the general requirements for Ductile Iron (DI) fittings suitable for Tyton joints to be used with Ductile Iron pipes with flanged and Tyton jointing system.

Types of specials

The following types of DI fittings shall be manufactured and tested in accordance with IS: 9523 or BS: 4772.

flanged socket

flanged spigot

Double socket bends (900, 450, 22 1/2 0, 11 1/4 0)

Double socket branch flanged tee

All socket tee.

Double socket taper.

All Flanged Tee.

All Flanged taper.

Supply

All the DI fittings shall be supplied with one rubber ring for each socket. The rubber ring shall conform to IS: 12820 and IS: 5382 as described in the preceding chapter. Flanged fittings shall be supplied with one rubber gasket per flange and the required number of nuts and bolts.

General

This section covers the requirements for lubricant for the assembly of Ductile Iron pipes and specials suitable for Tyton push-in rubber ring joints

Specification

The lubricant has to have the following characteristics:

must have a paste like consistency and be ready for use

has to adhere to wet and dry surfaces of DI pipes and rubber rings

to be applied in hot and cold weather; ambient temperature 0 - 50 °C, temperature of exposed pipes up to 70 °C

must be non toxic

must be water-soluble

must not affect the properties of the drinking water carried in the pipes

must not have an objectionable odour

has to inhibit bacterial growth

must not be harmful to the skin

must have a shelf live not less than 2 years

Acceptance tests

They shall be conducted in line with the provisions of the IS 9523

Packing

All the DI fittings shall be properly packed with jute cloth. Rubber rings shall be packed in polyethylene bags. Rubber rings in PE bags and nuts, bolts etc. shall be supplied in separate jute bags.

The fittings should also be supplied by the manufacturer of the pipes. They should preferably be manufactured by the manufacturer of the pipes. In case they are not, it will be the responsibility of the manufacturer of the pipes to have them manufactured from a suitable manufacturer under its own supervision and have it tested at his/sub contractors premises as per the contract. The pipe manufacturer will however be responsible for the compatibility and quality of the products.

Laying and jointing of DI pipes

Pipes should be lowered into the trench with tackle suitable for the weight of pipes. For smaller sizes, up to 200 mm nominal bore, the pipe may be lowered by the use of ropes but for heavier pipes suitable mechanical equipment have to be used.

All construction debris should be cleared from the inside of the pipe either before or just after a joint is made. This is done by passing a pull-through in the pipe, or by hand, depending on the size of the pipe. All persons should vacate any section of trench into which the pipe is being lowered

On gradients of 1:15 or steeper, precautions should be taken to ensure that the spigot of the pipe being laid does not move into or out of the socket of the laid pipe during the jointing operations. As soon as the joint assembly has been completed, the pipe should be held firmly in position while the trench is back filled over the barrel of the pipe. The designed anchorage shall be provided to resist the thrusts developed by internal pressure at bends, tees, etc.

Where a pipeline crosses a watercourse, the design and method of construction should take into account the characteristics of the watercourse to ascertain the nature of bed, scour levels, maximum velocities, high flood levels, seasonal variation, etc. which affect the design and laying of pipeline.

The assembly of the pipes shall be made as recommended by the pipe manufacturer and using the suitable tools.

The socket and spigot ends of the pipes shall be brushed and cleaned. The chamfered surface and the end of the spigot end have to be coated with a suitable lubricant recommended by the manufacturer of the pipes. Oil, petroleum bound oils, grease or other material which may damage the rubber gasket shall not be used as lubricant. The rubber gasket shall be inserted into the cleaned groove of the socket. It has to be checked for correct positioning.

The two pipes shall be aligned properly in the pipe trench and the spigot end shall be pushed axially into the socket either manually or with a suitable tool specially designed for the assembly of pipes and as recommended by the manufacturer. The spigot has to be inserted up to the insertion mark on the pipe spigot. After insertion, the correct position of the socket has to be tested with a feeler blade

Deflection of the pipes -if any- shall be made only after they have fully been assembled. The deflection shall not exceed 75 % of the values indicated by the pipe manufacturer.

Anchoring of the pipeline

Thrust blocks shall be provided at each bend, tee, taper, end piece to prevent undue movements of the pipeline under pressure. They shall be constructed as per design of ENGINEER- IN- CHARGE according to the highest pressure during operation or testing of the pipes, the safe bearing pressure of the surrounding soil and the friction coefficient of the soil.

Leakage Test

After laying and jointing the pipeline shall be tested for tightness of barrels and joints, and stability of thrust blocks in sections approved by the Engineer in Charge. The length of the sections depends on the topographical conditions. Preferably the pipeline stretches to be tested shall be between two chambers (air valve, scour valve, bifurcation, other chamber). At the beginning, the Contractor shall test stretches not exceeding 2 km. After successful organization and execution of tests the length may be extended to more than 2 km after approval of the Engineer in Charge.

The water required for testing shall be arranged by the contractor himself. The Contractor shall fill the pipe and compensate the leakage during testing. The Contractor shall provide and maintain all requisite facilities, instruments, etc. for the field testing of the pipelines. The testing of the pipelines generally consists in three phases: preparation, pre-test/saturation and test immediately following the pre-test. Generally, the following steps are required which shall be monitored and recorded in a test protocol if required

The testing conditions for the pipelines are summarized as follows:

Maximum hydrostatic test pressure for DI K-7 pipes shall be 2.0 times of maximum design pressure in the pipeline.

Pre test and saturation period with addition of make-up water

Pressure:	Test pressure
Duration:	3 hrs for DI pipes without cement mortar lining / 24 hrs for DI pipes with cement mortar lining

Pressure test with addition of make-up water

Pressure:	Test pressure
Duration:	3 hrs

Test criteria for DI pipes: Q = 1 liter per km per 10mm of pipe per 30 m test pressure per 24 hrs.

All pressure testing at site should be carried out hydrostatically. The pipes shall be accepted to have passed the

pressure test satisfactorily, if the quantity of water required to restore the test pressure as per the latest codal provisions does not exceed the amount 'Q', calculated by the above formula.

If it is required to test a section of a pipeline with a free end, it is necessary to provide temporary support against the considerable end thrust developed by the application of the test pressure. The end support can be provided by inserting a wooden beam or similar strong material in a short trench excavated at right angle to the main trench and inserting suitable packing between the support and pipe end.

The pipeline stretch will pass the test if the water added during the test period is not exceeding the admissible limits. No section of the pipe work shall be accepted by the Engineer in charge until all requirements of the test have been obtained.

On completion of a satisfactory test any temporary anchor blocks shall be broken out and stop ends removed. Backfilling of the pipeline shall be completed.

Failure to pass the test

All pipes or joints which are proved to be in any way defective shall be replaced or remade and re-tested as often as may be necessary until a satisfactory test shall have been obtained. Any work, which fails or is proved by test to be unsatisfactory in any way, shall be redone by the Contractor.

Flushing and disinfecting of pipelines

After testing and commissioning the contractor shall flush the pipes with a velocity not less than 1 m/s or as approved by the Engineer in Charge. Disinfection of drinking water pipelines shall be made by engineer- in charge.

Supply of Ductile Iron Pipes:-

The Contractor will have to supply DI pipes manufactured by manufacturer who has been in business of supply of DI pipes rubber ring jointed and have proven record of successful supply and testing of pipeline for minimum one year.

Valves

General

The sluice valve will conform to IS: 780/ IS: 2906.

The material to be supplied under this sub-section shall include but not be limited to the following:

All necessary fittings including bolts, nuts, gaskets, backing rings, counter flanges, jointing material, strainers etc. as required.

Sluice Valves

Scope

This section covers the requirements for non rising stem type sluice valve from 50 mm to 600 mm size. The valves will be used for water supply on line installations in upright positions, up to 450 C working temperature, with double flange and cap or hand wheel, for manual operation.

Nominal pressure and dimensions

The working pressure of the valves shall be 10 kg/cm² (1 MPa)

The dimension and mass of the sluice valves shall be in accordance with IS: 780 for sizes from 50 to 300 mm and IS: 2906 for sizes 350 to 600 mm.

The flanges and their dimensions of drilling shall be in accordance with IS: 1538 (part-I to XXII).

Material

The material for different component parts of sluice valve shall conform to requirements given below:

S No.	Component	Material	Ref. to IS	Grade / designation
1	Body, bonnet, wedge, stuffing box, gland, thrust plate, hand wheel cap. etc.	Grey cast iron	210	FG 200
2	Stem	Stainless steel	6603	AISI 431, AISI 410
3	Wedge nut	Leaded tin bronze	318	LTB 2
4	Body seat ring, wedge facing ring	Leaded tin bronze	318	LTB 2
5	Bolt	Carbon steel	1363	Class 4.6
6	Nut	Carbon steel	1363	Class 4
7	Bonnet gasket	Compressed fiber board	2712	C
8	Gland packing	Asbestos	4687	Nil

Coating

All sluice valves shall be coated by dipping in a bath of tar base composition as given in Clause 7 of IS: 780 for sizes from 50 mm to 300 mm and Clause 8 of IS: 2906 for sizes from 350 mm to 600.

All components susceptible to corrosion attack shall be coated internally and externally. Protective coating shall always be applied to the individual components before they are assembled, following shot blasting to give good adhesion.

Marking, testing and inspection

The standard marking and packing of the valves shall be done as per Clause 10 and 11 of IS: 780. The direction of rotation for OPEN, CLOSE position shall be marked on the hand wheel and on the bonnet of the valve.

Testing of sluice valve shall be done for close end in accordance with IS: 780 for sizes from 50 mm to 300 mm and IS: 2906 for sizes from 350 mm to 600.

All the valves shall be inspected for flaw detection test in accordance with IS: 780. for sizes from 50 mm to 300 mm and IS: 2906 for sizes from 350 mm to 600.

The design, construction material, manufacture, inspection, performance and testing shall comply with all applicable Indian Standards and Codes. Nothing in the specification will be construed to relieve the supplier of this responsibility.

Air valves

Scope and general design feature

This section covers the requirements of automatic double ball air valves to be used for evacuation of accumulation of air in water mains under pressure, for the exhaust of air when such mains are being charged with water and for inlet of air when they are emptied of water.

The Air Valves shall conform to IS14845. The design shall be such that higher the rate of flow the greater the resultant down thrust keeping the ball 'glued' to its seat until the last drop of air is expelled from the pipe system.

The valves shall have an integrated sluice valve. If required, they shall be installed on a flange welded on the MS pipe / special. The possible air velocity (inflow and outflow) must be at least 10 m/s. The working pressure of the air valves shall be 10 kg / cm² (1Mpa).

Construction feature

The flow of air should be as unobstructed as possible. The low-pressure orifice shall be in the same axis as the main discharge/incoming airflow and must have a diameter sufficiently large.

The cone angle in the low-pressure (large orifice) chamber should be carefully calculated and there should be adequate height to allow for free movement of the vulcanite ball in the low chamber. The annulus around the low-pressure vulcanite covered ball is to be generously proportioned for discharge of air under various differential pressures.

The orifice shall be carefully profiled to allow the requisite flow of air under varying differential pressure. It shall be in moulded synthetic rubber such that even after extended contact the vulcanite covered ball does not stick to it when the line pressure becomes zero.

In the high-pressure chamber the orifice shall be in profiled in such a manner that the rubber-covered ball is not damaged even after extended contact. There should be machined guide in the chamber, which ensures that the ball travels vertically and makes contact with the nipple and seals off the orifice without fail.

Material

The material for different component parts of the air valve shall conform to requirements given below:

S No.	Component	Specifications
1	Body	Cast Iron conforming to IS: 210 GR FG 200
2	High Pressure Cover	Cast Iron confirming to IS 210 GR FG 200
3	Low Pressure Cover	Cast Iron confirming to IS 210 GR FG 200
4	Cowl	Cast iron confirming to IS 210 GR FG
5	High Pressure Orifice Plug	Stain less steel conforming to AISI 410
6	Low pressure ball	Vulcanite covered seasoned timber
7	High pressure ball	Rubber covered seasoned timber
8	Lower pressure seat ring	Dexine (Nitrile rubber)
9	Isolating sluice valve	Conforming to IS: 780 – 1984
10	Spindle for sluice valve	Stainless steel conforming to AISI 410
11	Bolts and nuts	Mild steel

The body and seat of the valve shall withstand a working pressure of 10 kg/cm² for at least 15 minutes.

Inspection

Third Party Inspection:

The following items of supply will be got inspected from approved inspecting agency (CEIL, SGS. RITES) at manufacturers premises before dispatch at his own cost.

1. Ductile Iron pipes, rubber gaskets & specials
2. Sluice valves,
- 3 HDPE pipes

Specifications for Laying and Jointing of Pipe Line System for Water Supply

Preparatory work

The contractor will inspect the route along which the pipe line is proposed to be laid. He should observe/ find out the existing underground utilities/ construction and propose an alignment along which the pipeline is to be laid. He should make all efforts to keep the pipe as straight as possible with the help of ranging rods. Wherever there is need for deviation, it should be done with the use of necessary specials or by deflection in pipe joints (limited to 75% of permissible deflection as per manufacturer). The alignment as proposed should be marked on ground with a line of white chalk and got approved from Engineer In-Charge. The Contractor will than prepare an L-Section along this alignment showing the location of proposed pipeline. The L-section should be got approved from the site Engineer. The position of fittings, valves, should be shown on the plan.

Alignment and the L-Sections

The alignments, L-section (depth of laying) and location of specials, valves and chambers may be changed at site in co-operation with and after approval of the Engineer in Charge. The minimum cover to the top of the pipe shall be 1 m.

Standards

Except as otherwise specified in this technical specification, the Indian Standards and Codes of Practice in their latest version, National Building code, PWD specification of the state of Rajasthan and Manual of water supply of GOI shall be adhered to for the supply, handling, laying, installation, and site testing of all material and works.

Tools and equipment

The contractor has to provide all the tools and equipment required for the timely, efficient and professional implementation of the work as specified in the various sections of the contract and as specified by the instructions of manufacturers of the pipes and other material to be handled under this contract. On demand he shall provide to the Engineer in Charge a detailed list of tools and equipment available. If in the opinion of the Engineer in Charge the progress or the quality of the work cannot be guaranteed by the available quantity and type of tools and equipment the contractor has to provide additional ones to the satisfaction of the Engineer in Charge. The Contractor will always have a leveling instrument on site.

Handling and laying of pipes

Transportation of pipes and specials & Storage:-

The Contractor has to transport the pipes and other materials from manufacturer to the site of laying as indicated by the Engineer in Charge. Pipes should be handled with care to avoid damage to the surface and the socket and spigot ends, deformation or bending. Pipes shall not be dragged along the ground or the loading bed of a vehicle. Pipes shall be transported on flat bed vehicles/trailers. The bed shall be smooth and free from any sharp objects. The pipes shall rests uniformly on the vehicle bed in their entire length during transportation. Pipes shall be loaded and un-loaded manually or by suitable mechanical means without causing any damage to the stacked pipes.

The transportation and handling of pipes shall be made as per IS 12288. Handling instructions of the manufacturers of the pipes shall be followed. All precautions set out shall be taken to prevent damage to the protective coating, damage of the jointing surfaces or the ends of the pipes.

Whatever method and means of transportation is used, it is essential that the pipes are carefully placed and firmly secured against uncontrolled movement during transportation to the satisfaction of engineer in charge.

Cranes or chain pulley block or other suitable handling and lifting equipment shall be used for loading and un-loading of heavy pipes. However, for pipes up to 400 mm nominal bore, skid timbers and ropes may be used. Where using crane hooks at sockets and spigot ends hooks shall be broad and protected by rubber or similar material, in order to avoid damage to pipe ends and lining. Damage to lining must be repaired before pipe laying according to the instructions of the pipe manufacturer. Pipes shall not be thrown directly on the ground or inside the trench.

When using mechanical handling equipment, it is necessary to employ sufficient personnel to carry out the operation efficiently with safety. The pipes should be lifted smoothly without any jerking motion and pipe movement should be controlled by the use of guide ropes in order to prevent damage caused by pipes bumping together or against surrounding objects.

Rolling or dragging pipes along the ground or over other pipes already stacked shall be avoided.

The pipe should be given adequate support at all times. Pipe should be stored on a reasonably flat surface free from stones and sharp projections so that the pipe is supported through out its length. In storage, pipe racks should provide continuous support and sharp corners of metal racks should be avoided. Socket and Spigot pipes should be stacked in layer with sockets placed in alternate ends of the stack to avoid lop sided stacks.

Pipes should not be stored inside another pipe. On no account the pipes should be stored in stressed or bent condition or near the sources of heat. Pipes should not be stacked more than 1.5 m high and pipes of different sizes and classes should be stacked separately. The ends of the pipes should be protected from abrasion. The pipes should be protected from U.V. rays and excessive heat at all times. Their storage facility should be well ventilated.

The Contractor shall provide proper and adequate storage facilities to protect all the materials and equipment's against damage from any cause whatsoever and in case of any such damage/theft, the Contractor shall be held responsible.

The contractor will lay the pipelines along the alignments as per the layout given by the Engineer in Charge. The layout shall be given keeping in view the information available regarding existing services like water lines, sewers, telephone and electric lines/ cables. In the event some services fall in the alignment of lines to be laid, the contractor shall have to shift such services for which a provision has been made in the BOQ. The contractor shall take all due care to avoid damage to any such services and, in case of any damage occurring to them in progressing the work, the Contractor shall make good the same at his own cost. No additional time shall, however, be allowed on this account.

Stringing of pipes along the alignment

The pipes shall be laid out properly along the proposed alignment in a manner that they do not create any significant hindrance to the public and that they are not damaged.

Stringing of the pipe end to end along the working width should be done in such a manner that the least interference is caused in the land crossed. Gaps should be left at intervals to permit the passing of equipment across the working area. Pipes shall be laid out that they remain safe where placed and that no damage can occur to the pipes and the coating until incorporated in the pipeline. If necessary, pipes shall be wedged to prevent accidental movement. Precautions shall be made to prevent excessive soil, mud etc. entering the pipe.

Generally, the pipes shall be laid within two weeks from the date of their dispatch from the manufacturer /store .

Pipe trench

Trench excavation

The trench excavation of pipeline shall be in accordance with IS 12288. Pipe trenches shall be excavated to the lines and levels shown on the drawings or as directed by the Engineer in Charge. The depth of the excavated trench shall be as given in the drawings or as directed by the Engineer in Charge. The width of the trench at bottom between the faces of sheeting shall be such as to provide 200 mm clearance on either side of the Diameter. No pipe shall be laid in a trench until the section of trench in which the pipe is to be laid has been approved by the Engineer in Charge.

The depth should be sufficient to provide a cover not less than 1000 mm. It may be necessary to increase the depth of pipeline to avoid land drains or in the vicinity of roads, railways or other crossings. Care should be taken to avoid the spoil bank causing an accumulation of rainwater.

The bottom of the trench shall be trimmed and leveled to permit even bedding of the pipes. It should be free from all extraneous matter, which may damage the pipe or the pipe coating. Additional excavation shall be made at the joints of the pipes, so that the pipe is supported along its entire length.

All excavated material shall be stacked in such a distance from the trench edge that it will not endanger the work or workmen and it will avoid obstructing footpaths, roads and driveways. Hydrants under pressure, surface boxes, fire or other utility controls shall be left unobstructed and accessible during the construction work. Gutters shall be kept clear or other satisfactory provisions made for street drainage, and natural watercourses shall not be obstructed.

To protect persons from injury and to avoid damage to property, adequate barricades, construction signs, torches, red lanterns and guards, as required, shall be placed and maintained during the progress of the work and until it is safe for traffic to use the roadways. All materials, piles equipment and pipes which may serve as obstruction to traffic shall be enclosed by fences or barricades and shall be protected by illuminating proper lights when the visibility is poor.

As far as possible, the pipe line shall be laid below existing services, like water and gas pipes, cables, cable ducts and drains but not below sewers, which are usually laid at greater depth. Where it is unavoidable, pipeline should be suitably protected. A minimum clearance of 150 mm shall be provided between the pipeline and such other services.

Trees, shrubbery fences, poles, and all other property and surface structures shall be protected. Tree roots shall be cut within a distance of 50 cm from pipe joints in order to prevent roots from entering them. Temporary support, adequate protection and maintenance of all under ground and surface structures, drains, sewers and other obstructions encountered in the progress of the work shall be provided. The structures, which will be disturbed, shall be restored after completion of the work.

Where water forms or accumulates in any trench the Contractor shall maintain the trench free of water during pipe laying.

Wherever necessary to prevent caving, trench excavations in soils such as sand, gravel and sandy soil shall be adequately sheeted and braced. Where sheeting and bracing are used, the net trench width after sheeting shall not be less than that specified above. The sides of the excavation shall be adequately supported at all times and, except where described as permitted under the Contract, shall be not battered.

The Engineer in Charge in co-operation with the Contractor shall decide about the sheeting/ bracing of the trench according to the soil conditions in a particular stretch and taking into account the safety requirements of the Contractor's and Engineer-In- Charge's staff. Generally, safety measures against caving have to be provided for trenches with vertical walls if they are deeper than 2.0 m.

Trench excavation to commensurate with the laying progress

The work of trench excavation should be commensurate with laying and jointing of the pipeline. It should not be dug in advance for a length greater than 500 m ahead of work of laying and jointing of pipeline unless otherwise permitted by the Engineer in Charge. The Contractor has to ensure the following:

- safety protections as mentioned above have to be incorporated in the work process
- hindrances to the public have to be minimized
- the trench must not be eroded before the pipes are laid
- the trench must not be filled with water when the pipes are laid
- the trench must not be refilled before laying of the pipes

The bed for the laying of the pipes has to be prepared according to the L-Section immediately before laying of the pipes.

Bedding of the pipes

The trench bottom shall be even compact and smooth so as to provide a proper support for the pipe over its entire length, and shall be free from stones, lumps, roots and other hard objects that may injure the pipe or coating. Holes shall be dug in the trench bottom to accommodate sockets so as to ensure continuous contact between the trench and the entire pipe barrel between socket holes.

Laying and jointing of pipes

General

The pipes will be cleaned in the whole length with special care of the spigot and sockets on the inside/ outside to ensure that they are free from dirt and unwarranted projections. The whole of the pipes shall be placed in position singly and shall be laid true to profile and direction of slope indicated on longitudinal sections. The pipes shall be laid without deflection in a straight alignment between bends and between high and low points. Vertical and horizontal deflections between individual pipes need the approval of the Engineer in Charge. In no case the deflection shall be more than 75 % of those recommended by the manufacturer.

Before pipes are jointed they shall be thoroughly cleaned of all earth lumps, stones, or any other objects that may have entered the interior of the pipes, particularly the spigot end and the socket including the groove for the rubber ring.

Pipes and the related specials shall be laid according to the instructions of the manufacturers and using the tools recommended by them.

Cutting of pipes shall be reduced to a minimum required to conform to the drawings. Cutting has to be made with suitable tools and according to the recommendations of the manufacturer. The spigot end has to be chamfered again at the same

angle as the original chamfered end. Cutting shall be perpendicular to the Centre line of the pipe. In case of ductile iron pipes the cut and chamfered end shall be painted with two coats of epoxy paint. If there is no mark for the insertion depth on the spigot end of the (cut) pipe it shall be marked again according to the instructions of the manufacturer.

Before pipes are jointed they shall be thoroughly cleaned of all earth lumps, stones, or any other objects that may have entered the interior of the pipes, particularly the spigot end and the socket including the groove for the rubber ring. End caps are removed only just before laying and jointing

All specials like bends, tees etc. and appurtenances like sluice or butterfly valves etc. shall be laid in synchronization with the pipes. The Contractor has to ensure that the specials and accessories are ready in time to be installed together with the pipes.

At the end of each working day and whenever work is interrupted for any period of time, the free ends of laid pipes shall be protected against the entry of dirt or other foreign matter by means of approved plugs or end caps.

When pipe laying is not in progress, the open ends of installed pipe shall be closed by approved means to prevent entrance of trench water and dirt into the line.

No pipe shall be laid in wet trench conditions that preclude proper bedding, or when, in the opinion of the Engineer in Charge, the trench conditions or the weather are unsuitable for proper installation.

The pipeline laid should be absolutely straight unless planned otherwise. The accuracy of alignment should be tested before starting refilling with the help of stretching a string between two ends of the straight stretch of pipes to rectify possible small kinks in laying.

Special Cast Iron fittings and Accessories

Normally when pipeline is laid, a certain number of cast iron fittings such as tees, bends, reducers, etc, and special fittings such as air or sluice valves are required.

Laying of Fittings – All cast iron fittings shall be plain ended to suit the outside diameter of Asbestos cement pressure pipes and to the class and diameter of pipe manufactured. When using such cast iron fittings, they are jointed by cast iron detachable joints only. For cast iron specials having flanges, they are jointed in the pipeline with cast iron flange adaptors having one end flanged and the other plain ended.

Anchorage - It should particularly be noted that the cast iron joints do not hold pipe ends within it firmly. During working or test pressure, there will be tendency for the pipe ends or special ends to slip out of the joint, more so with the case of blank end cap used for closure of pipeline and all degree bends and tees. In order to keep them firmly in the pipeline, anchoring of these specials are necessary against the direction of thrust.

The anchorage shall consist of either concrete cast-in-situ or masonry built in cement mortar. The anchors shall be extended to the firm soil of the trench side. The shape of the anchors will depend on the kind of specials used. They shall be spread full width of trench and carried vertically by the side and over the special to about 15 cm. The bearing area on sides of the trench will be proportional to the thrust and to bearing capacity of the sides of the trench.

Back filling and tamping

The soil under the pipe and coupling shall be tamped in order to provide a firm and continuous support to the pipeline.

Tamping shall be done either by tamping bars or by using water to consolidate the back fill material.

The initial back fill material used shall be free of large stones and dry lumps. In stony areas the material for initial back fill can be shaved from the sides of the trenches. In bogs and marshes, the excavated material is usually little more than vegetable matter and this should not be used for bedding purposes. In such cases, gravel or crushed stone shall be hauled in.

The initial back fill shall be placed evenly in a layer of about 100 mm thick. This shall be properly

Consolidated and this shall be continued till there is a cushion of at least 300 mm of cover over the pipe.

If it is desired to observe the joint or coupling during the testing of mains they shall be left exposed.

Sufficient back fill shall be placed on the pipe to resist the movement due to pressure while testing.

Balance of the back fill need not be so carefully selected as the initial material. However, care shall be taken to avoid back filling with large stones, which might damage the pipe when spaded into the trench.

Pipes in trenches on a slope shall have extra attention to make certain that the newly placed back fill will not become a blind drain in effect because until back fill becomes completely consolidated, there is a tendency for ground or surface water to move along this looser soil resulting in a loss of support to the pipe. In such cases, the back fill should be tamped with extra care and the tamping continued in 100 mm layers right up to the ground level.

Anchoring of the pipeline

Thrust blocks shall be provided at each bend, tee, taper, end piece to prevent undue movements of the pipeline under pressure. They shall be constructed as per actual design and approval of Engineer in Charge according to the highest pressure during operation or testing of the pipes, the safe bearing pressure of the surrounding soil and the friction coefficient of the soil.

Providing HDPE Pipes & Specials**HDPE PIPES****HDPE Pipes**

The HDPE (High density polyethylene) pipes (for water supply) confirming to IS 4984-1995 and duly marked with certification of BIS shall only be supplied. The pipe shall confirm to the test requirements prescribed in IS 4984-1995. The minimum factory test pressure for hydraulic test shall be 2 times the rated pressure of pipe for 60 seconds. No defect/ leakage/ cracks should be visible after hydraulic test.

Colour

The colour of pipe shall be black. Each pipe shall contain minimum three equispaced longitudinal stripes of width 3mm in blue colour. These strips shall be co-extruded during pipe manufacturing and shall not be more than 0.2mm depth. The material of the stripes shall be same type of resin, as used in the base compound for the pipe.

Material

The raw material used for the manufacture of pipes should not constitute toxic hazard, should not support microbial growth and should not give rise to unpleasant taste or odor, clouding or discoloration of water.

The pipes shall be manufactured from 100% virgin PE-80 High density polyethylene (HDPE) food grade raw material with minimum required strength of 8MPa (PE-80). The raw material should be of food grade quality. The nominal pressure of pipes required shall be as specified in the scope of work. The pipe material shall be suitable for conveyance of drinking water for which the certificate of recognized institute shall be provided.

High density polyethylene (HDPE) used for the manufacture of pipes shall confirm the designation PEEWA-45-T-003 or PEEWA-45-T-006 or PEEWA-50-T-003 or PEEWA-50-T-006 or PEEWA-57-T-003 or PEEWA-57-T-006 of IS: 7238/1992. In addition the material shall also confirm to 5.6.2 of IS 7328-1992.

The specific base density shall be between 940.0 Kg/Cum and 958.4 Kg/Cum (both inclusive) when determined at 27 °C according to procedure prescribed in Annexure "A" of IS: 7328/1992. The value of the density shall not differ from the nominal value by more than 3 kg/cum as per 5.2.1.1 of IS 7328-1992.

The MFR (Melt Flow Rate) of the material shall be between 0.20g/10min and 1.10g/10min (both inclusive) when tested at 190 degree C with nominal load of 5 Kgf when determined by the method prescribed in 7 of IS: 2530-1963. The MFR of the material shall be within +/- 20% of the value declared by the manufacturer.

The resin shall be compounded with Carbon black. The Carbon Black content in the material shall be within 2.5 + 0.5% and dispersion of Carbon black shall be satisfactory when tested according to the procedure prescribed in IS: 2530-1963.

With the advancement in technology natural (unpigmented) resin designation PEEWA-45-T-003 or PEEWA-45-T-006 or PEEWA-50-T-003 or PEEWA-50-T-006 or PEEWA-57-T-003 or PEEWA-57-T-006 of IS: 7238/1992 duly stabilized with anti-oxidants may be compounded with suitable black master batch or processed directly after physical mixing with suitable black master batch in the pipe extruder for production of pipes, which shall confirm to the performance requirements of the pipe as specified in IS 4984. The material of pipe thus produced shall confirm to the requirements of 5.2 of IS 4984-1995.

The percentage of anti-oxidant used shall not be more than 0.3 percent by mass of finished resin. The anti-oxidant used shall be physiologically harmless and shall be selected from the list given IS: 10141-1982.

No reworked or recycled material shall be used.**Dimensions**

The outside diameter of pipes, tolerance on the same and ovality of pipes, and minimum and maximum wall thickness shall be confirming to IS 4984-1995. The length of straight pipe shall be 5 to 20m. However wherever specifically required under the conditions of contract, the pipes shall be supplied in coils.

Visual appearance

The internal and external surfaces of pipes shall be smooth, clean and free from grooving and other defects. The ends of the pipes shall be cleanly cut square with the axis to within the tolerances given in IS 4984 and free from deformity. Slight shallow longitudinal grooves or irregularities in the wall thickness shall be permissible provided that the wall thickness remains within the permissible limits.

Inspection and Testing of HDPE Pipes

The HDPE pipes supplied by the contractor shall be subjected to following tests as per IS 4984 for acceptance:

- Visual and dimensional check as per IS 4984
- Hydraulic characteristics/ Internal pressure creep rupture test as per IS 4984
- Longitudinal reversion test as per IS 4984
- Overall Migration test
- Density test
- Melt flow rate test
- Carbon black content and Dispersion test
- Any other test required as per provisions to which supplied pipes confirms i.e. (IS 8329)
- Hydraulic test at manufacturer premises before dispatch.

In addition the following are required for review by inspection authority:

- The test reports of raw material.
- The type test report of pipe. This shall not be more than two years old from the date of inspection of pipes.
- Notch Impact test as per ASTM-1474. HDPE pipes when tested as per ASTM-1474 (Notch Impact Test) should pass the Hydraulic test as per IS:4984:1995 for a minimum 165 Hrs. This test can be carried out at factory or at some private laboratory. Such report should not be more than 2 Month old from date of inspection.

The sampling method for testing shall be as per the provisions of the standards to which they are manufactured.

The pipes shall also be got tested from CIPET and amount for testing shall be borne by contractor. Department shall demand for manufacturers' test report for pipes along with pre dispatch inspection by EIC or his authorized representative.

Marking

All pipes shall be marked as per the provisions of IS 4984 and subjected to following minimum requirements:

Manufacturer name/ Trade mark,

Designation of pipe,

Lot number/ Batch number,

Manufacturing standard to which the pipe confirms (IS 4984) and BIS certification mark,

Mark of pre-dispatch Inspecting authority.

TRANSPORTATION / STORAGE OF PIPES AND SPECIALS:

The Contractor has to transport the pipes and other materials from manufacturer to the site stores and from the site stores to the site of laying as per the instructions given by the Engineer in Charge. Pipes should be handled with care to avoid damage to the surface and the socket and spigot ends, deformation or bending. Pipes shall not be dragged along the ground or the loading bed of a vehicle. Pipes shall be transported on flat bed vehicles/trailers. The bed shall be smooth and free from any sharp objects. The pipes shall rests uniformly on the vehicle bed in their entire length during transportation. Pipes shall be loaded and un-loaded manually or by suitable mechanical means without causing any damage to the stacked pipes.

The transportation and handling of DI pipes shall be made as per IS 12288. All precautions set out shall be taken to prevent damage to the protective coating, damage of the jointing surfaces or the ends of the pipes.

Whatever method and means of transportation is used, it is essential that the pipes are carefully placed and firmly secured against uncontrolled movement during transportation to the satisfaction of engineer in charge.

Damage to lining must be repaired, as per relevant IS code, before pipe laying according to the instructions of the pipe manufacturer after taking approval of EIC. Pipes shall not be thrown directly on the ground or inside the trench.

When using mechanical handling equipment, it is necessary to employ sufficient personnel to carry out the operation efficiently with safety. The pipes should be lifted smoothly without any jerking motion and pipe movement should be controlled by the use of guide ropes in order to prevent damage caused by pipes bumping together or against surrounding objects.

Rolling or dragging pipes along the ground or over other pipes already stacked shall be avoided.

The pipe should be given adequate support at all times. Pipe should be stored on a reasonably flat surface free from stones and sharp projections so that the pipe is supported through out its length. In storage, pipe racks should provide continuous

support and sharp corners of metal racks should be avoided. Pipes should not be stacked in large piles for all pipes. Socket and Spigoted pipes should be stacked in layer with sockets placed in alternate ends of the stack to avoid lop sided stacks. Pipes should not be stored inside another pipe. On no account the pipes should be stored in stressed or bent condition or near the sources of heat. Pipes should not be stacked more than 1.5 m high and pipes of different sizes and classes should be stacked separately. The ends of the pipes should be protected from abrasion. The pipes should be protected from U.V. rays and excessive heat at all times. Their storage facility should be well ventilated.

The Contractor shall provide proper and adequate storage facilities to protect all the materials and equipments against damage from any cause whatsoever and in case of any such damage/theft, the Contractor shall be held responsible.

The contractor will lay the pipelines along the alignments as per the approved L section. layout shall be given by the Engineer in Charge of his authorized representative.

The layout shall be given keeping in view the information available regarding existing services like water lines, sewers, telephone and electric lines/ cables. In the event some services fall in the alignment of lines to be laid, the contractor shall have to shift the alignment or such services. The contractor shall take all due care to avoid damage to any such services and, in case of any damage occurring to them in progressing the work, the Contractor shall make good the same at his own cost. No additional time and payment shall be allowed on this account. Rubber rings shall be handled and stored in their original packing, protected against sunlight and contacts with petroleum product, solvents and paints. The Contractor shall provide suitable lifting equipment for loading, unloading and laying of the pipes.

Specials for HDPE Pipes

Unless otherwise specified, the specials and the jointing material for HDPE pipes shall be Fusion fittings confirming to GBE/PL2:PART 4. Fusion fittings with integral heating element shall be used in general. All fittings shall be of Class B. Fittings shall be produced from material class PE 80 or PE 100. The fittings shall be free from cracks, voids, blisters, holes, distortion, dents, injurious incisions, inclusions or any other likely to impair their performance. For each fitting the fusion time shall be the same.

Laying and Jointing of Pipeline

Trench Excavation

The trench excavation of pipeline shall be in accordance with IS 7634 for HDPE pipes,. Pipe trenches shall be excavated to the lines and levels shown on the drawings or as directed by the Engineer in charge. The depth of the excavated trench shall be as specified in drawing or as directed by the Engineer in charge. The pipe shall not be laid in a trench, until the section of trench, in which the pipe is to be laid, has been approved by the Engineer in charge. The average cover should not be less than 900mm above pipe and in no case be less than 600mm when laid underground.

The bottom of the trench shall be trimmed and leveled to permit even bedding of the pipes. It should be free from all extraneous matter, which may damage the pipe coating. Additional excavation shall be made at the joints of the pipes, so that the pipe is supported along its entire length.

All excavated material shall be stacked in such a distance from the trench edge, so that it will not endanger the work or workmen and it will avoid obstructing footpaths, roads and driveway. Hydrant, surface boxes, fire or other utility controls shall be kept unobstructed and accessible during the construction work and be kept clear or other satisfactory provisions made for street drainage, Natural water-courses shall not be obstructed.

To protect persons from injury and damage to property, adequate barricades, construction signs torches, red lanterns and guards, as required, shall be placed and maintained during the progress of the work and until it is safe for traffic to use the roadways.

All materials, pipes equipment and pipes which may serve as obstruction to traffic, shall be enclosed by fences or barricades and shall be protected by illuminating proper lights when the visibility is poor.

As far as possible, the pipeline shall be laid below existing services, like water and gas pipes, cable ducts and drains but not below sewer, which are usually laid at greater depth. Where it is unavoidable, pipeline should be suitably protected. A minimum clearance of 150mm shall be provided between the pipeline and such other services.

Tree, shrubbery, fences, poles and all other property and surface structures shall be protected. Tree roots shall be cut within a distance of 50 cm from pipe joints in order to prevent roots from entering them. Temporary support, adequate protection and maintenance of all underground and surface structures, drains, sewers and other obstructions encountered in the progress of the work shall be provided. The structures, which will be disturbed, shall be restored after completion of the work. Where water accumulates in any trench the contractor shall maintain the trench free of water during pipe laying.

Wherever necessary to prevent caving, trench excavation in soils such as sand, gravel and sandy soil shall be adequately sheeted and braced. Where sheeting and bracing are used, the net trench width after sheeting shall not be less than that specified above. The sides of the excavation under shall be adequately supported at all time and except where described as permitted under the contract, shall be not battered.

The Engineer in charge in co-operation with the contractor shall decide about the sheeting/ bracing of the trench according to the soil conditions in a particular stretch and taking into account the safety requirements of contractor's and PHED staff.

Excavation for Laying Pipe Line along the road

While laying the pipeline below ground along the roadside, the contractor shall observe the following:

The contractor shall not be allowed to take earth from the burrow pits if excavation required to take additional earth.

If invert of pipe is kept above the existing burrow pit level or part of pipe is above it, the minimum side slopes of 1:1 shall be provided on the side towards the burrow pit area so as to provide required cover. The side slopes shall be properly compacted.

If earth is taken for providing required cover to pipe from the burrow pits, the burrow pits shall be so graded that no impounding of water is possible in burrow pit area.

If the pipeline is laid just near the road section, as far as practical, minimum cover of 1.00 meter shall be used. Whenever this requirement of cover cannot be ensured, pipeline shall be covered with properly designed pre-cast concrete slab.

Dewatering

Though the site for laying of pipe line does not requires any dewatering (except within City campus where the starting Pumping Station exist.) but if any dewatering is required to complete the work than it will be the responsibility of the contractor.

Fencing, Watching and Lighting

The posts of the fencing shall be of timber, securely fixed in the ground not more than 2.5 m. apart. They shall not be less than 10 cm in dia. or not less than 1.25 m above the surface of ground. There shall be two rails, one near the top of the posts and the other about 0.5 m above the ground and each shall be of 5 cm to 10 cm in dia. and sufficiently long to run from post to post which they shall be bound with strong ropes. The method, of projecting rails beyond the posts and tying together where they meet will not be allowed on any account. All along the edges of the excavated trenches, a bund of earth about one meter high shall be formed where so required by the Engineer-in-Charge for further protection. Proper provision shall be made for lighting at night and watchman shall be kept to see that this is properly done and maintained. In addition to the normal lighting arrangements, the contractors shall provide wherever such work is in progress, battery operated blinking light (6 volts) in the beginning and end of a trench with a view to provide suitable indication to the vehicular traffic. The contractor shall provide and display special boards printed with fluorescent paints indicating the progress of the work along the road. The contractor shall be held responsible for payment of all claims for compensation as a result of accident or injury to any person or property due to improper fencing, inadequate lighting or non-provision of red flags. The contractors shall at their own cost provide all notice boards before opening of roads as directed by the Engineer-in-Charge. The contractor shall make arrangements to direct traffic whenever work in through fare is in progress.

Trench Excavation to Commensurate with the laying progress

The work of trench excavation should not be dug in advance for a length greater than 500m ahead of work of laying and jointing of pipeline unless otherwise defined by the Engineer in charge. The contractor has to ensure the following:

- Safety protections as mentioned above have to be incorporated in the work process.
 - Hindrances to the public have to be minimized.
 - The trench must not be eroded before the pipes are laid.
 - The trench must not be filled with water when the pipes are laid.
 - The trench must not be refilled before laying of the pipes.
- The bed for laying of the pipes has to be prepared according to the L-section immediately before laying of the pipe.

Bedding of The pipes

The trench bottom should be even and smooth so as to provide a proper support for the pipe over its entire length, and shall be free from stones, lumps, roots and other hard objects that may injure the pipe or coating. Holes shall be dug in the trench bottom to accommodate sockets couplings so as to ensure continues contract between the trench and entire pipe barrel between socket holes.

Storage of HDPE pipes

Black polythene pipes may be stored either under cover or in the open. Coils may be stored on edge or stacked flat one on top of the other but in either case they should not be allowed to come into contact with hot water or steam pipes and should be kept away from hot surface. Straight lengths should be stored on horizontal racks giving continuous support to prevent the pipe taking on a permanent set. Storage of pipes in heating areas exceeding 270C should be avoided. If due to unsatisfactory storage or handling, a pipe is damaged or kinked, the damaged portion should be cut out completely.

Transportation and Handling of Pipes and Specials

The contractor has to transport the pipes and jointing material from the site of unloading to the site of laying as indicated by the Engineer in charge. Pipes should be handled with care to avoid damage to the surface and the socket and spigot ends, deformation or bending. Pipes should not be dragged along ground or the loading bed of vehicle. Pipes shall be transported on flat bed vehicle/ trailers. The bed shall be smooth and free from any sharp object. The pipes shall be loaded in such a way that they are secured and no movement should take place on the vehicle during transit. Pipes shall be loaded and unloaded manually or by suitable mechanical means/ cranes from the site of unloading without causing any damage to the stacked pipes. The pipes shall be lifted smoothly without jerking motion and pipe movement should be controlled by use of guide ropes. Handling shall be careful to avoid any damage to pipe or inner mortar lining of DI pipes. The lifting hooks if used shall be broad enough and pipe ends should be protected by rubber or similar material in order to avoid damage to the pipe ends. Rolling or dragging pipes along the ground or over other pipes shall also be avoided.

The pipes shall be laid out properly along the proposed alignment in a manner that they do not create any significant hindrance to the public or traffic and that they are not damaged on this account.

Stringing of the pipes end to end along the working width should be done in such a manner that the least interference is caused in the land crossed. Gaps should be left at intervals to permit the passing of equipment across the working area. Pipes shall be laid out such that they remain safe where placed and that no damage can occur to the pipes. If necessary, pipes shall be wedged to prevent accidental movement. Precautions shall be made to prevent excessive soil, mud etc. entering the pipe.

The joint gasket shall be kept in wooden boxes or their original packing and stored in cool conditions and not exposed to direct sunlight. Gaskets must not be deformed. They shall be taken out only shortly before they are needed.

Laying and Jointing of Pipes

HDPE pipes as per IS 7634; however the specific references given herein shall prevail on the provisions of the standards. Pipes should be lowered in the trench with tackle suitable for the weight of pipes. For smaller sizes up to 200mm nominal bore, the pipe may be lowered by the use of ropes.

The pipes and specials shall be inspected and defects noticed if any such as hair cracks, broken ends or damages etc. shall have to be removed/ rectified by contractor. Ends of pipes and specials shall have to be made good as and when required before laying and jointing. The pipes shall be cleaned in whole length with special care of the spigot and sockets/ other ends on the inside/outside to ensure that they are free from dirt and unwanted projections. The whole pipe shall be placed in position singly and shall be true to profile and direction of slope indicated. The pipes shall be laid without deflection in a straight line between bends and between high and low points. Vertical and horizontal deflections between individual pipes shall be not more than the permissible limits.

The pipes shall rest continuously on bottom of the trench and not on lumps of earth or on the joints. Before pipes are jointed they shall be thoroughly cleaned of all earth lumps, stones, or any other objects that may have entered the interior of pipes, particularly the spigot end and the socket including the groove for the rubber gasket. End caps are removed just before laying and jointing. The pipes and specials shall be laid accordingly to the instructions of manufacturer and using the tools recommended by them.

Where gradient of the bed slopes is more than 15 degrees, it may be necessary to anchor pipes against their sliding downwards, by providing suitable gradient blocks and straps.

All specials like bends, tees etc. and appurtenances like sluice or reflux valves etc. shall be laid in synchronization with the pipes. The contractor has to ensure that the specials and accessories are ready in time to be installed together with the pipes.

At the end of each working day and whenever work is interrupted for any period of time, the free ends of laid pipes shall be protected against the entry of dirt or other foreign matter by means of approved plugs or end caps.

No pipe shall be laid in wet trench conditions that preclude proper bedding, or when, in the opinion of the Engineer in charge, the trench conditions or the weather are unsuitable for proper installation.

Cutting of pipes shall be reduced to minimum required. The cutting of DI pipe for inserting valves, fittings etc. shall be done in a neat and workman like manner without damage to the pipe or lining so as to leave a smooth end at right angles to the axis of the pipe. Cutting shall be done by Hacksaw or Wheel cutter or pipe cutting machine according to the recommendations of manufacturer.

Suitably designed anchorage shall be provided at changes in direction and at dead ends to resist the static thrusts developed by internal pressure.

No pipe shall be laid in the wet trench conditions that preclude proper bedding, or when in the opinion of Engineer In-charge, the trench conditions or weather are unsuitable for proper installation.

laying underground

All construction debris should be cleaned from the inside of the pipe either before or just after a joint is made. This is done by passing a pull through in the pipe or by hand depending upon the size of pipe.

On gradient of 1:15 or steeper, precautions shall be taken to ensure that the spigot of pipe being laid does not move into or out of the socket of the laid pipe during the jointing operations. As soon as the joint assembly has been completed, the pipe should be held firmly in position while the trench is backfilled over the barrel of the pipe. The backfill should be well compacted.

The socket and spigot ends/ other ends of the pipes shall be brushed and cleaned. The chamfered surface and the end of the spigot end have to be coated with a suitable lubricant recommended by the manufacturer of the pipes. Oil, petroleum bound oils, grease or other material which may damage the rubber gasket shall not be used as lubricant. The rubber gasket shall be inserted into the cleaned groove of the socket. It has to be checked for correct positioning.

The two pipes shall be aligned properly in the pipe trench and the spigot end shall be pushed axially into the socket either manually or with a suitable tool specially designed for the assembly of pipes and as recommended by the manufacturer. The spigot has to be inserted up to the insertion mark on the pipe spigot. After insertion the correct position of the socket has to be tested with a feeler blade.

The HDPE pipes shall be laid shall be laid with butt fusion welding as per IS 7634-1975. The pipe shall be cut square and the face of the pipe shall be slightly scrapped prior to welding to remove oxidized layer. At the time of welding, leveling of the pipes is essential particularly in case of larger diameter pipes. Welding temperature should be 2000C and surfaces of heating

mirror (Metallic plate heated up by electrical coil or by blow torch) should be 2100+/- 50C. The welding of pipe should be held in either side of the heating mirror with only contact pressure of about 20KPa. When the rim of molten material is found, the pipes are removed from the heating mirror and immediately the joint shall be made by application of moderate pressure of approximately 100 to 200KPa for 2-3 seconds. The initial heating time for achieving molten rim, varies from 1 to 5 minutes depending upon the pipe wall thickness and size. It is essential to see that the rim formed is not excessive and the mirror should be kept exactly around 2100C.

Laying above Ground

The ground should be dressed to match the curvature of the pipe shell for an arc length subtending an angle of 120 degree at the center of pipes. Alternatively the pipeline shall be laid either on saddle, roller or rocker supports. The pipeline may be allowed to rest on ground if soil is non-aggressive. The above ground installations of spigot and socket pipes are provided with one support per pipe, the support being positioned behind the socket of each pipe.

Backfilling of the pipe trench

All excavation shall be backfilled to the level of the original ground surfaces unless otherwise shown on the drawing or ordered by the Engineer in charge and in accordance with the requirements of the specification. The material used for backfill, the amount thereof, and the manner of depositing and compacting shall be subject to the approval of the Engineer in charge, but the contractor will be held responsible for any displacement of pipe or other structures, any damage to their surfaces, or any instability of pipes and structures caused by improper depositing of backfill materials. The backfill material shall be free from cinders, ashes, slag, refuse, rubbish, vegetable or organic material, lumpy and frozen material, boulders, rocks or stone or other material, which in the opinion of Engineer in-charge, is unsuitable or deleterious. Backfilling shall be done in layers not exceeding 15 cm in thickness after compacting, watering and compacted to a density not less than 90 percent of the maximum dry density at optimum content of the surrounding material.

Trenches crossing a road shall be backfill with selected material. Any deficiency in the quantity of material for backfilling the trenches shall be supplied by the contractor.

The contractor shall at his own expense make good any settlement of the trench back fill occurring after backfilling and until the expiry of the defect liability period.

On completion of pressure and leakage tests exposed joints shall be covered with approved selected backfill placed above the top of the pipe and joints in accordance with the requirements of the above specifications. The contractor shall not use backfilling for disposal of refuse or unsuitable soil.

Testing of Pipeline

Sectional Tests

Hydraulic testing is the ultimate check about the overall workmanship of the pipeline and therefore the pipeline system shall be hydraulically tested to the satisfaction of Engineer in charge. After laying and jointing, the pipeline shall be tested for tightness of barrel and joints, and stability of thrust blocks in sections approved by the Engineer in charge. The length of sections depends on topographical conditions. Preferably the pipeline stretches to be tested shall be between two valve chambers (air valve, sluice valve, scour valve etc.).

The water required for testing shall be arranged by the contractor himself. The contractor shall fill the pipe and compensate the leakage testing. The contractor shall provide and maintain all requisite facilities, instruments, etc. for the field-testing of the pipelines. The testing of the pipelines generally consists in three phases, preparation, pre-test/ saturation and test immediately following the pre- test. Generally the following steps are required which shall be monitored and recorded in test protocol if required.

- Complete setting of the thrust blocks.
- Partial backfilling and compaction to hold the pipes in position while leaving the joints exposed for leakage control.
- Opening of all intermediate valves (if any)
- Fixing the end pieces for tests and after temporarily anchoring them against the soil (not against the preceding pipe stretch.
 - At the lower end with a precision pressure gauge and the connection to the pump for establishing the test pressure.
 - At the higher end with a valve for air outlet.
 - If the pressure gauge cannot be installed at the lowest point of the pipeline, an allowance in the test pressure to be read at the position of Gauge has to be made accordingly.
- The pipeline to be tested shall be filled with water manually or by a low-pressure pump from lowest point(s).
- The water for this purpose shall be reasonably clear and free of solids and suspended matter.
- Complete removal of air through air valves along the line.

- Closing all air valves and scour valves.
- Slowly raising the pressure to the test pressure @ nearly 1 Kg. per Cm² per minute while inspecting the thrust blocks and the temporary anchoring.
- Keeping the pipeline under pressure for the duration of the pre-test/ saturation of the lining by adding make-up water to maintain the pressure at the desired test level. Make-up water to be arranged by contractor himself at his/ own cost.
- Start the test by maintaining the test pressure at the desired level by adding more make up water, record the water added and the pressure in intervals of 15 minute at the beginning and 30 minutes at the end of the test period.
- If a drop in pressure occurs, the quantity of water added in order to re-establish the test pressure should be carefully measured. This should not exceed 0.1 liter per mm of pipe dia per km of pipeline per day for each 30 m head of pressure applied.
- The field-testing pressures of HDPE pipelines and duration of test shall be as follows:

Field Test pressure	Test duration
1.5 times rated pressure of pipe	6 Hours

- The acceptance criteria for HDPE pipes shall be that the pressure test pressure should be maintained for test duration.
- No section of the pipe work shall be accepted by the Engineer in Charge until all requirements of the test have been obtained.
- On completion of a satisfactory test any temporary anchor blocks shall be broken out and stop ends removed. Backfilling of pipe trench shall be completed.
- Failure to pass the test
- All pipes or joints, which are proved to be in any way defective shall be replaced or remade and re-tested as often as may be necessary until a satisfactory test shall have been obtained. Any work, which fails or is proved by test to be unsatisfactory in any way, shall be redone by the contractor.

SPECIFICATIONS FOR P/L/J AND SECTIONAL TESTING OF PIPELINES

General

The contractor will inspect the route along which the pipe line is proposed to be laid. Efforts shall be made by the contractor to make minor deviations from the marked alignment so as to keep the pipe alignment as straight as possible and to avoid damage of public and private properties along the alignment. The alignment of pipe line and location of specials & chambers may be changed at site in co- ordination and with prior approval of the Engineer In Charge. The final alignment on which the pipeline shall be laid shall be marked in field and got approved from the Engineer in Charge or his representative. Where ever there is need for deviation, it should be done with the use of necessary specials or by deflection in pipe joints (limited to 75% of permissible deflection as per relevant standards). The alignment as proposed should be marked on ground with a line of white chalk and got approved from Engineer In-Charge. The position of fittings, valves, shall be as per directions of engineer-in-charge. The quality of pipes, inner mortar lining and the quality of laying shall ensure that the considered co- efficient of friction of value (Cr=1) is obtained during the designed period, so that the design is validated and the designed quantities of flow can be delivered. Thus the contractor shall ensure that the conditions of pipes its lining and the laying are perfect in all respect.

Standards

Except otherwise specified in this technical specification, the Indian Standards and Codes of Practice in their latest version, National Building code, PWD specification of the state of Rajasthan and Manual of water supply of GOI shall be adhered to for the supply, handling, laying, installation, and site testing of all material and works. The laying of pipeline shall be done in confirmations to the following standards:

.Alignment and the L-Sections

The slopes provided shall be such that in existing ground level conditions, the maximum cover over the laid pipe is neither more than 1.5 m nor less than 0.9 m, if the pipe is to be laid above ground. The average cover generally should not be less than 0.9 meters. In case of HDPE pipes, the pipes shall have a minimum cover of 900 mm when laid under roads with light traffic or under cultivated soils and 1.25 m when laid under roads with heavy traffic. When the soil has poor bearing capacity and is subject to heavy traffic, the pipes shall be laid on a concrete cradle.

PROVIDING, LAYING, JOINTING, TESTING & COMMISSIONING OF PIPE LINES AND RELATED CIVIL WORKS.

Providing, Laying, Jointing, testing & commissioning of pipe lines as mentioned in scope of work Supply and testing at works, transportation, packing all type of specials, valves and other materials to be used. Stacking and/or storage of material, re-handling as per specifications, and carry out sectional testing, pre-commissioning checks, full completion test and trial runs.

Laying and Jointing of above mentioned pipe lines as per specifications mentioned in relevant IS code and water supply manual published by CPHEEO. The pipeline alignment in general shall be as per enclosed copy of drawing, however exact alignment shall be as per the directions of Engineer in charge. The alignment approved by the Engineer-In-Charge shall be final and binding to the contractor.

Providing, testing and installing all materials such as bends, tees, reducers, dismantling joints, insulating joints, transition joints, rubber rings, flanges, nuts & bolts, rubber sheets etc. of required specifications for the installations. All specials shall be of DI/ CI / Mild steel as per the requirements of site conditions desired at the point of installation as per hydraulic considerations & as per the directions of Engineer in charge.

All material required for complete project shall be arranged by contractor himself. No material shall be provided by the department. However department may choose to provide DI pipe for rising mains and distribution system. If so no payment shall be made to contractor on account of providing pipe lines.

Sizes and numbers of valves are tentative and may vary as per the directions of Engineer in charge during execution.

The Air valve shall be provided at all convexities of L-Section but an average distance not exceeding 750m. The pressure rating of valves shall be as per the design pressure at the point of installation. The locations of sectionalizing valves shall be as per site conditions and shall be got approved from Engineer-In-Charge.

Providing thrust blocks at horizontal bends wherever required or at locations given by Engineer in Charge for the combination of loads as per site conditions. The permissible deflection in each pipe length shall be as per the provisions of relevant standards.

Providing a dismantling pipe with flexible joints or dismantling joint with each valve for easy maintenance.

Any damage caused while laying, testing, and commissioning or during execution to the private properties or any other structure etc. shall be got repaired by the contractor at no additional cost to the department.

Completion and Commissioning of the pipelines.

Removal of defects during defect liability period after successful completion of work.

SCHEDULES AND SPECIFICATIONS FOR TUBE WELL WORK

Specification and scope of tube well work

The work of construction of tube wells is to be done in JDA jurisdiction and accordingly G schedule has been prepared.

The work of drilling of bores is suitable for 200mm diameter casing pipes and strainer pipes in all type of soils and rocks including fixing of casing and strainer pipes, Gravel Packing, Wrapping coir rope and development by compressor. The boring will be done as per relevant IS : 2800-1979, 4097-1970, 4270-1967, IS : 8110 amended up to date and any other relevant code applicable along with notifications.

Definition of Strata

- 2.1 Rocky area shall mean, area where the strata essentially comprises of the rock formation with over burden of less than 30 M and the aquifer is to be tapped in rock. The rock may be with or without fissures and faults, joints and bedding. Planes may have fractured and weathered zones. Rocks may be soft, medium or hard and may comprise of shales, sand stone, lime stone, dolomite, quartzite, basalts, granite, sciests, fillities slates, cheisses etc. and their intercalation, intrusive and conglomerates of these hut shall exclude clays, sand silts, pebbles cables, murrum and silt stones. The depth of drilling can be increased or decreased as per site conditions.

- 2.2 All alluvium area shall mean, areas where the strata comprises of loose, unconsolidated material like clay, silts, sands, gravel's, pebbles, cobbles 10 cms. Diameter and 2 M thickness and boulders (Upto beds of 1.0 meter thickness and less than 15 cms. Diameter)

Installation of well assembly

Aquifer study is to be done by the tenderer and accordingly he has to design the gravel pack, blind pipe, housing pipe and slotted pipe to be used shall be made of mild steel conforming to IS : 4270/1967 and approved class. The pipes may be seamless or electric resistance welded (ERW) with specified threads.

- 3.1 The slotted pipe to be used shall be lined slots (Vertical or Horizontal) with an opening area equal to as arrived at is design. The slots size should not exceed the thickness of slotted pipe. This slots size shall be specific depending on the result by actual mechanical analysis of the aquifer samples, which shall have to be done by the tenderer. The length of the slotted pipe/strainer shall normally be not less than 3 M. It shall actually be arrive at from the thickness of the aquifer encountered. It is not necessary to screen the whole part of the aquifer and such depth should be drilled so as to give at least 4000 LPH discharge for 200 mm diameter tube well.

The slotted pipe shall be attached to the housing pipe/blind pipe by means of strong M.S. Coupling/reducers as the case may be of quality ad design approved by Engineer-in- charge. The bottom plow shall be such as to suit the design of pipe assembly.

- 3.2 The design of well assembly should be got approved from the Engineer-in-Charges before lowering is started.

Painting

Before lowering coat of approved corrosion resistance paint shall be given to all the mild steel parts of the well assembly.

Gravel Packing

Gravel to be used shall be confirming with IS : 2800 (Part-II) 1979(latest). These shall be hard, well rounded and of reasonable size free from dust and foreign material as well as flaky particles. The uniformity coefficient should not be more than 2 (uniformity coefficient = D_{60}/D_{10}).

The size of gravel shall finally depend on the mechanical analysis of the aquifer. The Gravel will have to be cleaned and washed before use. A tolerance of 10% shall be allotted in respect of grading of Gravel.

The Gravel filling of the annular space between the pipe assembly and the bore holes shall start from the bottom of bore holes and shall be done upto ground level. The gravel packing will have to be done as per IS : 2800.

For items pertaining to drilling of tube wells, casing and strainer pipe, development of well, Pumping Machinery & Panel etc (200 mm dia tube well)

The boring shall be accepted only when it's Yield is 2000 LPH or more for 200 mm diameter TUBE WELL at a draw down not exceeding 7 meters. Only payment of Drilling shall be made for the tube wells having discharge less than above. It is responsibility of contractor to fill up bore holes of such unsuccessful tube wells upto the ground level immediately. Executive Engineer shall take decision in consultation with hydrogeologist regarding successfulness of tubewell. He shall take decision on the basis of possible alternative location & cost economics of using low discharge pump set (three or single phase). The new location will be decided by the Engineer in Charge in consultation with the contractor and the hydro-geologist.

Incase of unsuccessful tube well, the contractor shall remove the casing pipe/assembly from the site at his own cost, in case material not deposited by the contractor to the Department then the cost of these items shall be recover from contractor. Payment of drilling work shall only be made for unsuccessful tube well as per the decision of 183 PPC dated 5.3.2010 (Agenda Item No. 5(iii)). If the casing pipe is provided by the department then the same shall be taken out from such failure bore as far as possible and shall be deposited in division store as per the decision taken in 183 PPC, for which no payment shall be made to the contractor. If the pipes are provided by the contractor, no

payment shall be made to him for pipes in case of failure bore. The site selection will be decided by the Engineer-in-charge in consultation with the hydrogeologist so that chances of failure of bore are minimized.

(i) 100% payment shall be made after successful completion and commissioning of the system & release of power connection for individual tube well complete in all respect. The contractor shall remove the casing pipe/assembly from the site at his own cost.

For items pertaining to drilling of tube wells, casing and strainer pipe, development of well, Pumping Machinery & Panel etc (125mm dia tube well)

Any tube well giving discharge less than 2000 litres per hour at maximum drawdown of 7 meters shall not be considered as successful. For yield more than 2000 lph & less than 3000 lph, Executive Engineer shall take decision in consultation with hydrogeologist regarding successfulness of tubewell. He shall take decision on the basis of possible alternative location & cost economics of using low discharge pump set (three or single phase). The new location will be decided by the Engineer in Charge in consultation with the contractor and the hydro-geologist.

1. During the period of defect liability, repair/replacement if the tube well fails due any negligent act of the tenderer rendering the tube well going abandoned such as falling of pump set and sticking of pump set in the bore or filling of sand in the tube wells making tube well not usable the contractor shall be responsible for clearing all such material, sand etc. It by all efforts if the tube well is not put in operation the tenderer shall provide all lost material and drill a new tube well as the case may be for which no payment shall be made to the tenderer.

For declaring a tube well dry / abandoned during the defect liability period a committee including Executive Engineer, Hydrogeologist of the department and concerning Assistant Engineer shall examine the site and shall submit their report recommending for declaring the tube well dry or abandoned.

During the defect liability period any theft or damages to the system under the contract the contractor shall be responsible for lodging all FIR etc at his own cost.

6 Development of the tube well

The tube well may be developed as per clause 9.3 of IS : 2800 (Part I)-1991 (latest). The water coming out should be silt/sand free after completion of development. The tube shall be developed by using a compressor of minimum capacity 600 cfm and pressure 7.0 kg/cm². Final discharge should be totally sand free as per IS: 2800 (Part –I) 1991 (amended upto date). The payment shall be made for actual working hours for development subject to ceiling of maximum 25 hours for each tube well. The contractor has to bear the cost of development work needed beyond 25hrs, at his own cost.

Lowering of Riser pipe in Tube Well

Providing of HDPE pipe having SS nipples on both end including nut & bolts for 40 mm to 63 mm diameter shall be lowered in required length. The flange shall have required suitable size of holes and slot for cable.

Specifications for submersible pump sets

Supply of submersible pumping sets comprising of submersible motor of sufficient horse power coupled to a pump of duty condition as specified in the schedule of rates, having detailed specification given below:

Description:

- 8.1 The submersible pump set should be in accordance with the provision of IS 8034-1976 (specification for submersible pumps sets for clear cold fresh water) amended or revised upto date.
- 8.2 The electric motor is to operate through 3 phase, 50 c/s A.C. Supply of 400 +10% volts at 3000 rpm (synchronize).
- 8.3 The pump sets shall normally be installed in bore wells and should be suitable for grounding water generally available in Rajasthan. The water to be handled by the pump sets may have total solids 3000 ppm (max), turbidity 50 ppm chlorides 1000ppm (max) pH value between 6.5 to 8.5.
- 8.4 The discharge casing, suction casing, and pump bowl shall be made from cast iron grade FG 200 IS 210-1978. The pump shaft and bearings sleeves are to be made of stainless steel as per IS 1570(part IV) 1972 or CA 6mm confirming to ASTM A 296 with 12 % chrome steel carbon content upto 0.1% for mixed flow impellers materials should be chrome steel having minimum hardness of 200 BHN , or Aluminum Bronze as per grade AB- II or BS 1400. In case of radial flow impellers material may be aluminum bronze with hardness 140-180 BHN. The casing wear ring (where required and bearing bush shall be made from lead tin bronze grade 4 of IS 318-1981.
- 8.5 The motor starter should be easily rewirable and winding should be easily accessible to facilitate checking and locating of any fault without disturbing the full winding and to replace the default coils. It should be possible to rewind the motor with readymade pre-tested coils.

- 8.6 The stator body should preferably be shrunk fitted instead of being only press fitted. The stator body should be rigidly welded on the stamping assembly and adequate to arrangement of stamping inside the stator body preferably by providing matching grooves in stamping assembly and stator body. Metal rings with rounder fingers should be provided on both ends of stampings. Threaded joints in the motor should be avoided to prevent damage due to rest. Bearing housing should be threaded but located in spigot and by suitable tie bolts. The motor as well as stator should be impregnated under vacuum and the motor should be backed repeatedly under controlled conditions to ensure long life of varnish and give a hard finish to the motor surface. The rotor shaft should be provided with stainless steel sleeves in the bearing portion. The rotor should be made of corrosion resisting material.
- 8.7 The thrust bearing should be water lubricated and of hydro dynamic Mitchell type and should be able to take all untoward loads at most unfavorable running conditions. It should have sieving metallic thrust pads.
- 8.8 The rotating element (as assembled rotors) of pump should be dynamically balanced at high speeds.
- 8.9 The manufacture should have facilities for dynamic balancing at high speed, vacuum impregnated of rotors and stators high tension electrical testing and pump testing. Details in this regard be enclosed with tender.
- 8.10 Performance curves of various pumps offered should be enclosed. The curve should be for duty range showing discharge/head, discharge/efficiency, discharge/BHP and discharge/submergence relations.
- 8.11 The cable shall conform to IS 694 (Part I) 1964 and IS 694 (Pt. II) 1964 specifications for PVC insulated cables (for voltage upto 1100 volts) Pt. I with copper conductors.
- 8.12 The coupling shall be preferably of mesh type rigid sleeves coupling of stainless steel non slip type with matching groove collar and key way arrangement.
- 8.13 The duty point of pumps shall be located near the peak efficiency and there should not be any steep fall in QHH V/s efficiency curve in the head range of 10% and 25%.
- 8.14 Efficiency – The efficiency, motor efficiency and overall efficiency should be clearly mentioned in the offer. Please note that no negative tolerance in overall efficiency will be allowed.
- 8.15 The motor shall conform to IS 9283-1979 and IS 325-1978 (amended up to date) the later as far it can be applied to submersible motors regarding electrical performance. The motor shall not get overloaded throughout the working range of pump even when voltage is as low 358 volts.
- 8.16 Inspection :- A certificate of inspection of submersible pumping set will be produced by contractor along with the bill to Engineer-in-Charge. All the testing and inspection charges will be paid by the contractor himself.
9. Specifications for feeder pillar panels:
- Feeder Pillar Panels suitable for 10.0 H.P. Electric Motors complete with star delta starters and DOL starter upto 5 HP Electric motor and other accessories as detailed below operated on 3 phase 50 cycles A.C. supply 415 volts.
- 1 No. push button operated air Break fully automatic Star Delta Starters in sheet steel enclosure for 10.0 H.P. electric motors conforming to IS: 8544 (amended upto date). Motor Contactor Rating
Main Delta Star
Upto 10.0 H.P. 16 Amps
- 1 No. Miniature Circuit breaker (TPN) confirming to IS: 8828-1978 of adequate capacity, 32 Amp
- 9.3 1 No. 0-500 volts 100mm diameter round projection volt meters class 1.5 with selector switch confirming to IS: 1248 (amended upto date)
- 9.4 1 No. 100mm diameter round projection mounting type ammeter of suitable range class 1.5 with selector switch (details shown below) confirming to IS: 1248 (amended upto date) 0 to 30 amp range
- 9.5 3 Nos. Indicator Lamps RYB indication.
- 9.6 Provision for supply and fixing of power capacitor 4 KVAR ISI mark with the panel, space of requisite standard KWH meter may be provided in the panel with thick bakelite sheet for fixing of KWH meter
- 9.7 3 Nos. 415 volts rewirable type fuses (for 32 Amp)
- 9.8 1 No. Danger plate
- 9.9 1 no. Name plate.
- 9.10 1 No. Single phase preventor based on negative sequence voltage sensing to protect the submersible motor against single phasing should have facility to automatically restart the pump on resumption of power supply with auto/manual selection.

- 9.11 Space for Flow meter display unit.
- 9.12 Space for Pressure Display.
- 9.13 Neutral link.
- 9.14 Connecting strip 60 Amp 9 way

The above accessories and equipment will be mounted in a floor mounting type sheet shall enclosures made out of 16 gauge MS sheet and having locking arrangement and 2 Nos. earthing bolts, The complete panels board should be synthetic enamel painted with two coats after applying basic primer over washed and clean metal surface. The panel board will be fixed/mounted on a angle iron framework made of 35x35x5mm angle iron so that the same could be floor mounted and installed at site. The panel will be fully factory wired and ready for connection to the equipment.

Size of feeder pillar panels exclusive of canopy Height 1200mm, Width 850mm, Depth 400mm.

Size of Canopy: 940 mm W, 400mm D, 100mm H Tapering. Stand size made of angle iron 35x35x5mm H= 360mm. (Drawings of feeder panel enclosed)

The panel shall be mounted on masonry platform with 50mm thick CC 1:2:4 flooring having size 1000mm x 600mm protruding 45cm above the existing road level.

Detailed specification of Individual Items:

9.15 Starters

Push button operated air break starter fully automatic suitable for starting squirrel cage induction motor working on 3 phase 415 Volts (+10% to -15%) 50 c/s A.C. supply each starter shall comprising as per IS:8444 (amended upto date)

Over Current Device:

1 No. Triple pole thermal bimetallic/over current relay accurately calibrated and temperature compensated with differential system for phase failure and unbalanced load protections.

Control Assembly

It shall conform to IS: 2959-1975 and shall comprise of 3 triple pole contractors of specified capacity one for main, one for the star position and one for delta position. Each contractor shall be provide with 1 No. And 1 NC auxiliary unit.

Vacuum impregnated machine wound and backed coil with inter layer paper insulation/epoxy cost suitable for tropical conditions. The coil should be safe from mechanical damage in case of accidental mishandling and should have high resistance to moisture and suitable for operation of 415 (+10% to -15%) volt supply.

Contractors should be of suitable silver alloy to ensure long life and the contact system should be double break and designed to keep bounce to the minimum. Provision for mechanically interlocking the contractors should be available.

The manner of removal of fixed and moving contacts should be easy. The thermal connections preferable should be require disconnection during contact replacement.

The coil should be easily accessible and the coil replacement as well as the contactor assembly should be simple without likely to pull out. Screws should be provided with retaining arrangement.

(C) Timer:

The change over from star to delta position shall be automatic and sharp through thermal/pneumatic/electronic timer (adjustable approximately from 5 to 20 seconds or 2 to 12 seconds)

(D) Start and Stop Push Button:

Shrouded and mounted on the cover.

9.16 Control Switch:

The miniature circuit breaker shall be of adequate rating suitable for operation at 415 V-3 phase, to C/s A.C. supply. The breaker mechanism shall be of quick make break and trip free. The components of the breaker should be designed to last the life of the breaker with no maintenance what so ever including greasing.

The circuit breaker shall have unambiguous mechanical trip indication by means of the position of the knob in addition to ON/OFF.

The circuit breaker shall trip in less than or equal to 25 milli-seconds short circuit conditions.

9.17 Painting

All steel work should undergo a process of de-greasing, pickling in acid and cold rising, passivating and sprayed with a high corrosion resistance primer. The finishing treatment should be application of two coats of synthetic enamel paint.

9.18 Wiring

The panel should be completely factory wired for the connection to the equipment at site, wiring should be made in such a way that it is easily accessible for observations repair work without disturbing other components. Contactor should be PVC insulated conforming to IS 694

The make of various components should be as below

Miniature Circuit breaker : L&T/MDS/Standards/Indo Asian make or any equivalent mark.

Ampere/Voltmeter : IMP /AE/Essmoar equivalent ISI mark

Starter/Contactor/Relay Timer : L&T/Siemens/BCH

Porcelain Rewirable fuse unit : Havells/Standard or any equivalent ISI mark.

Selector Switch : Kaycee/Becon/Salzer

Single Phase preventor : Minilec/or any equivalent ISI mark

Capacitor L&T and equivalent ISI marked

Schedule - B

Complete set of drawing can be obtained from office of Executive Engineer (PHE-I).

Schedule - C (Sample of material)

The contractor shall submit the list of samples of the following items in specified quantities as mentioned against each item before the commencement of work or within 15 days of issue of work order which ever is earlier, to the Engineer – In – Charge for carrying out of test as specified under schedule "D" and shall obtain his approval before issuing any such material at site.

Sample of the following items shall be submitted for each source of supply free of cost by the contractor.

- | | |
|------------------|------------|
| 1. Gravel | 0.25 cu.m. |
| 2. PVC wire mesh | 0.5 Sq.m. |

Sample of earth strata /tube well at interval of 6m or change of strata for each tube well separately in fine and clear bottles.

Water samples in clear bottles for chemical analysis at every 3m interval.

Any other sample that may be required by Engineer- in – Charge from time to time.

Water sample after development in two bottles for each tube well (The Chemical analysis from PHED laboratory shall be submitted to Engineer -in-charge, no payment shall be made by department in this regard)

Schedule - D (Tests to be carried out)

The following test to be carried out by the Executive engineer or any other agency authorized by him to undertake such test.

The Engineer – in – Charge or his authorized representative will carry out as and when considered necessary for the quantity and quality of work done and for the materials used in the work. The contractor, unless otherwise specified shall provide all facilities and arrangements to undertake these tests and all testing charges shall be borne by the contractor.

The contractor shall supply required quantity of samples desired by executive engineer, the samples so obtained shall be sent to authorized laboratory for testing, if the material is not found according to the specifications the entire cost of samples and testing shall be borne by the contractor and the entire lot of supply will also be rejected.

Schedule - E (Site Conditions)

The work is located at different places in JDA region.

The view of the having visited the site, the contractor should sign the certificates as below:

It is certified that I/We.....the tenderer for the above work having visited the site and have and aquanted myself/ourselves with all conditions and accordingly I/we am/are quoting the rates in confirmation of above facts and in stipulation of the other conditions as mentioned in the tender form.

Schedule - F

The complete work defined in the scope of work in the schedule A and detailed itemswise under schedule G appended herewith shall be completed in all respect and to the entire satisfaction of the Engineer – in – Charge and hand over to the JDA or to the person nominated by the JDA to take over within stipulated period from the date of issue of order to the contractor. The date of commencement of the rate contract shall be 10 days after issue of work order. The completion period of each tube well or number of tube well shall be as per clause 12 of Special Terms and Conditions

Schedule - G

Schedule "G" given separately. The contractor is liable to honour of the any adjoining property and any other work for the damage ascertained on account of this work, while in progress.

SCHEDULE –H

The unit rates of items which are not covered under the basic schedule of rates mentioned above by Addl. Chief Engineer and the cost analysis will be done, if needed.

The scope of work for each item of work in schedule–G is as per detailed drawing.

All leads and lifts, centering and strutting are included in the item rates for such work and no extra payment on account of extra lead lifts centering and strutting is admissible. The contractor should invariably account all these items involved in work in his percentage premium rates offered in the tender by him, such claim shall be paid to him.

The quantities of different items and schedules–G are estimated, which may vary as per actual site conditions. The contractor will have to execute the work as per site conditions and will not paid any thing extra on account of non execution one or more items. He is also required to assess the areas of the site of works. The extra work shall not be done by the contractor until and unless the quantity and unit rates for such extra work is agreed between JDA and the contractor and written order to such effect is issued by the competent authority. All extra work shall be paid as per basic schedule of rates on which schedule-G has been prepared.

In case the unit rates or extra works to be carried out is not covered under basic schedule of rates as per specified then the unit rate shall be decided by analysis of prevailing market rate. Such basic items shall be considered for detailed analysis of the extra work and not tender premium shall be paid over and above such rates

SPECIFICATION OF ALL FLANGED CI SPECIALS

The cast iron flanged specials (all flanged tee, flanged tapers, bends, blank flanges, and Puddle collar) shall be according to IS: 1538.

The specials shall be internally and externally coated with hot applied (dip) bituminous paint. All flanged specials shall be used for nominal pressure of 10 kg/cm² (1Mpa).

Flanged specials shall be supplied with the required bolts, nuts and rubber gaskets. The nut & bolts shall be supplied in jute bag; rubber gasket shall be supplied in polyethylene bags.

The length and size of the puddle collars to be fixed at different places of the structures shall be decided by the Engineer in Charge. Pipe make shall be got approved from Executive Engineer, District Division I Jaipur before using it on site

MS PIPES & SPECIALS

MS PIPELINE

1.1.1. SPECIFICATIONS

This part of the specification covers manufacturing, supply, delivery, lowering, laying, jointing, internal lining, outer coating, testing and commissioning of mild steel pipes. Manufacturing of MS pipes shall be done in conformity with IS: 3589. The MS pipes shall be fabricated out of steel plates or strips of fresh mild steel coils, spirally welded / longitudinal welded, having butt-welded joints with beveled ends, as per IS 3589.

The minimum thicknesses of MS pipes to be provided in this project are 6mm. "The outer surface shall be coated with high built epoxy paint to RDSO specification no. M&C/PCN/III/88 to give a dry film thickness of 250 microns".

MS SPECIALS

The MS specials, wherever required, shall be made out of MS pipes not less than 6mm thick and shall be internally and externally coated with anti corrosive paint with red oxide as primer coat.

MS LEAK REPAIR CLAMPS

The MS Leakage Clamps used during testing or maintenance shall be made out of 5mm thick MS strip and of appropriate width. The civil work which are required to done in this contract shall be confirming to PWD manual and to the satisfaction of Engineer in Charge.

SPECIFICATIONS OF SUBMERSIBLE PUMP SETS

(AS PER IS 8034) (AMENDED UP TO DATE)

1.0 SCOPE

This includes supply of ISI marked submersible Pumping Sets as per IS 8034 comprising of Submersible Motor of sufficient horse-power coupled to a Pump of duty conditions as specified in scope of work and G schedule as per detailed specifications given below. The Motor shall have cable leads of minimum 15 meters length externally.

2.0 DESCRIPTION

- 2.1 The Submersible Pumping Sets shall be ISI marked as per IS 8034 (specification for Submersible Pumping Sets for clear, cold fresh water) (amended or revised up to date) and should be as per provisions/ specifications mentioned hereunder.
- 2.2 The electric motor is to operate through 3 phase 50 c/s A.C. Supply of 415 volts + 6% & -15% volts i.e. between 352 to 440 Volts. The preferred speed shall correspond to 2 pole motors [3000 rpm (synchronous)]
- 2.3 The Pump sets shall normally be installed in bore wells and should be suitable for conditions existing for ground waters generally available in Rajasthan. The water to be handled by the Pump sets may have Total dissolved Solids 3000 PPM (max), Turbidity 50 PPM (silica scale) Chlorides 1000 PPM (max) and PH value between 6.5 to 8.5.

3.0 DETAILS OF PUMPS

- 3.1 The material of construction of various components of the pump shall be as under:

S.No.	ITEM	MATERIAL OF CONSTRUCTION
1	Discharge casing (if provided)	Cast Iron Grade FG 200 of IS: 210-1993
2	Suction casing	Cast Iron Grade FG 200 of IS: 210-1993
3	Pump bowl	Cast Iron Grade FG 200 of IS: 210-1993
4	Diffuser	Cast Iron Grade FG 200 of IS: 210-1993 or glass filled Polyphenylene oxide (modified PPO) or glass filled Polycarbonate of IS 8034
5	Pump shaft	Stainless steel grade X 04 Cr12, X 12 Cr12 or X 20Cr13 of IS: 6603
6	Impeller for radial flow/ mixed flow	Bronze grade LTB 2 of IS: 318 or Stainless steel grade X 12 Cr12 of IS 6911 or IS 6603 or glass filled Polyphenylene oxide (modified PPO) or glass filled Polycarbonate of IS 8034
7	Casing wear ring (if provided)	Bronze Grade LTB 4 of IS:318
8	Bearing bush in discharge & suction	Bronze Grade LTB 4 of IS:318

- 3.2 The thickness of impeller vanes shall be not less than 1.5mm at tips and 3mm at the base.
- 3.3 The rotating element (as assembled rotors) of Pumps should be dynamically balanced at high speed. Each metallic impeller shall be dynamically balanced to grade G 6.3 of IS-11723 (part-I) for ensuring smooth performance free of vibrations.

The maximum outside diameter of the pump set corresponding to nominal diameter of the tube well shall be as given below:

3.4	Nominal Diameter of the Tubewell	3.5	Maximum Outside Diameter of
		3.6	Submersible Pump sets
3.7	150 mm	3.8	142 mm
3.9	200 mm	3.10	192 mm

- 3.5 The coupling shall be preferably of mesh type rigid sleeves coupling of stainless steel non-slip type with matching groove, collar and key way arrangement.
- 3.6 The pump shall be tested for operating head range of not less than +10 percent and -25 percent of the user's specified duty head (i.e. head as specified in enclosed Annexure-I). The duty point of pumps shall be located near the peak efficiency and there should not be steep fall in Q V/S H, efficiency curve in the head range of +10% and -25%. This entire range should be on the stable portion of the curve

4.0 DETAILS OF MOTOR

- 4.1 The motor shall conform to IS: 9283-1995 (amended up to date). The motor shall be of continuous duty (type S1) specified in IS 12824: 1989.
- 4.2 The Motor stator should be easily rewire-able and winding should be easily accessible to facilitate checking and locating of any fault without disturbing the full winding and to replace defective coils. It should be possible to rewind the motor with readymade pre tested coils.
- 4.3 The stator body should preferably be shrunk fitted instead of being only press fitted. The stator body should be tightly welded on the stamping assembly and adequate arrangement should be provided for stopping of rotation or shifting of stampings inside the stator body preferably by providing matching grooves in the stamping assembly and the stator body. Metal rings with rounded fingers should be provided on both ends of stamping.
- 4.4 Threaded joints in the motor should be avoided to prevent damage due to rusting. Bearing housing should not be threaded but located on spigot and held by suitable bolts.
- 4.5 The rotor as well as stator should be impregnated under vacuum or air drying and both should be baked repeatedly under controlled conditions to ensure long life of varnish/ galvanising/ chrome plating/epoxy and to give a hard finish to the motor surface. The rotor should be dynamically balanced at high speed.
- 4.6 All the material and components for the motors shall be suitable for application in respect of corrosion resistance and mechanical performance continuously under water. The typical materials to be used for various parts of motor are given below: -

S.No.	ITEM	MATERIAL OF CONSTRUCTION
4.7	4.8 Bearing housing	4.9 Grey cast iron Gr. FG-200 of IS 210:1993
4.10	4.11 Motor shaft	4.12 Chromium steel Gr. 04 Cr 13, or 12 Cr 13, or 20 Cr
4.14	4.15 Bearing bush	4.16 Leaded tin bronze LTB 3, LTB 4 or LTB 5 of IS 4.17 318:1981 or Resin bonded carbon metal or
4.18	4.19 Rotor laminations	4.20 Electrical sheet of IS 648:1994
4.21	4.22 Rotor conductor	4.23 Electro grade copper of IS 613:1984
4.24	4.25 Stator laminations	4.26 Electrical sheet steel of IS 648:1994
4.27	4.28 Stator winding wire	4.30 Electro grade copper of IS 613:1984
4.31	4.32 Stator winding wire insulation	4.33 PVC or with polymer of IS 8783:1978
4.34	4.35 Breather	4.36 Nitrile rubber
4.37	4.38 Thrust bearing	4.39 Vulcanized fibre v/s chromium steel or vulcanized
4.41	4.42 Cable gland	4.43 Nitrile rubber
4.44	4.45 Stator Casing	4.46 Grey Cast iron FG 200 of IS 210:1993 or Carbon 4.47 steel (sheet or pipe) or stainless steel sheet

4.48 The materials indicated are typical. Manufacturers may use materials of properties superior as per the properties of materials indicated in manufacturing submersible motor.

4.49 The thrust bearing should be water lubricated and of hydrodynamic Mitchell type and should be able to take all untoward loads at most unfavorable running conditions. It should have swiveling metallic thrust pads.

4.50

4.51 The output motor ratings shall be as per Clause 6.3 of IS 9283:1995 (amended upto date). The motor rating beyond 15 kW shall be as declared by the manufacturer. The motor shall be capable of delivering rated output with variations in value of voltage and frequency for Category B as per clause 6.2.2 of IS 9283:1995.

4.52

4.53 The motor shall be suitable for entire working range of pump from +10% to -25% of the user's specified duty head (i.e. head as specified in enclosed Annexure-I). The motor shall not get overloaded in the entire working range. The criteria for checking non-overloading shall be that maximum current in entire range shall not exceed the limits specified in Table 1 (clause 7.1) of IS 8034: 2002 for various ratings between 1.1 kW to 15 kW. In case of motor rating more than 15 kW the manufactures has to declare maximum current, which the motor can take. The permissible limit of maximum current in the operating head range for checking non-overload requirements is 1.07 times of Maximum current declared by the manufacturer.

5.0 SUBMERSIBLE CABLE

5.1 The cable shall be ISI marked as per IS 694:1990. It shall be PVC insulated and PVC sheathed, flexible, 3 core flat type having copper conductors suitable for working voltage up to and including 1100 Volts. Size of Cable shall be as under:

S.No.	Motor KW Rating (in KW)	Cable Size 3 core flat with copper conductor of flexible type	Type of Starting
1	Less than 3.7 KW	1. 1x1.5 Sq mm	Direct on line
2	3.7 KW	1x2.5 Sq mm	-do-
3	From 4.5KW to 5.5 KW	2x1.5 Sq mm	Star Delta
4	Above 5.5KW to 9.3 KW	2x2.5 Sq mm	-do-
5	Above 9.3KW to 11.0 KW	2x4.0 Sq mm	-do-
6	Above 11 KW to 16 KW	2x6.0 Sq mm	-do-
7	Above 16 KW to 22 KW	2x10 Sq mm	-do-
8	Above 22 KW and Less than 30 KW	1x16 Sq mm	ATS
9	From 30 KW and Less than 38.5 KW	1x25 Sq mm	-do-
10	From 38.5 KW and less than 48.5 KW	1x35 Sq mm	-do-
11	From 48.5 KW and above	1x50 Sq mm or size as per requirement.	-do-

- 5.3 In place of cable sizes 1x25 Sq mm & 1x35 Sq mm cable of 2x16 Sq mm can be provided as an alternative. Similarly in place of 1x50 sq mm, the cable of 2x25 Sq mm can be provided as an alternative. These two leads of lower sizes shall be provided in parallel and cores suitably connected to make the core leads with respect to ATS method of starting.

6.0 TESTING & INSPECTION

- 6.1 Testing of the pump sets shall be carried out as per relevant IS codes. The inspecting agency shall test & inspect the pump set as per enclosed Appendix"D". The tenderer should have all required facilities and shall get pumpsets tested & inspected in accordance with enclosed Appendix"D".
- 6.2 The manufacturer should have facilities for dynamic balancing at high speed, vacuum impregnation/air drying of rotors and stator, high tension electrical testing and pump performance testing. Details in this regard should be shown to the inspecting agency.
- 6.3 At the time of supply, the firm must submit with its invoice detailed test report on a finished pump set offered and reports of various tests conducted during manufacture.
- 7.0 MARKING: The marking shall be as per relevant IS code. The pump set shall invariably be marked with BIS standard mark. Purchasers mark 'PHED RAJ.' & 'Years of Supply' shall also be mentioned on each pump & motor.

NOTE: Wherever reference of IS number is given it may be treated as amended/ revised up to date at the time of inspection of supply/ replacement by inspection agency. Any amendment/ revision shall be effective only when it is implemented by BIS.

SPECIFICATIONS OF PVC SUBMERSIBLE CABLE

1.5Sq mm to 50Sqmm (IS 694-1990) (Amended up to date)

1. SCOPE

- 1.1 These specification cover the supply of ISI marked three core flexible flat PVC insulated and PVC Sheathed cable conforming to IS 694:1990 (amended up to date) to be used with the submersible pumping sets inside and outside water for working voltage up to and including 1100 volts. These cables are to be used as cables suitable for outdoor use having bunched plain high conductivity copper conductor conforming to IS: 8130-1984 (amended up to date) and insulated and sheathed with PVC compound conforming to IS: 5831-1984 (amended up to date).

2. MATERIAL OF CONSTRUCTION

2.1 COPPER CONDUCTOR

- 2.2 The bunched conductor shall be composed of plain annealed high conductivity copper wires complying with Class 5 of Copper Conductor as per IS 8130-1984 (amended up to date). The nominal max. diameter of wires and corresponding minimum number of wires in a strand and maximum allowable resistance shall be as follows:

S.No.	Size of cable in sq. mm	Maximum dia. & corresponding wires in a Core		Max. resistance of conductors at 20o centigrade (ohms/Km.)
		Maximum dia. in Mm	Minimum No. of wires in core	
1	1.5	0.26	29	13.30
2	2.5	0.26	47	7.98
3	4.0	0.31	53	4.95
4	6.0	0.31	80	3.30
5	10.0	0.41	76	1.91
6	16.0	0.41	122	1.21

7	25.0	0.41	190	0.78
8	35.0	0.41	266	0.554
9	50.0	0.41	379	0.386

NOTE: THE CROSS SECTIONAL AREA OF EVERY CORE SHOULD BE SAME AS PER PRESCRIBED SIZE OF CABLE (WHEN CALCULATED ON THE BASIS OF DIA OF EACH WIRE & NUMBER OF WIRES IN A CORE).

2.3 INSULATION & SHEATH

The insulation shall be of PVC compound conforming to the requirement type 'A' of IS 5831:1984 (Specification for PVC insulation and sheath of electric cable) (amended up to date). The sheath shall be of PVC compound conforming to the requirement of type ST-I of IS: 5831-1984 (amended up to date). Cores shall be identified by different coloring of PVC insulation. Colour of cores shall be identified by Red, Yellow and Blue and the colour of sheath shall be Black only.

Three cores shall be laid side by side. Average thickness of insulation shall not be less than the nominal value (ti) mentioned below and the smallest of measured values of thickness of insulation shall not fall below the nominal value ti mentioned below by more than (0.1 mm + 0.1 ti).

The sheath where applicable, shall be applied by extrusion. It shall be applied over the laid up cores. It shall be so applied that it fits closely on the laid up cores and it shall be possible to remove it without damage to the insulation. The thickness of sheath determined by taking the average of a number of measurements, shall not be less than the nominal value (ts) specified below, and smallest of the measured values shall not fall below the nominal value(ts) specified below by more than 0.2mm + 0.2 ts.

S.No.	Size of cable (mm2)	Nominal thickness of insulation (mm) (ti)	Nominal thickness of sheath ts (mm)
1	1.5	0.6	0.9
2	2.5	0.7	1.0
3	4.0	0.8	1.1
4	6.0	0.8	1.1
5	10.0	1.0	1.2
6	16.0	1.0	1.3
7	25.0	1.2	1.5
8	35.0	1.2	1.6
9	50.0	1.4	1.7

3. TESTING

3.1 ACCEPTANCE TESTS

The following tests shall constitute acceptance tests:

S.No.	Test	Test method as per
(A)	Annealing Test (for copper)	Part No.1 of IS:10810
(B)	Conductor Resistance Test	Part No.5 of IS:10810
(C)	Test for thickness of insulation and sheath.	Part No. 6 of IS:10810
(D)	Tensile strength and elongation at break of insulation and sheath.	Part No. 7 of IS:10810
(E)	Insulation resistance test	Part No. 43 of IS:10810
(F)	High Voltage Test	Clause 16.3 of IS: 694 The cable shall withstand without breakdown an ac voltage of 3 kV (rms) or a dc voltage of 7.2 kV applied for a period of 5 minutes for each test connection.

(G)	Flammability test	Clause 16.5 of IS: 694 & Part No. 53 of IS: 10810 (The period of burning after removal of flame shall not exceed 60 seconds and the unaffected (uncharged) portion from the lower edge of the top clamp shall be at least 50mm).
-----	-------------------	---

3.2 ROUTINE TESTS

The following shall constitute routine tests;

- a) Conductor resistance test, and
- b) High voltage test.

4. TYPE TEST

The following tests shall constitute type tests:

S.No.	Type Test	For Requirements, Ref	Test Method
a)	Tests on		
	i) Annealing Test (for	IS 8130: 1984	As per Part 1 of IS: 10810
	ii) Resistance	IS 8130: 1984	As per Part 5 of IS: 10810
b)	Test for overall dimensions and thickness of	10, 13, 14 Table 1 to 5 of IS 8130: 1984	As per Part 6 of IS: 10810
c)	Physical test		
	i) Tensile strength and	IS 5831: 1984	As per Part 7 of IS: 10810
	ii) Loss of mass	IS 5831: 1984	As per Part No.10 of IS:10810
	iii) Ageing in air	IS 5831: 1984	As per Part No.11 of IS:10810
	iv) Shrinkage test	IS 5831: 1984	As per Part No.12 of IS:10810
	v) Heat Shock	IS 5831: 1984	As per Part No.14 of IS:10810
	vi) Hot	IS 5831: 1984	As per Part No.15 of IS:10810
d)	Insulation	IS 5831: 1984	As per Part No.43 of IS:10810
e)	High voltage test (Water immersion test)	16.2 of IS 694	As per Part No.45 of IS:10810 i) ac test The core(s) shall be carefully removed from a sample approximately 3 M long from the finished cable. They shall be so immersed in a water bath at 60 ± 3 degree C that their ends protrude at least 200mm above the water level. After 24 hours, a voltage of 3 kV (rms) shall be applied between conductors and water. This voltage shall be raised to 6 kV (rms) within 10 seconds and held constant at this value for 5 minutes. If the sample fails in this test, one more sample shall be subjected to this test, which should pass. ii) dc test
S.No.	Type Test	For Requirements, Ref	Test Method

			The cores which have passed the preliminary test mentioned above shall be subsequently tested with a dc voltage of 1.2 kV in the same water bath at the same temperature. The conductors shall be connected to the negative pole and water to the positive pole of dc supply by means of a copper electrode. The core shall withstand this dc voltage test for 240 hours without breakdown. The voltage shall be applied continuously, but if there are any unavoidable interruptions during the 4 hours period, that period shall be increased by the time of interruptions. The total of such interruptions shall not exceed 1 hour otherwise the test shall be started again.
f)	Flammability test	16.5 of IS 694	As per Part 53 of IS: 10810
g)	Cold bendtest diameter <= 12.5mm	IS 5831:1984	As per Part No.20 of IS:10810
h)	Cold impact test for diameter more than 12.5mm	IS 5831:1984	As per Part No.21 of IS:10810
i)	Additional ageing test	16.6 of IS 694	Ageing of Sample A sample, 6 mtrs. long of the finished cable shall be suspended in a heating chamber and exposed to a temperature of 80 ± 2 degree C during a period of 168 hours. Immediately after this, the sample shall be placed in a bath of boiling water for a period of 8 hours and in a water bath at 25 ± 0.5 C for 16 hours. This procedure shall be repeated on 5 successive days. The ends of the sample shall protrude at least 200mm above the water level.

5. The inspection including stage inspection and testing of the material shall be got done by the inspecting agency at the works of manufacturer. All acceptance test mentioned above shall be conducted by inspecting agency.

5. SAMPLING OF CABLES:

A) LOT

In any consignment the cables of the same size and type manufactured under essentially similar conditions of production shall be grouped together to constitute a lot.

B) SCALE OF SAMPLING

Samples shall be taken and tested from each lot for ascertaining the conformity of the lot to the requirements of the specification. The number of samples to be selected shall depend on column 2 & 3 of following table. These samples shall be taken at random:

S.No.	Number of drums in lot	Number of drums to be taken as sample	Permissible number of defectives
1	2	3	4
1	Upto 25	3	0
2	26 to 50	5	0
3	51 to 100	8	0
4	101 to 300	13	1
5	301 & above	20	1

- c) In order to ensure the randomness of selection, procedure given in IS 4905:1968 may be followed.

D) NUMBER OF TESTS AND CRITERION FOR CONFORMITY:

From each of the drum selected according to column 2 & 3 of above table, suitable lengths of test samples shall be taken.

These tests samples shall be subjected to each of the acceptance tests. A test sample is called defective if it fails in any one of the acceptance tests. If the number of defectives is less than or equal to the corresponding permissible number given in column 4 of above table, the lot shall be declared as confirming to the requirements of the acceptance tests; otherwise not.

6. PACKING AND MARKING

- 6.1 The cable shall be supplied in non-returnable wooden drums with adequate barrel diameter and shall be packed in such a manner that it shall be protected from injury and damages during transit. Not more than one length shall be wounded on one drum.
- 6.2 The cable shall carry following information stenciled on the drum and contained in label attached to it:
- a) Reference to IS 94
 - b) Manufacturer's Name, Brand Name of trade mark.
 - c) Type of Cable and Voltage grade.
 - d) Number of Cores.
 - e) Nominal core sectional area of conductor.
 - f) Length of Cable.
 - g) Cable code (yy)
 - h) Direction of rotation of drum (By means of arrow)
 - i) Years of Manufacture.
 - j) Approximate gross weight.
 - k) No. of wire in a core

Schedule - I

No material shall be supplied by JDA

Specification of G.I. Pipes

1. Scope:

This includes manufacture & Supply of galvanized mild steel Tubes Sockets (Medium Class) to be used for Water wells and other miscellaneous purposes conforming to IS: 1329-1990 (amended up to date) in nominal bore of pipes of 32mm. The pipes should be ISI marked.

2. Material:

General requirements relating to supply of Mild steel Tubes shall confirm to IS: 1387-1967. The welded tubes shall be manufactured from hot rolled steel skeip/strip confirming to Grade-I ass per IS: 10748-1984 (amended up to date).

The tube shall be Electric Resistance welded (ERW). The height of the internal weld fin shall not be greater than 60% of the specified thickness.

The chemical analysis of steel tubes shall be carried out only for sulphur & phosphorous requirement. The Sulphur & phosphorus requirements shall not exceed 0.05 percent each with maximum permissible variation of 0.005 percent each. The analysis shall be carried out as per IS: 228.

The sockets shall be electric resistance welded and should meet the requirement of IS: 1239 (Part-2) 1992 (amended up to date). However socket for 32mm pipe shall be manufactured from seamless pipe & it shall be not dipped galvanized.

3. Dimension and Masses:

Dimensions and masses of steel Tubes shall be as follows:

Nominal Bore (mm)	Out side Diameter		Thickness (mm)	Mass of screwed & socketed type kg/m	Minimum out side diameter of socket (mm)	Minimum length of socket (mm)
	Maximum (mm)	Minimum (mm)				
32	42.9	42.0	3.2	3.13	49.0	51.0
50	60.8	59.7	3.6	5.10	68.0	60.0

4. Length of Pipe:

The G.I. pipes of 32mm/50mm nominal bore with socket (as per clause 3.4 above) shall be supplied in 3 M. length.

The length of tube shall be measured as inclusive of socket on one end with handling tight. Handling tight means that the socket is so tight fitted that it should not fall down during handling on transit.

5. galvanising:

The Zinc coating on the tube shall be in accordance with IS: 4736-1986. The tubes shall be galvanized before screwing .

6. Tolerance on Thickness mass & length:

The tolerance shall be permitted as per clause 9 and 11 of IS: 1239 (Part-II) 1990. However tolerance in length of 32mm pipe shall + 0-mm-25-mm.

7. Finish:

All pipes shall be clearly finished and reasonably free from injurious defects. The ends shall be cleanly cut and reasonably square. The tubes shall be reasonably straight.

1. Protection And Packing:

The protection and packing shall be done as per provision of relevant IS:

2. Inspection

All material shall be inspected by the concerned Executive Engineer. Material shall be supplied in Divisional Store for checking and then issued for execution.

Note: Wherever there is reference of Indian Standard it shall be considered amended up to date at the time of inspection of Supply/replacement by inspecting agency. Any amendment shall be effective only when it is implemented by B.I.S. All the material shall be ISI marked.

All dimensions shall be referred from updated relevant IS Code.

SPECIAL CONDITIONS OF THE CONTRACT

1. Contractor shall get the D.I./HDPE pipe inspected from the third party (CEIL, SGS, RITES) before bringing the material at site. The inspection charges shall be born by the contractor. No payment of these items shall be made before the third party inspection.
2. In case of pipe line testing shall be done as per the relevant Code and the leakage level shall not be more than as per IS 8329 then 100% payment shall be released after commissioning & testing.
3. The quantity of work can be increased or decreased. However, no guarantee is given about the actual quantity of work.
4. No extra payment shall be made to the contractor on account of excavation in collapsible strata or in hard or rocky strata. The tenderers shall have to make their own arrangement for completing the work and no claim in this respect will entertained.
5. On collection of complete material for each section the same shall be got checked by Engineer-in-Charge or his authorized representative. Such approval shall in no way release the contractor of his responsibility regarding completion of work, as per required specification until the contract is complete.
6. The electric connection, if required, for construction and testing purpose shall be arranged by the contractor at his own cost.
7. The contractor shall make his own arrangement regarding water required for the execution and testing of the work and shall also arrange for the supply of drinking water to his own employees. He shall defray all charges in this connection and should include in his rates a sufficient amount to cover such charges. All such facilities as are required now to be provided for the labour, made under labour welfare rules enforce, shall also be provided by the contractor at his own cost.
8. The contractor will be required to see that the usual hours of work are adhered too. No work shall be done after the sun set without the permission of the engineer-in-charge.
9. The contractor/firm or company while executing the work will adopt all safety measures at his cost to safeguard from any loss of life and damage of public and private property. If any loss and damage is occurred, they will pay the full compensation from their own pocket to the concern. All the consequence (legal and or financial) will be born by the contractor only and JDA will not be responsible in any way.
10. Water for construction / testing purpose shall have to arranged by contractor at his own cost. If water is supplied by the department, the same shall be recovered from the contractor from each running bill at the rate of 1% of total value of pipe line laying work, In case of metered connection the charges shall be recovered on the actual consumption basis on the commercial rates.
11. The contractor shall be fully responsible for structural safety and water tightness of pipeline when tested.
12. No secured advance against material procured at site will be allowed.
13. Pipeline laying should be done in the presence an Engineer not below the rank of Junior Engineer of the JDA, and trench shall be refilled after checking of Assistant engineer. After taking layout, the contractor shall submit day to day schedule of work to the Engineer-in-charge in advance.
14. The contractor/firm or company will take utmost care to safeguard the water mains, Electric and Telephone cable existing surface drains water connections etc., while executing the work. Any damages/rectification shall be born by the contractor only
15. The contractor shall, at his own cost, arrange to provide, erect and maintain necessary display boards/ flags/banners etc. at selection points of project site giving such information as considered necessary for public awareness/ information/ safety as directed by the Engineer-in-charge.
16. Contractor shall provide sufficient number of boards at site of work indicating "JDA AT WORK" at his own cost as required by Engineer-in-charge.
17. The surplus earth and damaged materials will be immediately removed from the site of work and dumped as per instruction of Engineer-in-charge.
18. The material collected at site and paid provisionally shall remain under the watch and ward of the contractor till it is consumed fully on the work.
19. Any material not conforming to the specifications collected at site shall have to be removed by the contractor within a period of 3 days of the instructions, issued by the Engineer-in-charge, failing which, such material shall be removed by the Engineer-in-charge at risk and the contractor after expiry of 3 days period.
20. The contractor/firm/company is bound to get the workmen insured against accident from the Insurance Company at his own cost.
21. Contractor shall be the sole custodian of the men and material at work and will be fully responsible for any loss of life or otherwise occurred during the execution of the works.
22. The Engineer – in – Charge or his authorized representative will carry out as and when considered necessary for the quantity and quality of work done and for the materials used in the work. The contractor, unless otherwise specified shall provide all facilities and arrangements to undertake these tests and all testing charges shall be borne by the contractor.
23. The contractor shall supply required quantity of samples desired by executive engineer, the samples so obtained shall be sent to authorized laboratory for testing, if the material is not found according to the specifications the entire lot of supply will also be rejected. The entire cost of samples and testing shall be borne by the contractor.

24. Defects Liability period

The defect liability period shall be as per JDA office order no. JDA/Ex.En. (TA to Dir. Eng.-1)/2016/D-29 dated 11.03.16 (Annexure 'E').

25. As Built Drawings.

The submission of the As-built drawings of the water line work is the precondition for the final payment. The final drawings shall be submitted in one reproducible set and 3 copies on linen bound in an album of an approved size. The contractor shall submit all the completion drawings. The scale of drawing and the size of drawing shall be as per the direction of the Engineer in Charge.

26. The contractor shall be solely responsible for all kind of liaison before starting the work with PHED/Other JDA zone/JVVNL & BSNL etc. which is required to avoid any damage of already laid pipe lines, Electric, BSNL cables. The contractor shall also liaison for the inter connection work with existing PHED system.

27. Before start of work contractor has to inform concerned JDA zone officers to avoid/minimize road damage

28. If there is any typographical error or otherwise in the 'G' Schedule. The nomenclature and the rates as given in the relevant BSR and JDA approved items/rates on which schedule 'G' is based, shall prevail.

The above conditions may be read very carefully and adhered strictly.

I/we confirm above

Signature of contractor

**Executive Engineer (PHE-I)
JDA, Jaipur**

Section A-5

Annexure

Annexure A :**Compliance with the code of Integrity and No Conflict of Interest**

Any person participating in a procurement process shall –

- (a) Not offer any bribe, reward or gift or any material benefit either directly or indirectly in exchange for an unfair advantage in procurement process or to otherwise influence the procurement process;
- (b) Not misrepresent or omit the misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- (c) Not indulge in any collusion, Bid rigging or anti-competitive behavior to impair the transparency, fairness and progress of the procurement process;
- (d) Not misuse any information shared between the procuring Entity and the Bidders with an intent to gain unfair advantage in the procurement process;
- (e) Not indulge in any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- (f) Not obstruct any investigation or audit of a procurement process;
- (g) Disclose conflict of interest, if any; and
- (h) Disclose any previous transgressions with any Entity in India or any other country during the last three years or any debarment by any other procuring entity.

Conflict of Interest :-

The Bidder participating in a bidding process must not have a Conflict of interest.

A conflict of interest is considered to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations.

i. A Bidder may be considered to be in Conflict of Interest with one or more parties in a bidding process if, including but not limited to:

- a. Have controlling partners/shareholders in common ; or
- b. Receive or have received any direct or indirect subsidy from any of them; or
- c. Have the same legal representative for purposes of the Bid; or
- d. Have a relationship with each other; directly or through common third parties, that puts them in a position to have access to information about or influence on the Bid of another Bidder, or influence the decisions of the Procuring Entity regarding the bidding process; or
- e. The Bidder participates in more than one Bid in a bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all Bids in which the Bidder is involved. However, this does not limit the inclusion of the same subcontractor, not otherwise participating as a Bidder, in more than one Bid; or
- f. The Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the Goods, Works or Services that are the subject of the Bid; or
- g. Bidder or any of its affiliates has been hired (or is proposed to be hired) by the Procuring Entity as engineer-in-charge/ consultant for the contract.

Annexure B :**Declaration by the Bidder regarding Qualifications****Declaration by the Bidder**

In relation to my/our Bid submitted to for procurement of in response to their Notice inviting Bids No.Dated
I/We hereby declare under Section 7 of Rajasthan Transparency in Public Procurement Act, 2012, that :

1. I/We possess the necessary professional, technical, financial and managerial resources and competence required by the Bidding Document issued by the Procuring Entity;
2. I/We have fulfilled my/our obligation to pay such of the taxes payable to the Union and the State Government or any local authority as specified in the Bidding Document;
3. I/We are not insolvent, in receivership, bankrupt or being wound up, not have my/our affairs administered by a court or a judicial officer, not have my/our business activities suspended and not the subject of legal proceeding for any of the foregoing reasons;
4. I/We do not have, and our directors and officers not have, been convicted of any criminal offence related to my/our professional conduct or the making of false statements or misrepresentations as to my/our qualifications to enter into a procurement Contract within a period of three years preceding the commencement of this procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
5. I/We do not have a conflict of interest as specified in the Act, Rules and the Bidding Document, which materially affects fair competition;

Date :
Place :

Signature of bidder

Name :
Designation :
Address :

Annexure C :**Grievance Redressal during Procurement Process**

The designation and address of the **First Appellate Authority is Commissioner, JDA Jaipur.**

The designation and address of the **Second Appellate Authority is Executive Committee (E.C.), JDA Jaipur.**

(1) Filing an appeal

If any Bidder or prospective bidder is aggrieved that any decision, action or omission of the Procuring Entity is in contravention to the provisions of the Act or the Rules or the Guidelines issued there under, he may file an appeal to First Appellate Authority, as specified in the Bidding Document within a period of ten days from the date of such decision or action, omission, as the case may be, clearly giving the specific ground or grounds on which he feels aggrieved:

Provided that after the declaration of a Bidder as successful the appeal may be filed only by a Bidder who has participated in procurement proceedings:

Provided further that in case a Procuring Entity evaluates the Technical Bids before the opening of the Financial Bids, an appeal related to the matter of Financial Bids may be filed only by a Bidder whose Technical Bid is found to be acceptable.

(2) The officer to whom an appeal is filed under para (1) shall deal with the appeal as expeditiously as possible and shall Endeavour to dispose it of within thirty days from the date of the appeal.

(3) If the officer designated under para (1) fails to dispose of the appeal filed within the period specified in para (2), or if the Bidder or prospective bidder or the Procuring Entity is aggrieved by the order passed by the First Appellate Authority, the Bidder or prospective bidder or the Procuring Entity, as the case may be, may file a second appeal to Second Appellate Authority specified in the Bidding Document in this behalf within fifteen days from the expiry of the period specified in para (2) or of the date of receipt of the order passed by the First Appellate Authority, as the case may be.

(4) Appeal not to lie in certain cases

No appeal shall lie against any decision of the Procuring Entity relating to the following matters, namely:-

- (a) Determination of need of procurement;
- (b) Provisions limiting participation of Bidders in the Bid process;
- (c) The decision of whether or not to enter into negotiations;
- (d) Cancellation of a procurement process;
- (e) Applicability of the provisions of confidentiality.

(5) Form of Appeal

- (a) An appeal under para (1) or (3) above shall be in the annexed form along with as many copies as there are respondents in the appeal.
- (b) Every appeal shall be accompanied by an order appealed against, if any, affidavit verifying the facts stated in the appeal and proof of payment of fee.
- (c) Every appeal may be presented to First Appellate Authority or Second Appellate Authority, as the case may be, in person or through registered post or authorized representative.

(6) Fee for filing appeal

- (a) Fee for first appeal shall be rupees two thousand five hundred and for second appeal shall be rupees ten thousand, which shall be non-refundable.
- (b) The fee shall be paid in the form of bank demand draft or banker's cheque of a Scheduled Bank in India payable in the name of Appellate Authority concerned.

(7) Procedure for disposal of appeal

- (a) The First Appellate Authority or Second Appellate Authority, as the case may be, upon filing of appeal, shall issue notice accompanied by copy of appeal, affidavit and documents, if any, to the respondents and fix date of hearing.
- (b) On the date fixed for hearing, the First Appellate Authority or Second Appellate Authority, as the case may be, shall,-
 - (i) Hear all the parties to appeal present before him; and
 - (ii) Peruse or inspect documents, relevant records or copies thereof relating to the matter.
- (c) After hearing the parties, perusal or inspection of documents and relevant records or copies thereof relating to the matter, the Appellate Authority concerned shall pass an order in writing and provide the copy of order to the parties to appeal free of cost.
- (d) The order passed under sub-clause (c) above shall also be placed on the State Public Procurement Portal.

FORM No. 1

[See Rule 83]

**Memorandum of Appeal under the Rajasthan
Transparency in Public Procurement Act, 2012**

Appeal No. of Before the
..... (First/Second Appellate Authority)

1. Particulars of appellant :

(i) Name of the appellant :

(ii) Official address, if any :

(iii) Residential address :

2. Name and address of the respondent (s) :

(i)

(ii)

(iii)

3. Number and date of the order appealed against and name and designation of the officer/authority who passed the order (enclose copy), or a statement of a decision, action or omission of the Procuring Entity in contravention to the provisions of the Act by which the appellant is aggrieved:

4. If the Appellant proposes to be represented by a representative, the name and postal address of the representative:

5. Number of affidavits and documents enclosed with the appeal :

6. Grounds of appeal :

(Supported by an affidavit)

7. Prayer :

Place

Date

Appellant's Signature

Annexure D :**Additional Conditions of Contract****1. Correction of arithmetical errors**

Provided that a Financial Bid is substantially responsive, the Procuring Entity will correct arithmetical errors during evaluation of Financial Bids on the following basis:

- i. If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected, unless in the opinion of the Procuring Entity there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price shall be corrected;
- ii. If there is an error in a total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected ; and
- iii. If there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (i) and (ii) above.

If the Bidder that submitted the lowest evaluated Bid does not accept the correction of errors, its Bid shall be disqualified and its Bid Security shall be forfeited or its Bid Securing Declaration shall be executed.

2. Procuring Entity's Right to Vary Quantities

- (i) At the time of award of contract, the quantity of Goods, works or services originally specified in the Bidding Document may be increased or decreased by a specified percentage, but such increase or decrease shall not exceed twenty percent, of the quantity specified in the Bidding Document. It shall be without any change in the unit prices or other terms and conditions of the Bid and the conditions of contract.
- (ii) If the Procuring Entity does not procure any subject matter of procurement or procures less than the quantity specified in the Bidding Document due to change in circumstances, the Bidder shall not be entitled for any claim or compensation except otherwise provided in the Conditions of Contract.
- (iii) In case of procurement of Goods or services, additional quantity may be procured by placing a repeat order on the rates and conditions of the original order. However, the additional quantity shall not be more than 25% of the value of Goods of the original contract and shall be within one month from the date of expiry of last supply. If the supplier fails to do so, the Procuring Entity shall be free to arrange for the balance supply by limited Bidding or otherwise and the extra cost incurred shall be recovered from the supplier.

3. Dividing quantities among more than one Bidder at the time of award (In case of procurement of Goods)

As a general rule all the quantities of the subject matter of procurement shall be procured from the Bidder, whose Bid is accepted. However, when it is considered that the quantity of the subject matter of procurement to be procured is very large and it may not be in the capacity of the Bidder, whose Bid is accepted, to deliver the entire quantity or when it is considered that the subject matter of procurement to be procured is of critical and vital nature, in such cases, the quantity may be divided between the Bidder, whose Bid is accepted and the second lowest Bidder or even more Bidders in that order, in a fair, transparent and equitable manner at the rates of the Bidder, whose Bid is accepted.

**Signature of Contractor
(PHE-I)
with full address & Mobile No.**

Executive Engineer

JDA, Jaipur

ANNEXURE- I**[Reference Clause 3(i)]**

Signed
Photograph of
Applicant

To be given on Non-Judicial stamp
Paper of Rs. 10/- only,

AFFIDAVIT

I/We..... Proprietor/ Partner/ Authorized signatory of M/s under take the oath that the information furnished by me/us in schedule I to VII of the assessment Bid for is correct to the best of my/our knowledge and nothing has been concealed by me. I acknowledge that if in future any information furnished by me is found incorrect I will be solely responsible and shall be punished as per the law and also any benefits in any form obtained by me shall be recoverable.

.....
Proprietor/ Partner/ Authorized signatory

M/s

.....

Note:-

The applicant has to enclose a self attested photo identity card with the above affidavit.

Annexure E:

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

No. JDA/Ex.En. (TA to Dir. Engg.-I)/2016/D-29

Dated: 11/3/2016

Office Order

Subject: - DLP period for various type of works.

As per the decision taken in the 201st meeting of Executive Committee held on 23.02.2016 w.r.t. agenda no. 201:22, DLP period of various natures of works amounting more than Rs. 25 lakhs has been revised as per following time periods based on nature of works.

This order will supersede the earlier orders issued in this regard i.e. order No. JDA/TA to D(E)/2010-11/D-317 dated 28.04.2011 including Special Condition No. 2.2.2 & 2.2.3 of Annexure-I related to SD refund & forfeiture (other Special Condition of annexure-I of this order will remain valid) and order No. JDA/Ex.En.(Pr.-5 & TA)/2013/D-43 dated 27.02.2013 and also all pertaining orders, in contract agreements or in PWF&AR having DLP period different than what is being enforced through this present order for concerned type of work.

Table-I

S.No.	Type of Work	Existing DLP Period	As per approved in E.C. held on 23.02.2016
1.	Bridge Work	3 years	5 Years
2.	CD Work	3 years	5 Years
3.	CC Road, PQC Work	3 years	5 Years
4.	CC tiles/Kerbs/medians	3 years	5 years
5.	Drains	6 months	3 years
6.	Roads		
	(i) Two layer WBM/CSB	3 years	6 Months or one full rainy season which ever is later
	(ii) For Renewal/Strengthening		
	(a) BT upto 30 mm thickness	3 years	1 year
	(b) BT above 30 mm to upto 40 mm	3 years	2 years
	(c) BT above 40 mm to upto 90 mm	3 years	3 years
	(d) ET Above 90 mm	3 years	5 years
	(iii) New Roads		
	(a) BT upto 90 mm	3 years	3 years
	(b) BT more than 90 mm	3 years	5 years
7.	Compound wall	6 months	3 years
8.	Buildings work		
	(i) Work pertaining to Sanitary works electrical works, Joinery works and painting works.	6 months	2 years
	(ii) Work pertaining to Building structure and other civil works.	6 months	5 years
9.	Electric work except maintenance	6 months	3 years
10.	Sewer/Water supply all including STP and water supply related work except maintenance works.	6 months	3 years ^{4.7}

The release of SD amount shall be as per following table:-

Table-II

S. No.	Released SD DLP period	1 st year	2 nd year	3 rd year	5 th year
1.	Upto 1 year	100%	40%	20% ✓	10%
2.	Upto 2 year		60%	20% ✓	10%
3.	Upto 3 year			60% ✓	10%
4.	Upto 4 year				20%
5.	Upto 5 year				50%

Various conditions for managing DLP are as under:-

- (i) At the time of completion of work, final component shall be worked out for each individual item like BT/CC/tiles/drains etc (as per different categories in Table I), DLP shall be operative based upon type of individual item ex:- CC-5 years, BT- 1/2/3/5 years, Drain- 3 years etc.
- (ii) Similarly for all new works, these components should be calculated at the time of TS itself, which should be made part of BID document.
- (iii) If any work, amount is less than Rs. 25 lakhs but later on due to extra/excess work, if amount of final work crosses more than Rs. 25 lakhs, DLP shall be operative as per rule for each individual item.
- (iv) Similarly if any work is more than Rs. 25 lakhs but after finalization amount of work is less than Rs. 25 lakhs, DLP should be operative for six months or rainy season whichever is late.
- (v) During DLP period if contractor fails to repair any work even after issue of 7 days written notice, same work shall be got executed by respective Executive Engineer at the contractor's risk and cost. This process shall be applicable throughout the DLP period. After completion of DLP period in such works contractor should be debarred and blacklisted from JDA for three years as per RTPP Rule 2012 and 2013 where he defaults twice in a single agreement or in two different works.
- (vi) Quarterly Inspection as per rules shall be carried out and DLP registers shall be maintained by respective Executive Engineers to monitor the DLP repairs.
- (vii) Special and regular inspection shall also be carried out as per order no. JDA/Ex.En & TA to DE-I/2014-15/D-223 dated 12.03.2015 and order no. SE (PMGSY) CIRCULAR 2006/D-115 dated 04.05.2006 Point no. 3.
- (viii) In case JDA feels to take up work on any existing DLP road due to any reason, following procedure should be adopted:
 - (a) At the time of withdrawal total liability of repairs as per DLP conditions to be carried out and contractor shall be asked to complete the same. After completion of assessed repairs DLP period shall be released after deduction amt. as per table III.

Table-III

% Recovery on Withdrawal of DLP, of work order DLP period	1 year	2 year	3 year	4 year	5 year
1 year	1.12	-	-	-	-
2 year	2.55	1.43	-	-	-
3 year	4.38	3.26	1.83	-	-
5 year	9	7.88	6.45	4.62	2.47

Note:- Calculation is to be done on quarterly basis.

(b) In case Contractor fails to carry out these repairs, same shall be carried out at his risk and cost. If the total amt. of such repairs works out to be more than total retained amt. of SD, same shall be recovered from other works and as per PDR rules. The amount as per Table III is also to be deducted in addition to this amount.

(ix) Based upon type of work, DLP conditions for works to be carried out during DLP period with their frequency of respective type of work shall be prepared by respective SE's after approval of these periods.

This order shall come in force with immediate effect and will be applicable on all new works whose NIB is to be called.

Sd/-
Director (Engineering-I)
JDA, Jaipur

Copy to following for information and necessary action:-

1. PS to IDC, JDA, Jaipur.
2. PS to Secretary, JDA, Jaipur.
3. Director Engineer I/II, JDA, Jaipur.
4. Director (Fin.), JDA, Jaipur.
5. C.F, JDA, Jaipur.
6. All Add. Chief Engineers, JDA, Jaipur.
7. All Superintendent Engineers, JDA, Jaipur.
8. OSD (RM), JDA, Jaipur.
9. Additional Director (REV.&DP.)
10. CAO (P&A) JDA, Jaipur.
11. Sr. Horticulturist, JDA, Jaipur
12. All Executive Engineer, JDA, Jaipur.
13. DD (E&B) JDA, Jaipur.
14. All AOs, JDA, Jaipur.
15. All AAOs, JDA, Jaipur.
16. System Analyst
17. All Contractors' Association, JDA, Jaipur.
18. Guard file

Sd/-
S.E. & TA to Dir. (Engg.-I)
JDA, Jaipur

Annexure F:**Jaipur Development Authority, Jaipur****Office Order**

No. : JDA/IT(1074501)/E-Services/2015-16/D-399

Dated: 4-10-2016

Subject: Payment mechanism for participating in tender.

Jaipur Development Authority has decided to receive Earnest Money Deposit (EMD) (Bid Security), Tender Fee and RISL processing fee online through JDA Portal. The bid security options available in tender for participants are as mentioned below:

A. Payment Options:**Option-1: Bank Guarantee (BG) against EMD / Bid Security**

Bidder may opt Bank Guarantee (BG) against EMD (Bid Security), for which bidder requires to prepare BG before applying in the tender. The details of BG requires to be fed on JDA portal before paying balance amount (Tender Fee + RISL Processing Fee). This amount will be paid through **Payment Gateway only**, option to make balance payment through EFT (RTGS/NEFT) will not be available.

If bidder does not opt for BG against EMD, options of making complete payment through Payment Gateway or through EFT (NEFT / RTGS) will be available.

Option-2: Electronic Fund Transfer (EFT: NEFT/RTGS)

If the bidder selects payment mode as EFT (NEFT/RTGS), "Paying Slip for EFT (NEFT/RTGS)" will be generated by the system for the complete amount. The payment can be made from **any Bank any Branch** using this Paying Slip through NEFT/RTGS (Claim against payment made through EFT in any other JDA bank account will not be acceptable and bidder stands disqualified from participation in the bid applied for). After successful transaction through NEFT/RTGS, as per the standard procedures it may take 4 to 24 hours in process of confirmation of EFT through Auto-Process depending on the time of EFT done. Therefore, option to make payment through EFT (NEFT/RTGS) will be available till 2 days prior to closing date of bid participation.

Option-3: Payment Gateway (Aggregator)

The facility to make payment through Debit Card, Credit Card, Net banking etc., will be available. User can use this facility from **anywhere any time** till the closing date & time of bid participation.

B. Bid Participation Receipt

After confirming payment, the bidder will get Bid Participation Receipt on the basis of which user will get the payment details along with other details for bidding on e-Procurement portal of GOR.

- In case of BG as the remaining payment will be done through Payment Gateway, on successful transaction the "Bid Participation Receipt" will be generated on real time basis.

- In case complete payment is done through Payment Gateway, on successful transaction the "**Bid Participation Receipt**" will be generated on real time basis.
- In case complete payment is done through EFT (NEFT/RTGS), on confirmation of payment from ICICI Bank (Auto Process) "**Bid Participation Receipt**" will be available on Login of Bidder on JDA portal.

This payment mechanism will come into force w.e.f 15/10/2016. Thereafter, old payment mechanism related to NEFT/ RTGS in which the bidder makes direct payment without "**Paying Slip for EFT (NEFT/RTGS)**" in JDA's bank account will be discontinued.

All procuring entities are hereby directed to clearly mention this procedure in NIB document.


(Pawan Arora)
Secretary

Copy for information and further necessary action to:

1. P.S. to JDC, JDA, Jaipur.
2. P.S. to Secretary, Secretary, JDA, Jaipur.
3. Director (Law / Finance / Town Planning / Engineering-I / Engineering-II), JDA, Jaipur.
4. All Additional Chief Engineer _____, JDA, Jaipur
5. DC (Administration)/DC(Store)/DC (Vehicle), JDA, Jaipur
6. System Analyst, JDA, Jaipur
7. Analyst-cum-Programmer, JDA to ensure integration of software w.e.f 01/10/2016.
8. All Xen _____, JDA, Jaipur.
9. Officer-in-charge, SPPP Portal, Jaipur.
10. OSD (Public Relation) / PRO, JDA, Jaipur.


(Brijesh Kishore Sharma)
OSD (RM)

Annexure G:

जयपुर विकास प्राधिकरण, जयपुर

क्रमांक :- F-()JDA/Sr.Ao.works-II/2017/D-

172

दिनांक :-

12.7.17

आदेश

1 जुलाई 2017 से भारत सरकार के नोटिफिकेशन द्वारा GST लागू होने के कारण व्यक्तियों/फर्म/कम्पनी/संस्था/टेकेदार के निर्माण/सिविल आपूर्ति/सेवाओं इत्यादि के कार्यों के प्राधिकरण द्वारा बिल भुगतान किये जाने के लिये प्राधिकरण कर सलाहकार चार्टर्ड एकाउन्टेन्ट से प्राप्त हुई राय के क्रम में निम्नांकित प्रमाण पत्र/शपथ पत्र/Invoice बिलों के साथ प्रस्तुत किया जाना सुनिश्चित करावे :-

1. व्यक्ति/फर्म/कम्पनी/संस्था/टेकेदार का GST के अन्तर्गत रजिस्ट्रेशन प्रमाण पत्र की स्व:प्रमाणित फोटो प्रति।
2. व्यक्ति/फर्म/कम्पनी/संस्था/टेकेदार का GST के रजिस्ट्रेशन नहीं होने के स्थिति में स्व:प्रमाणित शपथ पत्र।
3. अप्रजिकृत व्यक्ति/फर्म/कम्पनी/संस्था/टेकेदार के बिलों के भुगतान की स्थिति में मासिक टैक्स Invoice भुगतान-आधिकारी द्वारा मासिक आधार पर उसी माह के अंत में तैयार करवाया जाना सुनिश्चित किया जावेगा।
4. आपूर्ति एवं सेवा के विरुद्ध भुगतान बिलों में Vat/Service Tax चार्ज होने (Vat/Service Tax होने) पर (दिनांक 30.06.17 तक आपूर्ति एवं Invoice जारी करने पर) Taxable Invoice नहीं बनाया जावेगा एवं इनका भुगतान पूर्वानुसार (01.07.2017 से पूर्व निहित प्रक्रिया अनुसार) किया जाना सुनिश्चित करावे।

स्पष्टीकरण :- दिनांक 30.06.17 तक सामान की आपूर्ति के बिलों में Vat Invoice होने पर या अन्यथा होने पर इनका भुगतान पूर्वानुसार 01.07.2017 से पूर्व निहित प्रक्रिया अनुसार किया जावेगा।

संलग्न :- GST रेट तथा HSN/SAC CODE की फोटो प्रति

(बृजेश किशोर शर्मा)
निदेशक(वित्त)

प्रतिलिपि निम्न को सूचनार्थ एवं आवश्यक कार्यवाही हेतु :-

1. वरिष्ठ निजी सचिव, आयुक्त, जविप्रा, जयपुर।
2. वरिष्ठ निजी सचिव, संचिद, जविप्रा, जयपुर।
3. निदेशक (वित्त/विधि/अभियांत्रिकी-प्रथम व द्वितीय/आयोजना/परियोजना, जविप्रा, जयपुर।
4. अतिरिक्त आयुक्त(प्रशासन/पूर्व/पश्चिम/एल.पी.सी./भूमि), जविप्रा, जयपुर।
5. संयुक्त आयुक्त(सिस्टम मैनेजमेन्ट/संसाधन एवं समन्वय), जविप्रा, जयपुर।
6. विशेषाधिकारी(संसाधन विकास), जविप्रा, जयपुर।
7. अतिरिक्त निदेशक(राजस्व एवं सम्पत्ति निस्तारण), जविप्रा, जयपुर।
8. समस्त जोन उपायुक्तगण , जविप्रा, जयपुर।
9. मुख्य लेखाधिकारी(पी. एण्ड ए.), जविप्रा, जयपुर।
10. उपनिदेशक(व्यय एवं बजट), जविप्रा, जयपुर।
11. वरिष्ठ लेखाधिकारी(निर्माण-प्रथम/द्वितीय/आर.सी.आर./पेंशन/नीलामी), जविप्रा, जयपुर।
12. सिस्टम एनालिस्ट, जविप्रा, जयपुर को प्रेषित कर लेख है कि सिस्टम में GST नम्बर सम्मिलित करने एवं Tax Invoice बनाने की प्रक्रिया तैयार करावे।
13. उप रजिस्ट्रार(सहकारिता), जविप्रा, जयपुर।
14. अधिशार्पी अभियन्ता जोन , जविप्रा, जयपुर।
15. वरिष्ठ उद्यानविज्ञ, जविप्रा, जयपुर।
16. लेखाधिकारी (भुगतान/योजना/निर्माण)/सहायक लेखाधिकारी, जविप्रा, जयपुर।
17. प्रभारी अधिकारी, नागरिक सेवाकेन्द्र, जविप्रा, जयपुर।
18. सलाहकार(जनसम्पर्क), जविप्रा, जयपुर।
19. रोकड़ियों(निर्माण/सिविल/भूमि आवांति), जविप्रा, जयपुर।
20. रक्षित पत्रावली

अति.निदेशक(रा.एवं स.नि.)

SPECIAL CONDITIONS

1. If there is any typographical error or otherwise in the 'G' Schedule the rates given in the relevant BSR on which schedule 'G' has been prepared, shall prevail.
2. The contractor shall follow the contractor labour regulation and abolition Act 1970 & Rule 1971.
3. The JDA shall have right to cause on audit and technical examination of the work and the final bills of the contractor including all supporting vouchers, abstract etc. to be made within two years after payment of the final bills and if as a result such audit any amount is found to have been over paid/excess in respect of any work done by the contractor under the contract or any work claimed by him to have been done under this contract and found not to have been executed the contractor shall be liable to refund such amount and it shall be lawful for the JDA to recover such sum from him in the manner prescribed in special condition no. 8 or any other manner legally permissible and if it is found that the contractor was paid less than that was due to him under the contract in respect of any work executed by him under it, the amount of such under payment shall be paid by the JDA to the contractor.
4. Tax exemption/ Tax liabilities if any shall be applicable as per prevailing government rule and bidder has to consider this while quoting the rates.
5. The contractor shall not work after the sunset and before sunrise without specific permission of the authority Engineer.
6. Whenever any claim against the contractor for the payment of a sum of money arises out of or under the contracts, the JDA shall be entered to recover the sum by appropriating in part or whole of the security deposit of the contractor. In the event of the security being insufficient or if no security has been taken from the contractor then the balance of the total sum recoverable as the case may be shall be deducted from any sum then due or which at any time there contract with the JDA should this sum be sufficient to recover the full amount recoverable, the contractor shall pay to JDA on demand the balance remaining due. The JDA shall further have the right to effect such recoveries under P.D.R. Act.
7. The rate quoted by the contractor shall remain valid for a period of 120 days from the date of opening of the tenders.
8. By submission of this tender the contractor agree to abide with all printed conditions provided in the PWD manual from 64 (Chapter 3-para 36) and subsequent modification.
9. No conditions are to be added by the contractor and conditional tender is liable to be rejected.
10. All transaction in the execution of this work and this tender will be liable to GST & other taxes levied by GOR & GOI.
11. If any Bid withdraws his Bid prior to expiry of said validity period given at S.No. 7 or mutually extended prior or makes modifications in the rates, terms and conditions of the tender within the said period which are not acceptable to the department or fails to commence the work in the specified period, fails to execute the agreement and fails to furnish performance guarantee the department shall without prejudice to any, other right or remedy, be at liberty to forfeit the amount of earnest money given in any form absolutely. If any contractor, who having submitted a Bid does not execute the agreement or start the work or does not complete the work and the work has to be put to re-bidding, he shall stand debarred from participating in bidding in JDA for Six Months in addition to forfeiture of Earnest Money / Security Deposit /Performance Guarantee and other action under agreement
12. Rules regarding enlistment of contractors provide that work upto five times limit for which they are qualified for tendering can be allotted to them. Therefore, before tender the contractors will keep this in mind, and submit the details of work. Bids with incomplete or incorrect information are liable to be rejected.
13. Any material not conforming to the specifications collected at site shall have to be removed by the contractor within a period of 3 days of the instructions, issued by the Engineer-Incharge in writing. Failing which, such material shall be removed by the Engineer-Incharge at risk and the contractor after expiry of 3 days period.
14. The material collected at site and paid provisionally shall remain under the watch and ward of the contractor till it is consumed, fully on the work.
15. The rates provided in Bid documents are inclusive of all Taxes, royalty.
16. No extra lead of earth/material shall be paid over and above as specified in 'G' schedule. Source/borrow pit area for earth shall have to be arranged by the Contractor at his own cost.
17. Undersigned has full right to reject any or all Bids without given any reasons.

18. Mortar of Masonry work and lean concrete will be permitted mixer with hopper.
19. As per Supreme Court decision "All contracts with Governments shall require registration of workers under the building and other construction workers (Regulation of Employment and Conditions of Service) Act, 1996 and extension of benefits to such workers under the act."
20. The Bidder are required to submit copy of their enlistment as contractor.
21. Conditions of RPWA-100 will be mandatory & acceptable to the contractor.
22. Any Bid received with unattested cutting/overwriting in rates shall be rejected and such bidder will be debarred from Bidding for three months in JDA.
23. All the provisions of THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT, 2012 and Rules, 2013 will be applicable. If there is any contradictions in existing special conditions and provisions of THE RAJASTHAN TRANSPARENCY IN PUBLIC PROCUREMENT ACT, 2012 and RULES, 2013 shall be applicable.
24. Time period of work can be increased as per RTPP Rules.
25. **"If any bidder quotes a rate below than the schedule "G" rates, i.e. rates below than "at par", then the bidder has to deposit the difference amount i.e. difference amount of the rates as per "at par" and quoted "below", as "Work Performance Guarantee". This amount has to be deposited before the commencement of work and will be refunded after expiry of DLP only in case of satisfactory performance of work during DLP. Lowest bidder will be issued LOA (Letter of Acceptance) and within 14 days period he has to deposit difference amount in the form of B.G/FDR/NSC. The validity of B.G/FDR/NSC shall be for a period three months beyond of DLP period of work. In case of non deposition of the same in specified period, the bid security will be forfeited. In case work is not completed satisfactorily, the "Work Performance Guarantee" will be forfeited and other action will be taken as per Contract Agreement."**

Signature of Contractor
with full address & Mobile No.

Executive Engineer (PHE-I)
JDA, Jaipur



राजस्थान सरकार
वित्त (सामान्य वित्तीय एवं लेखा नियम) विभाग



क्रमांक : एफ.2(1)वित्त/जीएण्डटी-एसपीएफसी/2017 जयपुर, दिनांक : 23.12.2020

परिपत्र

वित्त विभाग की अधिसूचना क्रमांक एफ. 2(1)वित्त/जीएण्डटी - एसपीएफसी/2017 दिनांक 18.12.2020 द्वारा आरटीपीपी नियम, 2013 के नियम 42(2) में संशोधन करते हुए आमंत्रित की जाने वाली आगामी बोलियों के संदर्भ में दिनांक 31.12.2021 तक बिड सिक्यूरिटी राशि प्राप्त नहीं करने एवं इसके स्थान पर बिड सिक्यूरिटी के संबंध में घोषणा पत्र (Declaration) प्राप्त करने का प्रावधान किया गया है।

चूंकि उक्त नियमों में बिड सिक्यूरिटी राशि के स्थान पर बिड सिक्यूरिटी के संबंध में घोषणा पत्र (Declaration) प्राप्त करने का नवीन प्रावधान किया गया है। अतः समस्त उपापन संस्थाओं के उपयोगार्थ बिड सिक्यूरिटी के संबंध में लिए जाने वाले घोषणा पत्र (Declaration) का मानक प्रारूप संलग्न प्रेषित है। राजस्थान स्टाम्प अधिनियम, 1998 की धारा 3 सपठित अनुसूची के अनुच्छेद 4 के अनुसार घोषणा पत्र (Declaration) पर 50/- रुपये स्टाम्प ड्यूटी देय है तथा इस स्टाम्प ड्यूटी की राशि पर नियमानुसार 30 प्रतिशत सरचार्ज देय है। अतः समस्त उपापन संस्थाओं को निर्देशित किया जाता है कि बिड सिक्यूरिटी के संबंध में प्रस्तुत किए जाने वाले घोषणा पत्र (Declaration) पर उक्तानुसार राजस्थान राज्य में स्टाम्प ड्यूटी एवं सरचार्ज का भुगतान सुनिश्चित करावें।

संलग्न- उपरोक्तानुसार

(विमल कुमार गुप्ता)
संयुक्त शासन सचिव

प्रतिलिपि निम्नांकित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित है:-

1. सचिव, राज्यपाल/प्रमुख सचिव, मुख्यमंत्री/विशिष्ट सहायक समस्त मंत्रीगण/राज्य मंत्रीगण ।
2. उप सचिव, मुख्य सचिव/निजी सचिव, समस्त अति. मुख्य सचिव/प्रमुख शासन सचिव/ शासन सचिव/विशिष्ट शासन सचिव ।
3. सचिव, राजस्थान विधानसभा, राजस्थान, जयपुर ।
4. सचिव, लोकायुक्त सचिवालय, राजस्थान, जयपुर ।
5. सचिव, राजस्थान लोक सेवा आयोग, अजमेर ।
6. रजिस्ट्रार, राजस्थान उच्च न्यायालय जोधपुर/जयपुर ।
7. प्रधान महालेखाकार ए एण्ड ई राजस्थान जयपुर ।
8. प्रधान महालेखाकार ऑडिट राजस्थान जयपुर ।
9. समस्त संयुक्त शासन सचिव/उप शासन सचिव/सचिवालय के समस्त अनुभाग/विभाग ।
10. समस्त विभागाध्यक्ष/जिला कलक्टर/संभागीय आयुक्त ।
11. रजिस्ट्रार, राजस्थान सिविल सेवा अपील अधिकरण, जयपुर ।
12. समस्त वित्तीय सलाहकार/मुख्य लेखाधिकारी ।
13. समस्त कोषाधिकारी ।
14. समस्त उपापन संस्थाएं ।
15. तकनीकी निदेशक वित्त विभाग को भेजकर लेख है परिपत्र को वित्त विभाग की वेबसाइट पर प्रकाशित करवाने की व्यवस्था करावें ।
16. रक्षित पत्रावली ।

23/12/2020
संयुक्त शासन सचिव

Form of Bid-Securing Declaration

Date :
Bid No. :
Alternative No. :

To :

We, the undersigned, declare that:

We understand that, according to your conditions, bids must be supported by a Bid-Securing Declaration.

We accept that we are required to pay the bid security amount specified in the Term and Condition of Bid, in the following cases, namely :-

- (a) when we withdraw or modify our bid after opening of bids;
- (b) when we do not execute the agreement, if any, after placement of supply/work order within the specified period;
- (c) when we fail to commence the supply of the goods or service or execute work as per supply/work order within the time specified;
- (d) when we do not deposit the performance security within specified period after the supply/work order is placed; and
- (e) if we breach any provision of code of integrity prescribed for bidding specified in the Act and Chapter VI of these rules.

In addition to above, the State Government shall debar us from participating in any procurement process undertaken for a period not exceeding three years in case where the entire bid security or any part thereof is required to be forfeited by procuring entity.

We understand this Bid Securing Declaration shall expire if :-

- (i) we are not the successful Bidder;
- (ii) the execution of agreement for procurement and performance security is furnished by us in case we are successful bidder;
- (iii) thirty days after the expiration of our Bid.
- (iv) the cancellation of the procurement process; or
- (v) the withdrawal of bid prior to the deadline for presenting bids, unless the bidding documents stipulate that no such withdrawal is permitted.

Signed :-----

Name :-----


In the capacity of :-----

Duly authorized to sign the bid for and on behalf of :

Dated on day of

Corporate Seal -----

[Note: In case of a Joint Venture, the Bid Securing Declaration must be signed in name of all partners of the Joint Venture that is submitting the bid.]



ANNEXURE- II

Bank Guarantee Performa for Bid security deposit
Form of (Bank Guarantee) -En cashable at branch of the bank in Jaipur City.

To
 Secretary,
 Jaipur Development Authority,
 Jaipur

Sub:

Bank Guarantee No. _____ dated _____ for [amount of Security in figures] [in words] on behalf of _____ [Name of the Bidder] against the Security Deposit for the work of **"P/L/J of DI/HDPE pipe line and construction of 2 nos. 200 mm dia tube well with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur."**

WHEREAS, _____ [name of Bidder with address] (hereinafter called "the Bidder") has submitted his Bid dated for the work of **"P/L/J of DI/HDPE pipe line and construction of 2 nos. 200 mm dia tube well with 3 years O&M for water supply scheme Shiv Enclave, JDA, Jaipur."** (Name of Work) (Hereinafter called "the Bid").

KNOW ALL PEOPLE by these presents that we _____
 _____ (Name of Bank) of having our registered office at _____ [name of country] having our registered office at _____ (hereinafter called "the Bank") are bound unto Secretary, Jaipur Development Authority. (Hereinafter called "the Employer") in the sum of Rupees _____ [Amount of Security in figures] _____ (in words) only for which payment will and truly to be made to the said Employer, the Bank binds itself, its successors, and assigns by these presents.

That on demand of JDA , this Bank Guarantee is encashable at following branch in Jaipur City.

1. Name of Bank:
2. Name of the branch with branch code:
3. Address:
4. E-Mail Id:
5. Telephone No.
6. Fax No.:

SEALED with the Common Seal of the said Bank this _____ day of _____ of 20____.

THE CONDITIONS of this obligation are:

- (1) if the Bidder withdraws his Bid during the period of Bid validity specified in the Form of Bid;
- (2) if the Bidder refuses to accept the correction of errors in his bid;
- (3) If the Bidder, having been notified of the acceptance of his Bid by the Employer during the period of Bid validity;

- (a) fails or refuses to execute the Form of Agreement in accordance with the Instructions to Bidders, or
(b) fails or refuses to furnish the Performance Security, in accordance with the Instructions to Bidders;

We undertake to pay to the Employer up to the above amount upon receipt of his first written demand, without the Employer having to substantiate his demand, provided that in his demand the Employer will note that the amount claimed by him is due to him owing to the occurrence of one or more of the above conditions, specifying the occurred condition or conditions.

This Guarantee will remain in force up to and including the date 30 days after the date of expiration of the Bid Validity, as stated in the Instructions to Bidders, or any such extension thereto as may be agreed by the Bidder, notice of which extension(s) to the Bank is hereby waived. Any demand in respect of this Guarantee should reach the Bank not later than the above date.

The amount covered under the above Bank Guarantee shall be automatically be credited in the accounts of JDA in ICICI Bank, JDA Campus, Jaipur through ISFC code No ICICI 006754. Bank Account No. 675401700518 on the date of expiry or its validity, unless the agencies get it re-validated well before its expiry date or produce NOC from JDA in written for its release.

Date _____ Signature of the Bank _____

Witness _____ Seal _____

[Signature, Name and Address]

[Note: To be furnished on appropriate non-judicial stamps.]

PAYMENT MECHANISM FOR PARTICIPATING IN TENDER

Jaipur Development Authority has decided to receive Earnest Money Deposit (EMD) (Bid Security) Tender fee online through JDA portal. The bid security options available in tender for participants are as mentioned below :

A. Payment Options:

Option-1: Bank Guarantee (BG). against EMD / Bid Security

Bidder may opt Bank Guarantee (BG) against EMD (Bid Security) for which bidder requires to prepare BG before applying in the tender. The details of BG requires to be fed on JDA portal before paying balance amount (Tender Fee). This amount will be paid through **Payment Gateway only**, option to make balance payment through EFT (RTGS/NEFT) will not be available

If bidder does not opt for BG against EMD, options of making complete payment through Payment Gateway or through EFT (NEFT/RTGS) will be available

Option-2: Electronic Fund Transfer (EFT: NEFT/RTGS)

If the bidder selects payment mode as EFT (NEFT/RTGS) **"Paying Slip for EFT (NEFT/RTGS)"** will be generated by the system for the complete amount. The payment can be made from **any Bank any Branch** using this Paying Slip through NEFT/RTGS (Claim against payment made through EFT in any other JDA bank account will not be acceptable and bidder stands disqualified from participation in the bid applied for). After successful transaction through NEFT/RTGS, as per the standard procedures it may take 4 to 24 hours in process of confirmation of EFT through Auto-Process depending on the time of EFT done. Therefore, option to make payment through EFT (NEFT/RTGS) will be available till 2 days prior to closing date of bid participation.

Option-3: Payment Gateway (Aggregator)

The facility to make payment through Debit Card, Credit Card, Net banking etc., will be available. User can use this facility from **anywhere any time** till the closing date & time of bid participation

B. Bid Participation Receipt

After confirming payment, the bidder will get Bid Participation Receipt on the basis of which user will get the payment details along with other details for bidding on e-Procurement portal of GOR

- In case of BG as the remaining payment will be done through Payment Gateway, on successful transaction the **"Bid Participation Receipt"** will be generated on real time basis
- In case complete payment is done through Payment Gateway, on successful transaction the **"Bid Participation Receipt"** will be generated on real time basis
- In case complete payment is done through EFT (NEFT/RTGS), on confirmation of payment from ICICI Bank (Auto Process) **"Bid Participation Receipt"** will be available on Login of Bidder on JDA portal.

-SD-
Executive Engineer (PHE-I)
JDA, Jaipur

Section A6

Drawings

Section A-7

Bill of Quantities

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of work:- P/L/J of DI/HDPE pipe line with construction of 2 Nos 200 mm Dia tube well with 3 years O&M for Water supply scheme Shiv Enclave, JDA, Jaipur.

Estimate**Part 'A' - (BSR ITEMS)**

Providing, Laying & Jointing of DI/HDPE water pipe lines complete

Based on JDA PHE BSR-2016

S. No.	PARTICULARS	Qty.	Unit	Rate	AMOUNT (in Rs.)
1	Providing laying & Jointing of ISI mark centrifugally cast (Spun) ductile iron pressure pipe for water with socket and spigot end and Tyton joint confirming to IS 8329/2000 and departmental specification in standard length (As required) for (Class K-7) suitable for push on joint (rubber gaskets jointing) with side cement mortar lining with cutting of pipe and fixing of C.I. special joint where ever required. This also include the excavation of trench up to 1.5 Meter depth in all type of soil cutting of road surface pavement where required lift up to 1.5 Mt. stacking the soil clear form the edge of excavation andrefiling of soil after laying and jointing of pipe line with proper compaction and disposing of all surplus soil as directed with in lead of 30 Meter. This also include getting the pipe line tested and site clearance etc.(D-878 dt.01.09.2008)				
1.1	100 mm	600.00	P. Meter	1397.00	838200.00
2	Providing/fixing/testing KG of DI specials (K-7) i.e. bend, tees, tail pieces, flanges etc. of various size as per the site condition and requirement including all jointing material in all respects, As per PHED specification. (D-306 dt. 28.04.2009)	100.00	Kg.	90.00	9000.00
3	Providing, fabricating and installing MS specials including rolling, cutting, welding in different shape and size. (D-547 dt. 20.12.2011)	200.00	Kg.	80.00	16000.00
4	Labour charges for inter connection of proposed pipe line with existing, pipe line by digging of Pit, cutting of pipe, without bailing out of water and satisfactory testing of inter connection and site clearance. (D-547 dt. 20.12.2011)	10.00	Each	890.00	8900.00
5	Supply of cast iron detachable joints class-10 as per ISI specification (IS 8794-1988) along with rubber ring (ISI marked) and nut bolts complete as per PHED specificatins. (D-547 dt. 20.12.2011)				

5.1	100 mm	35.00	Each	274.00	9590.00
6	Supply and fixing of cast iron double sluice valves IS 14846/2000 specification (ISI marked) of PN-1 rating including cost of rubber flange gasket and nut bolts complete as required for following sizes. (D-547 dt. 20.12.2011)				
6.1	100 mm	8.00	Each	5541.00	44328.00
7	Supply of cast iron specials (class-10) as per IS : 5531-1988) specification as required. (D-547 dt. 20.12.2011)				
7.1	80 mm to 150 mm	400.00	Kg.	58.00	23200.00
8	Providing, Laying & Jointing in standard lengths HDPE PE-80 PN-6 pipes conforming to IS-4984:1995 (UP TO DATE) with necessary jointing material like mechanical connection i.e. thread/insert/quick release coupler joint/compression fitting joint of flanged joint and specials jointing pipe by butt fusion welding method, including all taxes (central and local), transportation and freight charges inspection charges loading/unloading charges, stacking the same in closed shade duly protecting from sunray and rain including cost of labour and material, specials (Tees, bend etc.) and also including the excavation of trench up to 1.5 Meter depth in all type of soil cutting of road surface pavement where required lift up to 1.5- Mt. stacking the soil clear from the edge of excavation and refilling of soil after laying and jointing of pipe line with proper compaction and disposing of all surplus soil as directed with in lead of 50 Meter with satisfactory, hydraulic testing etc. complete as per technical specifications and direction of Engineer-in-charge. (supply up to 90 mm dia. Coil & above 90 mm dia straight length in 6.0 M)				
8.1	90 mm dia	2300.00	Mtr.	318.00	731400.00
8.2	110 mm dia	1200.00	Mtr.	441.00	529200.00
Total Part-A				Rs.	2209818.00
Say				Rs.	2209818.00

Executive Engineer (PHE-I)
JDA, Jaipur

I/We Quote as % Above/ Below the schedule " G "

(In Words.....)'

Signature of Contractor
With full Address & Mobile No.

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

Name of work:- P/L/J of DI/HDPE pipe line with construction of 2 Nos 200 mm Dia tube well with 3 years O&M for Water supply scheme Shiv Enclave, JDA, Jaipur.

Estimate**Part 'B' -BSR Items**

Construction of 200 mm dia tubewells with pumping machineraies & allied works.

Based on JDA PHE BSR-2016

S. No.	PARTICULARS	Qty.	Unit	Rate	AMOUNT (in Rs.)
	Part-I				
1	Construction of Tube-well upto 100 Meter depth and above in all type of rocks by DTH system and over burden, to accommodate casing pipe of following sizes in all types of soils and over burden including lowering of casing pipes, but excluding cost of casing pipes as per IS : 2800 (Part I & II) 1979 specifications. The work would be completed after obtaining sand free water. The tube well should have a throughout bore as per nominal dia of casing pipe:				
1.1	200 mm dia Nominal bore	220.00	R.Mtr.	742.50	163350.00
2	Construction of <i>tube-well</i> from ground levels and upto 100 Meter depth and above to accommodate housing and assembly pipe of following sizes in all types of alluvium strata by percussion/ rotary drilling method and with gravel as per IS:4097-1967 and packing as per IS:2800 (Part I -& II) 1979 as amended upto date (the work includes the cost of gravel & its primary packing and packing during development, lowering of housing & strainer assembly pipes, with supply and wrapping of coir-rope, wherever necessary, for arresting fine sand particles. The work will not include cost of housing pipe and strainer pipe assembly and development work, but work would be completed after obtaining sand free water).				
2.1	200 mm Nominal bore	180.00	R.Mtr.	1089.00	196020.00
3	Development of tube well as per IS specification using suitable compressor to give sand free water for required yield of the gravel packed tube well.	30.00	Hours	445.50	13365.00
4	Supply of <i>ERW M.S. black casing pipe</i> ISI marked (IS:4270/1992) of grade Fe410 of following sizes at site of work. Nominal bore of pipe (mm)				
4.1	200 Nominal bore of pipe (mm)	144.00	Mtr.	1413.00	203472.00
5	Supply of <i>strainer pipes</i> made of ERW M.S. black pipe ISI mark of following sizes at the site of work including required size of slotting as per IS:8110-1985.				
5.1	200 mm Nominal bore	36.00	Mtr.	1638.00	58968.00

6	P/Laying ISI marked P.V.C. insulated submersible cable confirming to IS:694 with flexible copper conductor including making connection etc. as required.				
6.1	4.0 Sq.mm 3 core flat / Round	320.00	Mtr.	102.40	32768.00
7	SITC of radial / mixed flow submersible motor pump sets ISI marked (IS:8034-1989) of approved make with required accessories including making connection suitable for T.W./ D.C.B./Open well. The job includes lowering of riser pipe, G.I./ H.D.P.E. pipe with rope, cables, installation of complete fitting and accessories, jointing of electrical cables up to switch board. All labour for testing of submersible pumps set and supply of water to water mains, complete in all respect. 150 mm diameter Submersible pump shall have following HP Rating, phase, Head, minimum Discharge respectively.				
7.1	10.0 HP, 3-Ø, (93-200)Mtr, (240-60)LPM Complete Rate Group-I	2.00	Each	29752.80	59505.60
8	Providing & lowering of G.I. Pipes, flange pipe including rubber washer and nuts of 8 mm dia complete in all respect I.S.1239 Marked.				
8.1	B Class 50 mm dia	280.00	R.Mtr.	369.00	103320.00
9	P & F G.I. Pipes (External Work) with G.I. fittings excluding union (IS : 1239 Mark) including trenching & refilling earth etc. 65mm dia nominal bore				
9.1	B' Class	60.00	Mtr.	381.60	22896.00
10	P & F G.I. Pipes (External Work) with G.I. fittings excluding union (IS : 1239 Mark) including trenching & refilling earth etc. 50mm dia nominal bore				
10	B class	30.00	Mtr.	302.40	9072.00
11	P & F Full-way Valve (IS:778 Mark) or wheel valve of approved make :				
11	Gun-Metal 50mm nominal bore	2.00	Each	1084.50	2169.00
12	Providing fixing and installation of 80 mm dia Woltman type water Each meter with material (Flanges,Insertion sheet, Nut bolt etc.) &fabrication supply and fixing of meter box made of 10 SWG MS sheetsuitable for 80 mm water meter (As per drawing including all accessories.) 50 mm to 80 mm dia (D-547 dt. 20.12.2011)	2.00	Each	22997.00	45994.00
13	Providing and installing of approved make spring loaded dual plate check valve of following dia. Including all taxes , inspection charges, loading and unloading, stacking etc., including cost of all labour, jointing material with nut bolts, rubber mats etc., and giving satisfactory hydraulic field testing, complete as per specifications.(D-547 dt. 20.12.2011)				

13	50 mm	2.00	Each	1571.00	3142.00
14	Supply and fixing & testing of feeder type penal board suitable for upto 15 HP electric motor having star delta/ DOL starter (L&T /BCH), MCB 32 amp.(havals /L&T), capacitor 3 KVR (L&T/Havals), Single phase priventor(L&T/havals),indicating lamp RYB , Amp. Meter (0 to 30Amp) , Volt Meter with selector switch (0 to 500 V) size 100 mm, kit kat fuse unit 100 amp,backlite sheet for fixing of 3 phase electric meter of JVVNL electric feeder penal approved as per design and specification mounted on angle iron fram and fixed plain on plain cement concrete plateform, size of feeder penal box 900X 450X1200mm (D-547 dt. 20.12.2011)				
14	Star Delta above 5 HP to 15 HP	2.00	Each	24915.00	49830.00
15	S&F tube well cover (for 200 mm dia pipe) of MS sheet 8 mm thick at top & 5 mm thick 100 mm wide shroud around the edge so as to form a cap on the top end of casing pipe with GI Nipple 45 cm long & two GI flanger at both end in 80 mm sizes passing through a hole in the centre of MS shet A 25 mm socket with end plug shall also be weld over top plate (as per drawing enclosede), A GI nipple having outside thread of size 1/2" (for installation pressure gauge) shall be provide & welded with GI 80 mm nipple near top plate nipple shall be provided with end plug.) (D-547 dt. 20.12.2011)	2.00	Each	908.00	1816.00
16	P/Laying P.V.C. / XLPE insulated & P.V.C. sheathed cable of 1.1 KV grade with aluminium conductor of IS:1554 P-I / IS :7098 P - I of Group 1 of approved make in ground as per IS:1255 including excavation of 30cmx75cm size trench, 25 cm thick under layer of sand,IInd class bricks covering, refilling earth,compaction of earth, making necessary connection, testing etc. as required of size.				
16	10.0 Sq. mm 4 core Complete Rate Armoured	60.00	Mtr.	136.00	8160.00
Total Part-B				Rs.	973847.60
Say				Rs.	973848.00

Executive Engineer (PHE-I)
JDA, Jaipur

I/We Quote as % Above/ Below the schedule " G "

(In Words.....)'

Signature of Contractor
With full Address & Mobile No.

JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

**Name of work:- P/L/J of DI/HDPE pipe line with construction of 2 Nos
200 mm Dia tube well with 3 years O&M for Water
supply scheme Shiv Enclave, JDA, Jaipur.**

Estimate**Part 'C'**

Operation & Maintenance of water supply scheme for 3 years

(NON BSR ITEMS)

S. No.	PARTICULARS	Qty.	Unit	Rate	AMOUNT (in Rs.)
1	Operation and maintenance of all the newly developed water supply assets under this contract as per scope of work including cost of consumable material for maintenance and spares (excluding electrical charges and chemical charges)	36.00	Per Month		
	Total Part-C Rs.				

**Executive Engineer (PHE-I)
JDA, Jaipur**