



JAIPUR DEVELOPMENT AUTHORITY, JAIPUR

www.jda.urban.rajabasthan.gov.in

532

No. JDA/EE (Elect-I)/2023/D-950

Date: 07/04/23

Minutes of Pre-Bid Meeting held on 02.08.2023

1. Name of Work: - Electrification (SITC of 33/0.4 KV GIS Sub-station, DG Set & Bus trunking etc.) of IPD Tower and Institute of Cardio Vascular Science building at SMS Hospital, Jaipur.
2. NIT No. :- 13/2023-24 published on 27.07.2023
3. Pre-bid Meeting held on 02.08.2023 in Manthan Hall, JDA, Jaipur.
4. The following prospective bidders/ representatives attend the meeting and briefed about the project, technical terms & conditions of qualification criteria and about payment terms etc. :-
 - i. M/s CG Power and Industrial Solutions Ltd. ; Mr. Somendra Vishwakarma (Query Sent by E-Mail)
 - ii. M/s Captiva Energy Solutions Pvt. Ltd.; Mr. Dharmendra Gupta (Query in pre-bid meeting)
 - iii. M/s L&T Electrical & Automation. ; Mr. Sushant Rathi & Mr. Sanjay Kasoti (Query in pre-bid meeting)
 - iv. M/s C&S Electric Ltd. ; Mr. Samir Ranjan Ray & Mr. Ravi Singh (Query in pre-bid meeting)
 - v. M/s ABB India Ltd.; Mr. Shipin Rathi, Mr. Mukul Khandal & Mr. Pulkit Bhatt
 - vi. M/s Engineer & Engineer ; Mr. Amit Gautam
 - vii. M/s SPL.; Mr. Naveen Sharma
 - viii. M/s Rajesh Power; Mr. Jitendra Sharma
 - ix. M/s SUPL; Mr. Abhishek Bhardwaj
 - x. M/s ICS.; Mr. Shubham Badgoti
 - xi. M/s K3 Construction Company; Mr. Sitaram Jat
5. Following officers of JDA were also present in pre-bid meeting :-
 - i. Director (Engg-I), JDA, Jaipur.
 - ii. SE-II, JDA, Jaipur.
 - iii. Executive Engineer (Elect-I), JDA, Jaipur.
 - iv. Assistant Engineer (Elect-I), JDA, Jaipur.

6. After briefing about the project, the pre-bid queries were started by bidders. The decision taken are as follows which will become the part of tender documents :-

S. No.	Relevant clause no. page no.	As per Bid Document	Pre-Bid Queries	Clarification from JDA
1.	M/s CG Power and Industrial Solutions Ltd. ; Mr. Somendra Vishwakarma (Query Sent by E-Mail)			
i	General		Request for CG Name Inclusion Under NIB 13/2023-24/GIS Sub-Station	As per Bid Documents
2.	M/s Captiva Energy Solutions Pvt. Ltd.; Mr. Dharmendra Gupta (Query in pre-bid meeting)			
i	General		Request for Enlistment of Captiva Make in the Make list of DG Sets	As per Bid Documents
3.	M/s L&T Electrical & Automation. ; Mr. Sushant Rathi & Mr. Sanjay Kasoti (Query in pre-bid meeting)			
i			2500 Amps 4 pole horizontal drawout type air circuit breaker 433V AC, 50Hz AC operation of fault breaking capacity 50 kA (Ics = Icu = Icw =100%) for 1 sec. electrically operated (EDO), with RS 485 Port on Modbus protocol along with Touch Screen Display, fitted with interlocked door, automatic safety shutters, mechanical ON/OFF and service/test/isolated position indicators, zone selective interlocking, ready to close, over temperature protection, thermal memory and frame earthing contact, conforming to IEC 60947/IS-13947/Part- II/1993 latest version as amended up-to-date complete with following accessories for each ACB. a) Independent electrical and manual spring closing mechanism -	As per Bid Documents

			1 No. b) Microprocessor releases based release for adjustable setting for over current, earth fault & short circuit protection with 4 line LCD (R,Y,B,N) with bar graph display for % loading of phases. all three current, neutral current and Voltage, release should self-powered requiring no external power supply, protection against phase unbalance and residual current, over temperature protection with 20 fault history and event history and inbuilt zone selective interlocking in-built thermal memory, 4NO/4NC auxiliary contacts with one trip contact, counting the number of operations and contact wear (ACB Life). confirming to IEC:60947/IS:13947, Part-II/1993 (latest version)		
	10 Page No. 17	Relays & Timer	ABB/SCHNEIDER/SIEMENS	Request you to kindly include L&T as a approved make in make list	As per Bid Documents
	Panel Buidner	No panel builder name specified in IEC 61439 panels	Request you to include OEM/OEM Franchise Partner as Panel Builders	Panel builder will be OEM/OEM Franchise Partner	
4.	M/s C&S Electric Ltd. ; Mr. Samir Ranjan Ray & Mr. Ravi Singh (Query in pre-bid meeting)				
i		Incorporation of C&S Make Switchgear in IPD Tower, SMS, Jaipur Tender		As per Bid Documents	

Assistant Engineer (Elect-I)
JDA, Jaipur

Executive Engineer (Elect-I)
JDA, Jaipur

SE-II
JDA, Jaipur

Director (Engg-I)
JDA, Jaipur